



- 1 3-terminal capacitor provides off-cycle crankcase heat.
- 2 Set heat anticipator at .40A.
- 3 For 208V operation move this wire to 208V transformer tap.

Fused Disconnect Switch

USE COPPER OR ALUMINUM WIRE

FACTORY WIRING	FIELD WIRING
Low Voltage ———	-----
High Voltage ———	-----

MODEL P24A2 w/5Kw

230/208y 60 Hz 1-Ph