



⚠ See alternate thermostat sheet.  
Set heat anticipator at .40A.

- NOTE A: 4 Ton Capacitor - 15/370V  
5 Ton Capacitor - 7 1/2/370V
- NOTE B: 4 Ton Capacitor - 40/440V  
5 Ton Capacitor - 45/440V

USE COPPER OR ALUMINUM WIRE

Single Package  
Air Conditioner  
4 and 5 Ton  
w/3Kw

Fused  
Disconnect  
Switch

230/208V 60 Hz 1-Ph

Factory Wiring \_\_\_\_\_  
Field Wiring - - - - -

P48A4, P60A4

4002-120C