



1 See alternate thermostat sheet.
Set heat anticipator at .40A.

- NOTE A: 4 Ton Capacitor - 15/370V
 5 Ton Capacitor - 7 $\frac{1}{2}$ /370V
- NOTE B: 4 Ton Capacitor - 40/440V
 5 Ton Capacitor - 45/440V

USE COPPER OR ALUMINUM WIRE

Single Package Air Conditioner
 4 and 5 Ton w/10Kw

Fused Disconnect Switch

230/208V 60 Hz 1-Ph

Factory Wiring _____
 Field Wiring - - - - -