



⚠ See alternate thermostat sheet.  
Set heat anticipator at .40A.

USE COPPER OR ALUMINUM WIRE

Fused Disconnect Switch  
230/208V 60 Hz 3-Ph

Single Package Air Conditioner  
4 and 5 Ton  
w/9Kw

Factory Wiring \_\_\_\_\_  
Field Wiring - - - - -