



T874C1000 Thermostat  
Q674A1001 Subbase

or

T872C1004 Thermostat  
Q672A1005 Subbase

NEC Class 2  
24V Wiring

24V Terminal  
Block

Outdoor  
Motor

Compressor  
Contactor

Capacitor  
(See Note A)

Blower  
Relay

Indoor Motor

Transformer

Heater  
Contactors

Thermal  
Cut-offs

Electric  
Heaters

Equip.  
Ground

USE COPPER OR  
ALUMINUM WIRE

- ⚠ Add jumper Rc to Rh. Set heat anticipators at .40A.
- ⚠ Remove jumper for 2-stage heat.
- ⚠ Set heat anticipators for W1 and W2 at .40A.

NOTE A: 4 Ton Capacitor - 15/370V  
5 Ton Capacitor - 7½/370V

Single Package  
Air Conditioner  
4 and 5 Ton  
w/12 or 15kw

Fused  
Disconnect  
Switch

230/208V 60 Hz 3-Ph

Factory Wiring ———  
Field Wiring - - - -