



T874C1000 Thermostat  
Q674A1001 Subbase

or

T872C1004 Thermostat  
Q672A1005 Subbase <sup>3</sup>

NEC Class 2  
24V Wiring

24V Terminal  
Block

10/370V Capacitor

Blower  
Relay

Indoor Motor

Transformer

Heater  
Contactors

Thermal  
Cut-offs

Electric  
Heaters

230V Terminal  
Block

Equip.  
Ground

USE COPPER OR  
ALUMINUM WIRE

- 1 Add jumper Rc to Rh. Set heat anticipators at .40A
- 2 Remove jumper for 2-stage heat.
- 3 Set heat anticipators for W1 and W2 at .40A.

NOTE A: 4 Ton Capacitor - 15/370V  
5 Ton Capacitor - 7 1/2/370V

Single Package  
Air Conditioner  
4 and 5 Ton  
w/18kw

Fused  
Disconnect  
Switch

230/208V 60 Hz 3-Ph

Factory Wiring ———  
Field Wiring - - - - -