



Fused Disconnect Switch
415/380-50-3

USE COPPER OR ALUMINUM WIRE

NOTE A: 4 Ton Capacitor - 15/370V
5 Ton Capacitor - 7½/370V

Single Package Air Conditioner
4 and 5 Ton
w/9 Kw @ 415 Volt

- ① Add jumper Rc to Rh. Set heat anticipators at .40A.
- ② Remove jumper for 2-stage heat.
- ③ Set heat anticipators for W1 and W2 at .40A.

Factory Wiring _____
Field Wiring - - - - -