



Emergency Signal Light

T872C1004 Thermostat
Q672F1025 Subbase ¹

NEC Class 2
24V Wiring

- ¹ Set heat anticipators at .40A
- ² Reroute jumper from X2-W2 to X2-E.

USE COPPER OR ALUMINUM WIRE

Factory Wiring _____
Field Wiring - - - - -

Single Package
Heat Pump
3-Ton
w/12 or 15kw