



Equip. Ground

USE COPPER OR ALUMINUM WIRE

- ⚠ Capacitor provides off-cycle crankcase heat.
- ⚠ See alternate thermostat sheet. Set heat anticipator at .40A.
- ⚠ For 208V operation move this wire to 208V transformer tap.

MODELS
20WA2, 24WA5
W/4 OR 5 KH

FACTORY WIRING FIELD WIRING
Low Voltage ———
High Voltage ———