


8201-040 Resistor
1.8 Megohm
3-Minutes

8201-039
Time Delay

Low Ambient Control
CO @ 200 PSIG
CI @ 250 PSIG

15/10-370V
Run
Capacitor

ACCUSTAT
LMS-AHII



24V
Terminal
Block

Outdoor
Motor

208V
24V Transformer

7.5/370 Capacitor

Blower
Relay

7.5/370
Capacitor

Indoor
Motor

Limit

8201-039
Time Delay

8201-040
Resistor
1.8 Megohm
3-Minutes

Heater
Contactor

Equip.
Ground

Thermal
Cut-off

Electric
Heater

240V Terminal Block

LL3 LL1

USE COPPER OR
ALUMINUM WIRE

⚠ Capacitor provides off-cycle crankcase heat.

⚠ For 208V operation move this wire to 208V transformer tap.

Fused
Disconnect
Switch

MODELS
20WA1 & 20WA2
w/ SKW
Catalog No. 05A34

230/208-60-1

Factory Wiring
Field Wiring

4007- 829A