



T872C1004 Thermostat
 Q672A1005 Subbase
 or
 T874C1000 Thermostat
 Q674A1001 Subbase

NEC Class 2
 24V Wiring

USE COPPER OR
 ALUMINUM WIRE

⚠ See alternate thermostat sheet. Set heat
 anticipator at .40A.

⚠ For 208V operation move this
 wire to 208V transformer tap.

Fused
 Disconnect
 Switch

230/208-60-1

Factory Wiring _____
 Field Wiring - - - - -

MODELS
 24WA4
 w/8 or 10Kw