



⚠ T87F or 1F56
Thermostat

NEC Class 2
24V Wiring

24V
Terminal
Block

Run
Capacitor
35/370

5/370
Motor
Capacitor

24V
Transformer

5 MFD
Capacitor

Blower
Relay

LOW (RED)

Indoor
Motor

HIGH
(BLACK)

Outdoor
Motor

Equip.
Ground

**USE COPPER
CONDUCTORS-ONLY**

⚠ See alternate thermostat sheet.
Set heat anticipator at .40A.

⚠ For 208V operation move this
wire to 208V transformer tap.

Fused
Disconnect
Switch

230/208-60-1

FACTORY WIRING	FIELD WIRING
Low Voltage ———	—————
High Voltage ———	—————

4008-110L