



T872R1164/0672L1185
or
T874R1129/0674L1181



40/440
Capacitor

Compressor
Fault
Relay

COMPRESSOR CONTACTOR

Transformer

208V

24V

High-Pressure
Switch

Reversing Valve
Solenoid (24V)

Blower
Relay

Em. Heat
Relay

HIGH (BLACK)

LOW (RED)
Indoor
Motor

10/370
Capacitor

OUTDOOR
MOTOR

Capacitor
15/370

Defrost Thermostat

Defrost
Timer

LIMIT

Heater
Contactors

T2 T1
T2 T1
L2 L1

50A Circuit Breaker
(42WH)

60A Circuit Breaker
(48WH5)

60A Circuit Breakers

Blue

Brown

Yellow

Thermal
Cutoff

Red

Electric
Heater

EQUIP
GROUND

⚠ If there is an X1 and X2
terminal on Q674L1181,
Jumper them together and
connect from C to either one

FACTORY WIRING	FIELD WIRING
Low Voltage	-----
High Voltage	-----

USE COPPER OR
ALUMINUM WIRE

⚠ For 208V operation move this
wire to 208V transformer tap.