



T872N1036/Q672F1299 or T874N1024/Q674F1261

X G R Y1 W1 W2 W3 E L

T872R1164/Q672L1185  
T874R1129/Q674L1181

X2 X1 G R Y1 B W2 W3 E L

C G R Y1 Y1 B W1 W2 W3 E L D1 D2

24V Terminal Block

Compressor

Internal Overload

Immersion Crankcase Heater

Compressor Contactor

Transformer

208V

24V

High Pressure Switch

Blower Relay

Defrost Relay

Black

HIGH

Reversing Valve Solenoid (24V)

Defrost Thermostat

Capacitor 15/370

Outdoor Motor

10/370 Capacitor

Indoor Motor

Defrost Timer

Terminal Block

LL3

LL2

LL1

Equip. Ground

Fused Disconnect Switch

⚠ If there is an X1 and X2 terminal on Q674L1181, jumper them together and connect from C to either one.

USE COPPER OR ALUMINUM WIRE

	FACTORY WIRING	FIELD WIRING
Low Voltage	_____	-----
High Voltage	_____	-----

MODEL  
42WH-3, 48WH5-3  
HEAT PUMP  
0 Kw

⚠ For 208V operation move this wire to 208V transformer tap 4014-210X

230/208-60-1