



T872N1036/Q672F1299 or T874N1024/Q674F1261

X G R Y1 W1 W2 W3 E L

T872R1164/Q672L1185
T874R1129/Q674L1181

X2 X1 G R Y1 B W2 W3 E L

C G R Y Y1 B W1 W2 W3 E L D1 O1

24V Terminal Block

Compressor

Internal Overload

Immersion Crankcase Heater

Compressor Contactor

Transformer

208V

24V

High Pressure Switch

Blower Relay

Reversing Valve Solenoid (24V)

Defrost Relay

Capacitor 15/370

Outdoor Motor

Black HIGH

Indoor Motor LOW (RED)

10/370 Capacitor

Defrost Thermostat

Defrost Timer

Terminal Block

LL3 LL2 LL1

Equip. Ground

Fused Disconnect Switch

230/208-60-3

⚠ If there is an X1 and X2 terminal on Q674L1181, jumper them together and connect from C to either one.

USE COPPER OR ALUMINUM WIRE

	FACTORY WIRING	FIELD WIRING
Low Voltage	_____	-----
High Voltage	_____	-----

⚠ For 208V operation move this wire to 208V transformer tap

4014-210P