



T872N1036/Q672F1299 or T874N1024/Q674F1261

T872R1164/Q672L1185
T874R1129/Q674L1181

24V Terminal Block

208V

Transformer

High Pressure Switch

Blower Relay

Reversing Valve Solenoid (24V)

Defrost Relay

Capacitor 15/370

Outdoor Motor

Defrost Thermostat

Defrost Timer

(See Chart A) Fuse Panel

Limit

Thermal Cutoff

Heater Contactor

Indoor Motor

10/370 Capacitor

Electric Heater

Equip. Ground

230/208-60-3

CHART A	
Fuse A	42WH-3, 48WH5-3, 40A T.D., 45A T.D.
Fuse B	.40A Standard for 12Kw, .45A Standard for 18Kw

ALL FUSES CLASS K5

⚠ If there is an X1 and X2 terminal on Q674L1181, jumper them together and connect from C to either one.
⚠ For 208V operation move this wire to 208V transformer tap.

MODEL
42WH-3, 43WH5-3
HEAT PUMP
w/12, 15 Kw

USE COPPER OR ALUMINUM WIRE

FACTORY WIRING FIELD WIRING
Low Voltage ————
High Voltage - - - - -

4014-230 P