



TB72N1036/Q672F1299  
or  
TB74N1024/Q674F1261

TB72R1164/Q672L1185  
or  
TB74R1129/Q674L1181

24V Terminal Block

Transformer

24V

High Pressure Switch

Blower Relay

Em. Heat Relay

Reversing Valve Solenoid (24V)

Defrost Thermostat

Defrost Relay

Outdoor Motor

Capacitor 15/370

Heating Blower Relay

10/370 Capacitor

Indoor Motor

Limit

Heater Contactor

Terminal Block

Equip. Ground

Thermal Cut-off

Electric Heater

LL31 LL21 LL11

LL31 LL21 LL11

CKT. A

CKT. B

USE COPPER OR ALUMINUM WIRE

Fused Disconnect Switch

If there is an X1 and X2 terminal on Q674L1181, jumper them together and connect from C to either one.

MODEL 48WH2 HEAT PUMP w/18KW

FACTORY WIRING      FIELD WIRING  
Low Voltage      High Voltage

230/208-60-3

4014-240H