



T872N1036/Q672F1299 or T874N1024/Q674F1261

T872R1164/Q672L1185

T874R1129/Q674L1181

24V Terminal Block

Transformer

208V

24V

High Pressure Switch

Blower Relay

Em. Heat Relay

Defrost Relay

Outdoor Motor

Capacitor 15/370

Heating Blower Relay

HIGH

10/370 Capacitor

LOW

Indoor Motor

Limit

Heater Contactor

Equip. Ground

Thermal Cut-off

Electric Heater

Reversing Valve Solenoid (24V)

Defrost Thermostat

Defrost Timer

(See Chart A) Fuse Panel

CHART A

	42WH-3	48WH5-3
Fuse A	40A T.D.	45A T.D.
Fuse B	60A Standard	

ALL FUSES CLASS K5

FACTORY WIRING	FIELD WIRING
Low Voltage	-----
High Voltage	-----

⚠ If there is an X1 and X2 terminal on Q674L1181, jumper them together and connect from C to either one.

MODEL  
42WH-3, 48WH5-3  
HEAT PUMP  
w/18KW

USE COPPER OR ALUMINUM WIRE

230/208-60-3

⚠ For 208V operation move this wire to 208V transformer tap.

4014-240S