



T872N1036/Q672F1299 or T874N1024/Q674F1261
 T872R1164/Q672L1185
 T874R1129/Q674L1181

24V Terminal Block

Transformer
 208V 24V
 High Pressure Switch

Blower Relay

Em. Heat Relay

Heating Blower Relay

Indoor Motor
 HIGH (BLACK) (RED)
 LOW
 10/370 Capacitor

Defrost Relay
 Outdoor Motor
 Capacitor 15/370

Reversing Valve Solenoid (24V)
 Defrost Thermostat
 Defrost Timer

Limit

Heater Contactor

(See Chart A) Fuse Panel

Equip. Ground

Thermal Cut-off

Electric Heater

USE COPPER OR ALUMINUM WIRE

CHART A		
	42WH-3	48WH5-3
Fuse A	40A T.D.	45A T.D.
Fuse B	60A Standard	

ALL FUSES CLASS K5

FACTORY WIRING FIELD WIRING
 Low Voltage ———
 High Voltage ———

⚠ If there is an X1 and X2 terminal on Q674L1181, jumper them together and connect from C to either one.

230/208-60-3

⚠ For 208V operation move this wire to 208V transformer tap.

4014-240V