



T872n1036/0672F1299 or T874N1024/a674F1261

T872R1164/0672L1185
T874R1129/0674L1181

24V Terminal Block

Compressor

Internal Overload

Immersion Crankcase Heater

Compressor Contactor

Transformer

208V

High Pressure Switch

Blower Relay

Defrost Relay

Outdoor Motor

Capacitor 15/370

Heating Blower Relay

10/370 Capacitor

Indoor Motor

Limit

Heater Contactor

Reversing Valve Solenoid (24V)

Defrost Thermostat

Defrost Timer

40A Circuit Breaker (42WH-3)

45A Circuit Breaker (48WH5-3)

60A Circuit Breaker

Equip. Ground

Thermal Cut-off

Electric Heater

⚠ If there is an X1 and X2 terminal on Q674L1181, jumper them together and connect from C to either one.

FACTORY WIRING	FIELD WIRING
Low Voltage ———	-----
High Voltage ———	-----

⚠ For 208V operation move this wire to 208V transformer tap.

USE COPPER OR ALUMINUM WIRE

CKT. A

CKT. B

230/208-60-3

4014-241F