



X G R Y1 W1 W2 W3 E L  
 TB72N1036/Q672F1299  
 or  
 TB74N1024/Q674F1261

X2 X1 G R Y1 B W2 W3 E L  
 TB72R1164/Q672L1185  
 or  
 TB74R1129/Q674L1181

C G R Y1 Y1 B W1 W2 W3 E L DH DI

24V  
Terminal  
Block

Compressor Contactor

Transformer

High Pressure  
Switch

Capacitor  
15/370

Outdoor  
Motor

Blower Relay

10/370V  
Capacitor

Indoor  
Motor

Outdoor  
Motor Relay

Defrost  
Relay

Defrost  
Thermostat

Defrost  
Timer

230V Terminal  
Block

230

Transformer

460

Terminal  
Block

LL3 LL2 LL1

Equip.  
Ground

⚠ If there is an X1 and X2 terminal on Q674L1181, jumper them together and connect from C to either one.

Fused  
Disconnect  
Switch

460-60-3

USE COPPER OR  
ALUMINUM WIRE

	FACTORY WIRING	FIELD WIRING
Low Voltage	—————	- - - - -
High Voltage	—————	- - - - -

MODEL  
48WH2  
HEAT PUMP  
0 Kw

4014-3106