



X G R Y1 W1 W2 W3 E L T872N1Q36/Q672F1299  
OR  
T874N1Q24/Q674F1261

X2 X1 G R Y1 B W2 W3 E L T872R1164/Q672L1185  
OR  
T874R1129/Q674L1181

C G R Y Y1 B W1 W2 W3 E L DH O1

24V Terminal Block

230V Terminal Block

230

460

Transformer

Terminal Block

L1 L2 L3

Equip. Ground

Fused Disconnect Switch

460-60-3

USE COPPER OR ALUMINUM WIRE

- ⚠ If there is an X1 and X2 terminal on Q674L1181, jumper them together and connect from C to either one.
- ⚠ For 208V operation move this wire to 208V transformer tap.

FACTORY WIRING		FIELD WIRING	
Low Voltage	—————	-----	-----
High Voltage	—————	-----	-----

MODEL  
48WH12, 48WH5  
HEAT PUMP  
0 Kw