



X G R Y1 W1 W2 W3 E L  
 TA72N1036/Q672F1299  
 OR  
 TB74N1024/Q674F1261

X2 X1 G R Y1 B W2 W3 E L  
 TB72R1164/Q672L1185  
 OR  
 TB74R1129/Q674L1181

C G R Y Y1 B W1 W2 W3 E L DH O1

24V  
 Terminal  
 Block

230V Terminal  
 Block

230  
 460  
 Transformer

Terminal  
 Block  
 LL3 LL2 LL1

Equip.  
 Ground

USE COPPER OR  
 ALUMINUM WIRE

⚠ If there is an X1 and X2 terminal on Q674L1181,  
 jumper them together and connect from C to  
 either one.  
 ⚠ For 208V operation move this  
 wire to 208V transformer tap.

MODEL  
 48WH12, 48WH5  
 HEAT PUMP  
 0 Kw

FACTORY WIRING    FIELD WIRING  
 Low Voltage ———  
 High Voltage - - - -

Fused  
 Disconnect  
 Switch

460-60-3

4014-310W