



T872N1036/Q672F1299 or T874N1024/Q674F1261

T872R1164/Q672L1185
or
T874R1129/Q674L1101



24V Terminal Block

High Pressure Switch

Blower Relay

Reversing Valve Solenoid (24V)

Defrost Relay

HIGH (BLACK)

LOW (RED)

Capacitor 10/370

10/370 Capacitor

Outdoor Motor

Defrost Thermostat

Limit

Heater Contactor

Defrost Timer

(See Chart A) Fuse Panel

Thermal Cutoff

Electric Heater

Equip. Ground

230/208-50-3

CHART A	
Fuse A	42UH-3 48WH5-3
Fuse B	40A T.D. 45A T.D.
Fuse C	40A Standard for 12Kw 45A Standard for 15Kw

ALL FUSES CLASS K5

⚠ If there is an X1 and X2 terminal on Q674L1181, jumper them together and connect from C to either one.
⚠ For 208V operation move this wire to 208V transformer tap.

USE COPPER OR ALUMINUM WIRE

FACTORY WIRING	FIELD WIRING
Low Voltage	-----
High Voltage	-----

4014-530 A