



TB72N1036/Q672F1299
or
TB74N1024/Q674F1261

TB72R1164/Q672L1185
or
TB74R1129/Q674L1181

24V Terminal Block

Outdoor Thermostat
Set at 45 F

Transformer

200V

24V

High Pressure Switch

Blower Relay

Defrost Relay

Capacitor
15/370

10/370
Capacitor

Reversing
Valve
Solenoid
(24V)

Defrost
Thermostat

Limit

Heater
Contactor

Indoor
Motor

Fuse
Panel

Equip. Ground

Thermal
Cut-off

Electric
Heater

Fuse A - 45A Time Delay
Fuse B - 30A Standard

⚠ If there is an X1 and X2 terminal on Q674L1181, Jumper them together and connect from C to either one.

⚠ For 208V operation move this wire to 208V transformer tap.

MODEL
48WH2 / 48WH5
HEAT PUMP
w/ 9 KW

USE COPPER OR
ALUMINUM WIRE

230/208-60-3

| | |
|------------------|--------------|
| FACTORY WIRING | FIELD WIRING |
| Low Voltage ——— | ----- |
| High Voltage ——— | ----- |

4014-805 A