



TB72H1036/Q672F1295  
or  
TB74H1024/Q674F1261

TB72R1164/Q672L1185  
or  
TB74R1129/Q674L1181

24V Terminal Block

Outdoor Thermostat Set at 45 F.

10/370 Capacitor

Fuse A - 45A Time Delay  
Fuse B - 30A Standard

USE COPPER OR ALUMINUM WIRE

⚠ If there is an X1 and X2 terminal on Q674L1181, jumper them together and connect from C to either one.  
⚠ For 208V operation move this wire to 208V transformer tap.

FACTORY WIRING	FIELD WIRING
Low Voltage _____	High Voltage - - - - -

MODEL  
48WH2, 48WH5  
HEAT PUMP  
w/9 KW

230/208-60-3

1014-8053