



| MODEL | CAPACITOR |
|--------|-----------|
| 30HPQ4 | 40/370 |
| 36HPQ4 | 40/440 |

REFER TO INSTALLATION INSTRUCTIONS FOR CONTROL CIRCUIT WIRING

24V Terminal Board

⚠ Reconnect from 5-60, to 5-30 for 30 minute cycle.

| FACTORY WIRING | FIELD WIRING |
|------------------|--------------|
| Low Voltage ——— | ----- |
| High Voltage ——— | ----- |

USE COPPER WIRE ONLY

MODELS
30HPQ4 1-Ph
36HPQ4 1-Ph

230/208-60-1