



- 1 Reroute jumper from X2-W2 to X2-E.
- 2 Set heat anticipators at .40A for W1

Fused Disconnect Switch

USE COPPER OR ALUMINUM WIRE

Factory Wiring \_\_\_\_\_

Field Wiring - - - - -

Single Package Heat Pump 5-Ton

208/230V 60 Hz 1-Ph

4036-110