

T874R1129/Q674L1181
THERMOSTAT TERMINALS

1 IF FURNACE IS EQUIPPED WITH
ONLY A 12VA OR 20VA TRANSFORMER
IT MUST BE REPLACED WITH A
FAN CENTER HAVING A 40VA
TRANSFORMER (BARD PART # 8201-006)

FURNACE
24V
CONNECTIONS

1 FURNACE FAN CENTER (40VA)
OR ELECTRONIC BLOWER CONTROL
(CC/CH SERIES FURNACES)

8603-006
SOLENOID VALVE

ALL WIRING IS LOW VOLTAGE FIELD INSTALLED

24V TERMINAL STRIP

TYPICAL CONNECTION TO GAS FURNACE

4050-804

