



COMPONENT CODE			
BIR	BLOWER INTERLOCK RELAY	DFC	OUTDOOR FAN CAPACITOR
CC	COMPRESSOR CONTACTOR	OFM	OUTDOOR FAN MOTOR
COMP	COMPRESSOR	PL1	PLUG #1
DCC	DUAL CAN CAPACITOR	PL2	PLUG #2
GND	EQUIPMENT GROUND	PL3	PLUG #3
HPC	HIGH PRESSURE CONTROL	PM	PHASE MONITOR
LAC	LOW AMBIENT CONTROL	T	TRANSFORMER
LPB	LOW PRESSURE BYPASS	TB	TERMINAL BLOCK
LPC	LOW PRESSURE CONTROL	TBL	LOW VOLTAGE TERMINAL BLOCK
		TDR	TIME DELAY RELAY

A B LABELED WIRES CONNECT IF NO OPTIONS USED.
 C MOVE ORANGE WIRE TO 208V TAP FOR 208V OPERATION

HIGH VOLTAGE	FACTORY STD.	FIELD	OPTIONAL	COLOR CODE							
				BK	BR	Y	G	V (PR)	T PK	TAN	
LOW VOLTAGE	—	- - -	— · —	BLACK	BROWN	GREEN	YELLOW	VIOLET	PURPLE	GRAY	LAVENDER
ACCESSORY	— · —	- - -	— · —	RED	ORANGE	WHITE	BLUE	GY (S)	SLATE		

**BARD MFG. CO.**  
 4063-806