



COMPONENT CODE			
BIR	BLOWER INTERLOCK RELAY	LPC	LOW PRESSURE CONTROL
CC	COMPRESSOR CONTACTOR	DFM	OUTDOOR FAN MOTOR
CCM	COMPRESSOR CONTROL MODULE	PL1	PLUG #1
COMP	COMPRESSOR	PL2	PLUG #2
DCC	DUAL CAN CAPACITOR	PL3	PLUG #3
GND	EQUIPMENT GROUND	T	TRANSFORMER
HPC	HIGH PRESSURE CONTROL	TB	TERMINAL BLOCK
LAC	LOW AMBIENT CONTROL	TBL	LOW VOLTAGE TERMINAL BLOCK
LPB	LOW PRESSURE BYPASS		

230/208-60-1 USE COPPER CONDUCTORS ONLY
 240/220-50-1 SUITABLE FOR AT LEAST 75° C
 PER NAMEPLATE

LABELED WIRES CONNECT IF NO OPTIONS USED. MOVE ORANGE WIRE TO 208V TAP FOR 208V OPERATION

	FACTORY STD.	FIELD	OPTIONAL
HIGH VOLTAGE	————	- - - -	— · — ·
LOW VOLTAGE	————	- - - -	— · — ·
ACCESSORY	————	- - - -	— · — ·

COLOR CODE						
BK	BLACK	Y	YELLOW	V	VIOLET	T
BR	BROWN	G	GREEN	(PR)	PURPLE	PK
R	RED	BL	BLUE	GY	GRAY	L
O	ORANGE	W	WHITE	(S)	SLATE	

BARD MFG. CO.
 4064-119 B