



- △ TBU & GND FIELD MOUNTED ON CONTROL PANEL OF UNIT
- △ USE COPPER CONDUCTORS SUITABLE FOR AT LEAST 75°C
- △ 50 MZ APPLICATION NOT ILL USED
- FUSE A - 50A CLASS K-5 240V
- FUSE B - 30A CLASS K-5 240V

COMPONENT CODE		COLOR CODE				BOARD OPT. CO.		
FB	FUSE BLOCK	BK	BR	R	O			
GND	EQUIPMENT GROUND	BR	BR	R	O			
H1	HEAT STRIP #1	Y	G	BL	W	V	T	TAN
H2	HEAT STRIP #2	Y	G	BL	W	V	P	PINK
HC1	HEATER CONTACTOR #1	Y	G	BL	W	V	L	LAVERNE
HC2	HEATER CONTACTOR #2	Y	G	BL	W	V	L	LAVERNE
HR	HEATING BLOWER RELAY	Y	G	BL	W	V	L	LAVERNE
LS	LIMIT SWITCH	Y	G	BL	W	V	L	LAVERNE
PL1	PLUG #1	Y	G	BL	W	V	L	LAVERNE
TBU	TERMINAL BLOCK J	Y	G	BL	W	V	L	LAVERNE
TCU	THERMAL OUTFIT	Y	G	BL	W	V	L	LAVERNE