




⚠ THERMOSTAT/SUBBASE
T874R1129/Q674L1181



UNIT 24V
TERMINAL BLOCK



TAPE OFF THIS LEAD



H600A 1014
HUMIDITY CONTROL
(OPTIONAL) ⚠

SOLENOID VALVE
(OPTIONAL)



SET ADJUST HEAT ANTICIPATOR AT .45A



REFER TO SECTION "HUMIDITY CONTROL" FOR SET UP

| | FACTORY WIRING | FIELD WIRING |
|--------------|-------------------|-----------------|
| LOW VOLTAGE | _____ | ----- |
| HIGH VOLTAGE | ————— | ----- |