



COMPONENT CODE			
CB1	CIRCUIT BREAKER #1	IBC	INDOOR BLOWER CAPACITOR
CB2	CIRCUIT BREAKER #2	IBM	INDOOR BLOWER MOTOR
CC	COMPRESSOR CONTACTOR	IBR	INDOOR BLOWER RELAY
CCH	COMPRESSOR CRANKCASE HEATER	LAC	LOW AMBIENT CONTROL
COMP	COMPRESSOR	LS	LIMIT SWITCH
CR1	CONTROL RELAY 1	OFM	OUTDOOR FAN MOTOR
CR2	CONTROL RELAY 2	PL1	PLUG #1
DCC	DUAL CAN CAPACITOR	SV	SOLENOID VALVE
GND	EQUIPMENT GROUND	SK	START KIT
H1	HEAT STRIP #1	T	TRANSFORMER
H2	HEAT STRIP #2	TB	TERMINAL BLOCK
HC1	HEATER CONTACTOR #1	TBL	LOW VOLTAGE TERMINAL BLOCK
HC2	HEATER CONTACTOR #2	TCD	THERMAL CUTOFF
HPC	HIGH PRESSURE CONTROL	TDR, TOR2	TIME DELAY RELAY

⚠ Labeled wires connect if no options used.			⚠ Move red wire to 208V tap for 208V operation			⚠ Red (low) Black (high) wires applicable				
HIGH VOLTAGE			LOW VOLTAGE			ACCESSORY				
FACTORY STD.	FIELD	OPTIONAL	COLOR CODE							
—	- - -	- · - · -	BK	BLACK	Y	YELLOW	V	VIOLET	T	TAN
—	- - -	- · - · -	BR	BROWN	G	GREEN	(PR)	PURPLE	PK	PINK
—	- - -	- · - · -	R	RED	BL	BLUE	GY	GRAY	L	LAVENDER
—	- - -	- · - · -	O	ORANGE	W	WHITE	(S)	SLATE		
BARD MFG. CO.										
4095-118 C										