



COMPONENT CODE			
CB1	CIRCUIT BREAKER #1	IBC	INDOOR BLOWER CAPACITOR
CB2	CIRCUIT BREAKER #2	IBM	INDOOR BLOWER MOTOR
CC	COMPRESSOR CONTACTOR	IBR	INDOOR BLOWER RELAY
COMP	COMPRESSOR	LAC	LOW AMBIENT CONTROL
CR1	CONTROL RELAY 1	LS	LIMIT SWITCH
CR2	CONTROL RELAY 2	OFM	OUTDOOR FAN MOTOR
DCC	DUAL CAN CAPACITOR	PL1	PLUG #1
GND	EQUIPMENT GROUND	SV	SOLENOID VALVE
H1	HEAT STRIP #1	SK	START KIT
H2	HEAT STRIP #2	T	TRANSFORMER
HC1	HEATER CONTACTOR #1	TB	TERMINAL BLOCK
HC2	HEATER CONTACTOR #2	TBL	LOW VOLTAGE TERMINAL BLOCK
HPC	HIGH PRESSURE CONTROL	TCO	THERMAL CUTOFF
		TDR, TDR2	TIME DELAY RELAY

A LABELED WIRES CONNECT IF NO OPTIONS USED.
 B MOVE RED WIRE TO 208V TAP FOR 208V OPERATION
 C RED (LOW) BLACK (HIGH) WERE APPLICABLE

HIGH VOLTAGE	FACTORY STD.			FIELD			OPTIONAL			COLOR CODE							
	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---
LOW VOLTAGE	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---
ACCESSORY	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---
BK	BLACK	Y	YELLOW	V	VIOLET	T	TAN										
BR	BROWN	G	GREEN	(PR)	PURPLE	PK	PINK										
R	RED	BL	BLUE	GY	GRAY	L	LAVENDER										
O	ORANGE	W	WHITE	(S)	SLATE												

BARD MFG. CO.
4095-136