



USE COPPER CONDUCTORS
ONLY SUITABLE FOR AT
LEAST 75° C

COMPONENT CODE

ALR	ALARM RELAY	HPC	HIGH PRESSURE CONTROL
CB1	CIRCUIT BREAKER #1	HSS	HIGH SPEED SOLENOID
CB2	CIRCUIT BREAKER #2	IBM	INDOOR BLOWER MOTOR
CC	COMPRESSOR CONTACTOR	LAC	LOW AMBIENT CONTROL
CCH	CRANKCASE HEATER	LBL	LINE BREAK LIMIT
CCM	COMPRESSOR CONTROL MODULE	LPC	LOW PRESSURE CONTROL
CHR	CRANKCASE HEATER RELAY	LS	LIMIT SWITCH
COMP	COMPRESSOR	DFM	OUTDOOR FAN MOTOR
DCC	DUAL CAN CAPACITOR	PTCR	PART TIME CAP. RELAY
GND	EQUIPMENT GROUND	P1	ACCESSORY PLUG #1
H1	HEAT STRIP #1	P2	ACCESSORY PLUG #2
H2	HEAT STRIP #2	T	TRANSFORMER
HC1	HEATER CONTACTOR #1	TB, TB2	TERMINAL BLOCK
HC2	HEATER CONTACTOR #2	TBL	LOW VOLTAGE TERMINAL BLOCK

▲ LABELED WIRES CONNECT
IF NO OPTIONS USED.

▲ MOVE RED WIRE TO 208V
TAP FOR 208V OPERATION

▲ IBM TIME DELAY DISABLE

	FACTORY STD.	FIELD	OPTIONAL
HIGH VOLTAGE	————	----	-----
LOW VOLTAGE	-----	----	-----
ACCESSORY	-----	----	-----

COLOR CODE			
BK	BLACK	Y	YELLOW
BR	BROWN	G	GREEN
R	RED	BL	BLUE
O	ORANGE	W	WHITE
V	VIOLET	(PR)	PURPLE
GY	GRAY	(S)	SLATE
T	TAN	PK	PINK
L	LAVENDER		

BARD MFG. CO.

4095-141 B

