



▲ LABELED WIRES CONNECT IF NO OPTIONS USED.    ▲ MOVE RED WIRE TO 208V TAP FOR 208V OPERATION    ▲ IBM TIME DELAY DISABLE

	FACTORY STD.	FIELD	OPTIONAL	COLOR CODE							
HIGH VOLTAGE	————	— — — —	— · — ·	BK	BLACK	Y	YELLOW	V	VIOLET	T	TAN
LOW VOLTAGE	————	— · — ·	— — — —	BR	BROWN	G	GREEN	(PR)	PURPLE	PK	PINK
ACCESSORY	————	— · — ·	— — — —	R	RED	BL	BLUE	GY	GRAY	L	LAVENDER
	————	— · — ·	— — — —	O	ORANGE	W	WHITE	(S)	SLATE		

COMPONENT CODE			
ALR	ALARM RELAY	HPC	HIGH PRESSURE CONTROL
CB1	CIRCUIT BREAKER #1	HSS	HIGH SPEED SOLENOID
CB2	CIRCUIT BREAKER #2	IBM	INDOOR BLOWER MOTOR
CC	COMPRESSOR CONTACTOR	LAC	LOW AMBIENT CONTROL
CCH	CRANKCASE HEATER	LPC	LOW PRESSURE CONTROL
CCN	COMPRESSOR CONTROL MODULE	LS	LIMIT SWITCH
CHR	CRANKCASE HEATER RELAY	DFM	OUTDOOR FAN MOTOR
COMP	COMPRESSOR	PTCR	PART TIME CAP. RELAY
DCC	DUAL CAN CAPACITOR	P1	ACCESSORY PLUG #1
GND	EQUIPMENT GROUND	P2	ACCESSORY PLUG #2
H1	HEAT STRIP #1	T	TRANSFORMER
H2	HEAT STRIP #2	TB, TB2	TERMINAL BLOCK
HC1	HEATER CONTACTOR #1	TBL	LOW VOLTAGE TERMINAL BLOCK
HC2	HEATER CONTACTOR #2	TCD	THERMAL CUTOFF

**BARD MFG. CO.**  
4095-141