



COMPONENT CODE			
CB1	CIRCUIT BREAKER #1	IBR	INDOOR BLOWER RELAY
CB2	CIRCUIT BREAKER #2	LOR	LOCK OUT RELAY
CC	COMPRESSOR CONTACTOR	LPB	LOW PRESSURE BYPASS
CCH	CRANKCASE HEATER	LPC	LOW PRESSURE CONTROL
CHR	CRANKCASE HEATER RELAY	LS	LIMIT SWITCH
COMP	COMPRESSOR	OFC	OUTDOOR FAN CAPACITOR
GND	EQUIPMENT GROUND	OFM	OUTDOOR FAN MOTOR
H1	HEAT STRIP #1	PL1	PLUG #1
H2	HEAT STRIP #2	SK	START KIT
HC1	HEATER CONTACTOR #1	T	TRANSFORMER
HC2	HEATER CONTACTOR #2	TB	TERMINAL BLOCK
HPC	HIGH PRESSURE CONTROL	TBL	LOW VOLTAGE TERMINAL BLOCK
IBC	INDOOR BLOWER CAPACITOR	TCO	THERMAL CUTOFF
IBM	INDOOR BLOWER MOTOR	TDR	TIME DELAY RELAY

**A** LABELED WIRES CONNECT IF NO OPTIONS USED. **△** MOVE RED WIRE TO 208V TAP FOR 208V OPERATION **△** RED (LOW) BLACK (HIGH)

HIGH VOLTAGE LOW VOLTAGE ACCESSORY	FACTORY STD.			FIELD			OPTIONAL			COLOR CODE							BARD MFG. CO. 4095-219 B					
	————	-----	-----	————	-----	-----	————	-----	-----	BK	BR	R	O	Y	G	BL		W	V (PR)	GY (S)	VIOLET PURPLE	GRAY SLATE