



For Vent Wiring or controller/thermostat connections, see literature packet or go to www.bardhvac.com

460-60-3
Per Nameplate L1 L2 L3
Hi Voltage
Field Connections

R Vent
option only

Ground Lug (11)

Ground Eyelet Green

Purple/White
Black/White

3-Way Valve

Yellow
Black
Red

Compressor

Outdoor Fan Motor

Black
Red

Low Ambient Control (opt.)

Hi Press. Control

Low Press. Control

Outdoor Temp Switch (Opt.)

Condenser Section

WARNING
USE COPPER CONDUCTORS
ONLY SUITABLE FOR AT LEAST
75°C.

DANGER
*ELECTRICAL SHOCK HAZARD
*DISCONNECT POWER BEFORE
SERVICING.

	Factory	Field	Optional
High Voltage			
Low Voltage			

Wire Identification numbers for Bard use only.
4107-307 A

A → **A**
Same Letter Designated
Wires Connect if Option Not Used
"A" & "C" No Control Option
"B" Only Freeze Stat & No ODT

NOTE: JUMPER PLUG MUST BE INSTALLED WHEN NO VENT OPTION IS INSTALLED