



For Vent Wiring or controller/thermostat connections, see literature packet or go to [www.bardhvac.com](http://www.bardhvac.com)

R Vent option only

460-60-3  
Per Nameplate L1 L2 L3  
Hi Voltage  
Field Connections

Ground Lug (11)

Ground Eyelet Green

Purple/White  
Black/White

3-Way Valve

Yellow  
Black  
Red

Compressor

Green  
Blue  
Yellow

Black  
Red

Outdoor Fan Motor

Low Ambient Control (opt.)

Hi Press. Control

Low Press. Control

Outdoor Temp Switch (Opt.)

Condenser Section

**WARNING**  
USE COPPER CONDUCTORS  
ONLY SUITABLE FOR AT LEAST  
75°C.

**DANGER**  
ELECTRICAL SHOCK HAZARD  
DISCONNECT POWER BEFORE  
SERVICING.

|              | Factory | Field | Optional |
|--------------|---------|-------|----------|
| High Voltage |         |       |          |
| Low Voltage  |         |       |          |

Wire Identification numbers for Bard use only.  
**4107-307 B**

**A** → **A**  
Same Letter Designated  
Wires Connect if Option Not Used  
"A" & "C" No Control Option  
"B" Only Freeze Stat & No ODT

NOTE: JUMPER PLUG MUST BE INSTALLED WHEN NO VENT OPTION IS INSTALLED