



**CAPACITOR CHART**  
**MODEL CAPACITOR**  
 PH13602 5/370

Compressor

Low Pressure Bypass

Emergency Heat Relay

Heat Pump Control

Note: Factory set on 60 min. cycle. Reconnect on 30 min. for 30 min. cycle or 90 min. for 90 min. cycle.

SEN JMP SPEEDUP 90 60 30

	Factory	Field	Optional
High Voltage			
Low Voltage			

460-60-3 Diagram

**WARNING**  
 USE COPPER CONDUCTORS ONLY SUITABLE FOR AT LEAST 75° C.

**DANGER**  
 \*ELECTRICAL SHOCK HAZARD  
 \*DISCONNECT POWER BEFORE SERVICING.

99 Wire Identification numbers for Bard use only.

**Bard**  
 SINCE 1914  
 Bard Mfg. Co.  
 Bryan, Ohio

4110-304

460-60-3

Indoor Section

4 pin plug for Indoor Blower Motor  
 L1 G L2 C

5 pin plug for Indoor Blower Motor  
 5 4 3 2 1

6 pin plug for Heater Package  
 3 2 6 1 5

SEN JMP SPEEDUP 90 60 30

Note: Factory set on 60 min. cycle. Reconnect on 30 min. for 30 min. cycle or 90 min. for 90 min. cycle.

Heat Pump Control

Emergency Heat Relay

Low Pressure Bypass

Compressor

**CAPACITOR CHART**  
**MODEL CAPACITOR**  
 PH13602 5/370

