


DUAL FUEL ADD-ON HEAT PUMP GUIDE FOR OPERATIONAL COST SAVINGS

REGION 4

BARD MANUFACTURING COMPANY, BOX 607, BRYAN, OHIO 43506

(419) 636-1194

**MANUAL 2100-072 REV. E
SUPERSEDES REV. D**



REGION HEATING LOAD HOURS

| Region | HLHr |
|--------|------|
| I | 750 |
| II | 1250 |
| III | 1750 |
| IV | 2250 |
| V | 2750 |
| VI | 2750 |

This map is reasonably accurate for the most parts of the United States but is necessarily highly generalized and consequently not too accurate in mountainous regions, particularly in the Rockies.

TABLE OF CONTENTS

| | |
|-------------------------------|----|
| General Description | i |
| How To use | ii |

| Heat Pump Outdoor Model | Heat Pump Indoor Model | Furnace Fuel | Furnace AFUE Efficiency Rating | Page |
|----------------------------|---------------------------|--------------|-----------------------------------|------|
| WQS30A | A36AQ-A | Electric | 100% | 1 |
| | | Natural Gas | 78% | 2 |
| | | Oil | 78% | 3 |
| | | Propane | 78% | 4 |
| WQS36A | A36AQ-A | Electric | 100% | 5 |
| | | Natural Gas | 78% | 6 |
| | | Oil | 78% | 7 |
| | | Propane | 78% | 8 |
| WQS42A | A42AQ-A | Electric | 100% | 9 |
| | | Natural Gas | 78% | 10 |
| | | Oil | 78% | 11 |
| | | Propane | 78% | 12 |
| 24UHPQA | A30AQ-A | Electric | 100% | 13 |
| | | Natural Gas | 78% | 14 |
| | | Oil | 78% | 15 |
| | | Propane | 78% | 16 |
| 24UHPQB | A36AQ-A | Electric | 100% | 17 |
| | | Natural Gas | 78% | 18 |
| | | Oil | 78% | 19 |
| | | Propane | 78% | 20 |
| 30UHPQB | A36AQ-A | Electric | 100% | 21 |
| | | Natural Gas | 78% | 22 |
| | | Oil | 78% | 23 |
| | | Propane | 78% | 24 |
| 30UHPQB | A37AQ-A | Electric | 100% | 25 |
| | | Natural Gas | 78% | 26 |
| | | Oil | 78% | 27 |
| | | Propane | 78% | 28 |
| 36UHPQB | A36AQ-A | Electric | 100% | 29 |
| | | Natural Gas | 78% | 30 |
| | | Oil | 78% | 31 |
| | | Propane | 78% | 32 |
| 36UHPQB | A37AQ-A | Electric | 100% | 33 |
| | | Natural Gas | 78% | 34 |
| | | Oil | 78% | 35 |
| | | Propane | 78% | 36 |

TABLE OF CONTENTS

| Heat Pump Outdoor Model | Heat Pump Indoor Model | Furnace Fuel | Furnace AFUE Efficiency Rating | Page |
|----------------------------|---------------------------|--------------|-----------------------------------|------|
| 42UHPQA | A61AQ-A | Electric | 100% | 37 |
| | | Natural Gas | 78% | 38 |
| | | Oil | 78% | 39 |
| | | Propane | 78% | 40 |
| 48UHPQB | A61AQ-A | Electric | 100% | 41 |
| | | Natural Gas | 78% | 42 |
| | | Oil | 78% | 43 |
| | | Propane | 78% | 44 |
| 60UHPQB | A61AQ-A | Electric | 100% | 45 |
| | | Natural Gas | 78% | 46 |
| | | Oil | 78% | 47 |
| | | Propane | 78% | 48 |

GENERAL DESCRIPTION

WHAT DOES THIS GUIDE SHOW?

This operational cost savings guide has been prepared to show theoretical cost savings for Bard dual fuel "add-on" heat pumps when used with either existing or new furnaces. It covers add-on applications for electric, oil, propane gas and natural gas type forced air furnaces. It includes both air source heat pumps and ground water source heat pumps at many combinations of gas, oil and electrical rates. It enables the user not only to make a theoretical operating cost comparison at today's fuel costs but also at future estimated higher energy costs.

It is important to understand that this is a theoretical comparison between fuels. Actual operation costs can vary depending on many difficult to predict variables such as the actual design heating or cooling load, air infiltration, and wind effects, solar effect, efficiency of existing furnace, severity of weather for a given heating or cooling season and also individual usage pattern.

SPECIAL FEATURE--FUEL SAVER MODULE

These estimates utilize the Bard Fuel Saver Module which permit the heat pump to operate below the balance point to maximize the energy savings. For each application an analysis should be made to determine the economic balance point which is the outdoor temperature at which it becomes more cost effective to shut the heat pump down with an outdoor thermostat. This temperature varies with each combination of fuel cost and furnace and heat pump efficiency level. Refer to tables included in the instructions with the Fuel Saver Module.

FURNACE EFFICIENCY

For purposes of these cost estimates, furnace efficiency levels of 100% AFUE for electric, 78% AFUE for natural and propane gas and 78% AFUE for oil was chosen. We recognize that any variation in efficiency from these values will change the operating cost somewhat. These values were chosen to best represent typical efficiency levels of most equipment in the field today.

HOW TO USE DUAL FUEL ADD-ON HEAT PUMP GUIDE TO ENERGY COST SAVINGS

1. Determine the heating Btuh loss and cooling Btuh gain for structure using a Bard "Whole-House Heat Loss and Gain Work Sheet," Form 0008, ACCA "Load Calculation," Manual J.
 - a. Heating house Btuh loss is _____ .
 - b. Cooling house Btuh gain is _____ .

2. Determine the type of fuel available at structure (what type of {fuel} heating system is already there).

| | |
|----------------|-----------------------------------|
| a. Electricity | D. Fuel Oil |
| b. Natural Gas | E. Good water supply and disposal |
| c. Propane Gas | |

3. Call local utilities and determine area energy costs.

| | |
|----------------------|------------------|
| a. Electricity _____ | \$/Kilowatt-hour |
| b. Natural Gas _____ | \$/Therm |
| c. Propane Gas _____ | \$/Gallon |
| d. Fuel Oil _____ | \$/Gallon |

4. Tentatively select an add-on heat pump system using Bard Manual 2100-057, "Heat Pump Sizing" as a guide, and a Bard equipment catalog.
 - a. Air to air heat pump

| | | |
|-------------|-------------------|------------|
| Model _____ | Indoor Coil _____ | |
| Btuh _____ | Heat Btuh _____ | Cool _____ |

 - b. Water to air

| | | |
|-------------|-------------------|------------|
| Model _____ | Indoor Coil _____ | |
| Btuh _____ | Heat Btuh _____ | Cool _____ |

5. Determine heating region where the structure is located. To do this, find the geographic location of house on regional heating load hours map. A map is located inside the front cover of this guide.
 - A. Region structure is located _____ .

YOU ARE NOW READY TO USE THE "DUAL FUEL ADD-ON HEAT PUMP GUIDE"

6. Select the "Dual Fuel Add-On Heat Pump Guide" for the region the structure is located. (See step 5 above.)

10. The balance point (the outdoor temperature at which the heat pump is running 100% of the time and just meeting structure heat loss requirements) is located on right side of page.

EXAMPLE: For a structure with a 70,000 Btuh with a 36UHPQA heat pump has a balance point of 36°F. Below this theoretical balance point, the heating load is automatically transferred between the heat pump and the furnace by the wall thermostat to maintain the desired temperature. This is accomplished with the Fuel Saver Module.

| 70,000 | \$ | 784 | 891 | 1004 | 1117 | 1230 | 1342 | 1455 | 1568 | 1675 | 1788 | 1901 | 2014 | ←--THEORETICAL HEATING COST * FURNACE ONLY |
|--------|----|------|------|------|------|------|------|------|------|------|------|------|------|--|
| .05 | \$ | 767 | 835 | 902 | 970 | 1032 | 1100 | 1168 | 1235 | 1303 | 1371 | 1438 | 1500 | THEORETICAL HEATING COST * FURN. + HEAT PUMP |
| .06 | \$ | 823 | 891 | 959 | 1026 | 1089 | 1156 | 1224 | 1292 | 1359 | 1427 | 1495 | 1557 | \$ PER YEAR |
| .07 | \$ | 880 | 948 | 1016 | 1083 | 1150 | 1218 | 1286 | 1354 | 1422 | 1489 | 1557 | 1619 | |
| .08 | \$ | 942 | 1010 | 1077 | 1145 | 1207 | 1275 | 1342 | 1410 | 1478 | 1546 | 1613 | 1675 | |
| .09 | \$ | 1004 | 1072 | 1139 | 1207 | 1269 | 1337 | 1405 | 1472 | 1540 | 1608 | 1675 | 1731 | |
| .10 | \$ | 1060 | 1128 | 1196 | 1263 | 1326 | 1393 | 1460 | 1528 | 1596 | 1664 | 1731 | 1784 | |
| .11 | \$ | 1119 | 1187 | 1254 | 1321 | 1384 | 1451 | 1518 | 1585 | 1652 | 1719 | 1786 | 1842 | |
| .12 | \$ | 1179 | 1247 | 1314 | 1381 | 1444 | 1512 | 1579 | 1647 | 1715 | 1783 | 1850 | 1912 | |
| .13 | \$ | 1239 | 1307 | 1374 | 1441 | 1504 | 1572 | 1640 | 1708 | 1776 | 1844 | 1911 | 1973 | |
| .14 | \$ | 1299 | 1367 | 1434 | 1501 | 1564 | 1632 | 1700 | 1768 | 1836 | 1904 | 1971 | 2033 | |
| .16 | \$ | 1416 | 1484 | 1551 | 1619 | 1681 | 1749 | 1816 | 1884 | 1952 | 2020 | 2087 | 2149 | |

BALANCE POINT 36 DEG. F. -10

11. To find annual cooling cost of heat pump, look at the bottom of page under annual air conditioning cost. Directly under the electric rate \$/KW (step 3) line, is located the annual cooling cost.

EXAMPLE: At .06 \$/KW rate for electricity, the cooling cost would be \$182.00 annually.

ANNUAL AIR CONDITIONING COST WHEN COOLING LOAD IS SIZED TO MATCH COOLING CAPACITY OF HEAT PUMP

| \$ | .05 | .06 | .07 | .08 | .09 | .10 | .12 | .14 | .16 | ←--ELECTRIC RATE \$/KWH |
|----|-----|-----|-----|-----|-----|-----|-----|-----|-----|--------------------------------------|
| \$ | 151 | 182 | 212 | 243 | 273 | 303 | 364 | 425 | 486 | ←--THEORETICAL AIR CONDITIONING COST |

THE ABOVE ANNUAL HEATING AND COOLING OPERATING COSTS ARE THEORETICAL ESTIMATES ONLY AND ARE PROVIDED FOR A COMMON BASIS OF COMPARISON BETWEEN VARIOUS TYPES OF HEATING AND COOLING SYSTEMS. ACTUAL VALUES MAY VARY DEPENDING ON ACTUAL WEATHER CONDITIONS AND INDIVIDUAL USAGE PATTERN.

NOTE: The accuracy of the "Dual Fuel-Add-On Heat Pump Guide to Energy Cost Savings," is directly affected by how accurately you estimate the structure's heat loss and heat gain in step 1. Because of uncontrollable variables, Bard Manufacturing Company is not responsible for any variation in actual operating costs from these theoretical estimates.

FIGURE 1

| HEAT PUMP CAPACITY BTU/HR | HEATING OIL COST \$/GAL | HEATING OIL COST - \$/GALLON | | | | | | | | | | | ELECTRIC RATE \$/KWH | THEORETICAL AIR CONDITIONING COST | | | |
|---------------------------------|-------------------------------|------------------------------|------|------|------|------|------|------|------|------|------|------|-------------------------|-----------------------------------|--|-------------------------|--|
| | | .70 | .80 | .90 | 1.00 | 1.10 | 1.20 | 1.30 | 1.40 | 1.50 | 1.60 | 1.70 | | | 1.80 | | |
| 35,000 | .16 | \$ | 389 | 445 | 502 | 558 | 615 | 671 | 727 | 784 | 835 | 891 | 947 | 1004 | ←--THEORETICAL HEATING COST * FURNACE ONLY | | |
| | | \$ | 406 | 417 | 428 | 434 | 445 | 457 | 468 | 479 | 490 | 502 | 507 | 519 | THEORETICAL HEATING COST * FURN. + HEAT PUMP | | |
| | | \$ | 423 | 434 | 445 | 457 | 468 | 479 | 490 | 502 | 519 | 530 | 541 | 552 | 563 | \$ PER YEAR | |
| | | \$ | 440 | 451 | 462 | 473 | 484 | 495 | 506 | 517 | 528 | 539 | 550 | 561 | 572 | | |
| | | \$ | 457 | 468 | 479 | 490 | 501 | 512 | 523 | 534 | 545 | 556 | 567 | 578 | 589 | | |
| | | \$ | 474 | 485 | 496 | 507 | 518 | 529 | 540 | 551 | 562 | 573 | 584 | 595 | 606 | | |
| | | \$ | 491 | 502 | 513 | 524 | 535 | 546 | 557 | 568 | 579 | 590 | 601 | 612 | 623 | | |
| | | \$ | 508 | 519 | 530 | 541 | 552 | 563 | 574 | 585 | 596 | 607 | 618 | 629 | 640 | | |
| | | \$ | 525 | 536 | 547 | 558 | 569 | 580 | 591 | 602 | 613 | 624 | 635 | 646 | 657 | | |
| | | \$ | 542 | 553 | 564 | 575 | 586 | 597 | 608 | 619 | 630 | 641 | 652 | 663 | 674 | BALANCE POINT 19 DEG.F. | |
| 40,000 | .16 | \$ | 445 | 507 | 575 | 637 | 699 | 767 | 829 | 891 | 959 | 1021 | 1083 | 1151 | ←--THEORETICAL HEATING COST * FURNACE ONLY | | |
| | | \$ | 457 | 473 | 490 | 507 | 530 | 547 | 564 | 581 | 598 | 620 | 637 | 654 | THEORETICAL HEATING COST * FURN. + HEAT PUMP | | |
| | | \$ | 474 | 485 | 496 | 507 | 518 | 529 | 540 | 551 | 562 | 573 | 584 | 595 | 606 | \$ PER YEAR | |
| | | \$ | 491 | 502 | 513 | 524 | 535 | 546 | 557 | 568 | 579 | 590 | 601 | 612 | 623 | | |
| | | \$ | 508 | 519 | 530 | 541 | 552 | 563 | 574 | 585 | 596 | 607 | 618 | 629 | 640 | | |
| | | \$ | 525 | 536 | 547 | 558 | 569 | 580 | 591 | 602 | 613 | 624 | 635 | 646 | 657 | | |
| | | \$ | 542 | 553 | 564 | 575 | 586 | 597 | 608 | 619 | 630 | 641 | 652 | 663 | 674 | | |
| | | \$ | 559 | 570 | 581 | 592 | 603 | 614 | 625 | 636 | 647 | 658 | 669 | 680 | 691 | | |
| | | \$ | 576 | 587 | 598 | 609 | 620 | 631 | 642 | 653 | 664 | 675 | 686 | 697 | 708 | | |
| | | \$ | 593 | 604 | 615 | 626 | 637 | 648 | 659 | 670 | 681 | 692 | 703 | 714 | 725 | BALANCE POINT 22 DEG.F. | |
| 50,000 | .16 | \$ | 558 | 637 | 716 | 795 | 880 | 959 | 1038 | 1117 | 1196 | 1280 | 1359 | 1438 | ←--THEORETICAL HEATING COST * FURNACE ONLY | | |
| | | \$ | 558 | 592 | 626 | 660 | 694 | 727 | 761 | 795 | 829 | 863 | 897 | 931 | THEORETICAL HEATING COST * FURN. + HEAT PUMP | | |
| | | \$ | 580 | 654 | 728 | 802 | 876 | 950 | 1024 | 1098 | 1172 | 1246 | 1320 | 1394 | \$ PER YEAR | | |
| | | \$ | 602 | 676 | 750 | 824 | 898 | 972 | 1046 | 1120 | 1194 | 1268 | 1342 | 1416 | | | |
| | | \$ | 624 | 698 | 772 | 846 | 920 | 994 | 1068 | 1142 | 1216 | 1290 | 1364 | 1438 | | | |
| | | \$ | 646 | 720 | 794 | 868 | 942 | 1016 | 1090 | 1164 | 1238 | 1312 | 1386 | 1460 | | | |
| | | \$ | 668 | 742 | 816 | 890 | 964 | 1038 | 1112 | 1186 | 1260 | 1334 | 1408 | 1482 | | | |
| | | \$ | 690 | 764 | 838 | 912 | 986 | 1060 | 1134 | 1208 | 1282 | 1356 | 1430 | 1504 | | | |
| | | \$ | 712 | 786 | 860 | 934 | 1008 | 1082 | 1156 | 1230 | 1304 | 1378 | 1452 | 1526 | | | |
| | | \$ | 734 | 808 | 882 | 956 | 1030 | 1104 | 1178 | 1252 | 1326 | 1400 | 1474 | 1548 | BALANCE POINT 28 DEG.F. | | |
| 60,000 | .16 | \$ | 671 | 767 | 863 | 959 | 1055 | 1151 | 1247 | 1342 | 1438 | 1534 | 1630 | 1726 | ←--THEORETICAL HEATING COST * FURNACE ONLY | | |
| | | \$ | 660 | 716 | 773 | 835 | 891 | 947 | 1004 | 1060 | 1117 | 1179 | 1235 | 1292 | THEORETICAL HEATING COST * FURN. + HEAT PUMP | | |
| | | \$ | 710 | 823 | 893 | 963 | 1033 | 1103 | 1173 | 1243 | 1313 | 1383 | 1453 | 1523 | \$ PER YEAR | | |
| | | \$ | 767 | 880 | 950 | 1020 | 1090 | 1160 | 1230 | 1300 | 1370 | 1440 | 1510 | 1580 | | | |
| | | \$ | 823 | 936 | 1006 | 1076 | 1146 | 1216 | 1286 | 1356 | 1426 | 1496 | 1566 | 1636 | | | |
| | | \$ | 880 | 993 | 1063 | 1133 | 1203 | 1273 | 1343 | 1413 | 1483 | 1553 | 1623 | 1693 | | | |
| | | \$ | 936 | 1049 | 1119 | 1189 | 1259 | 1329 | 1399 | 1469 | 1539 | 1609 | 1679 | 1749 | | | |
| | | \$ | 993 | 1106 | 1176 | 1246 | 1316 | 1386 | 1456 | 1526 | 1596 | 1666 | 1736 | 1806 | | | |
| | | \$ | 1049 | 1162 | 1232 | 1302 | 1372 | 1442 | 1512 | 1582 | 1652 | 1722 | 1792 | 1862 | | | |
| | | \$ | 1106 | 1219 | 1289 | 1359 | 1429 | 1499 | 1569 | 1639 | 1709 | 1779 | 1849 | 1919 | BALANCE POINT 33 DEG.F. | | |
| 70,000 | .16 | \$ | 784 | 891 | 1004 | 1117 | 1230 | 1342 | 1455 | 1568 | 1675 | 1788 | 1901 | 2014 | ←--THEORETICAL HEATING COST * FURNACE ONLY | | |
| | | \$ | 784 | 828 | 872 | 916 | 960 | 1004 | 1048 | 1092 | 1136 | 1180 | 1224 | 1268 | THEORETICAL HEATING COST * FURN. + HEAT PUMP | | |
| | | \$ | 828 | 916 | 1004 | 1092 | 1180 | 1268 | 1356 | 1444 | 1532 | 1620 | 1708 | 1796 | \$ PER YEAR | | |
| | | \$ | 872 | 960 | 1048 | 1136 | 1224 | 1312 | 1400 | 1488 | 1576 | 1664 | 1752 | 1840 | | | |
| | | \$ | 916 | 1004 | 1092 | 1180 | 1268 | 1356 | 1444 | 1532 | 1620 | 1708 | 1796 | 1884 | | | |
| | | \$ | 960 | 1048 | 1136 | 1224 | 1312 | 1400 | 1488 | 1576 | 1664 | 1752 | 1840 | 1928 | | | |
| | | \$ | 1004 | 1092 | 1180 | 1268 | 1356 | 1444 | 1532 | 1620 | 1708 | 1796 | 1884 | 1972 | | | |
| | | \$ | 1048 | 1136 | 1224 | 1312 | 1400 | 1488 | 1576 | 1664 | 1752 | 1840 | 1928 | 2016 | | | |
| | | \$ | 1092 | 1180 | 1268 | 1356 | 1444 | 1532 | 1620 | 1708 | 1796 | 1884 | 1972 | 2060 | | | |
| | | \$ | 1136 | 1224 | 1312 | 1400 | 1488 | 1576 | 1664 | 1752 | 1840 | 1928 | 2016 | 2104 | BALANCE POINT 36 DEG.F. | | |

ADDITIONAL AIR CONDITIONING COST WHEN COOLING LOAD IS SIZED TO MATCH COOLING CAPACITY OF HEAT PUMP

| ELECTRIC RATE (\$/KWH) | 05 | 06 | 07 | 08 | 09 | 10 | 12 | 14 | 16 |
|-----------------------------------|-----|-----|-----|-----|-----|-----|-----|-----|-----|
| THEORETICAL AIR CONDITIONING COST | 151 | 182 | 212 | 243 | 273 | 303 | 364 | 425 | 486 |

←--ELECTRIC RATE \$/KWH
←--THEORETICAL AIR CONDITIONING COST

THE ABOVE ANNUAL HEATING AND COOLING OPERATING COSTS ARE THEORETICAL ESTIMATES ONLY AND ARE PROVIDED FOR A COMMON BASIS OF COMPARISON BETWEEN VARIOUS TYPES OF HEATING AND COOLING SYSTEMS. ACTUAL VALUES MAY VARY DEPENDING ON ACTUAL WEATHER CONDITIONS AND INDIVIDUAL USAGE PATTERN.

BARD MANUFACTURING COMPANY
 DUAL FUEL ADD-ON HEAT PUMP GUIDE TO ENERGY COST SAVINGS

REGION 4
 HEAT PUMP MODEL: COMPRESSOR SECTION: NOS30A INDOOR: A3640-A
 COOLING CAPACITY AT 55 DEG.F. ENTERING WATER TEMP.: 30770 BTUH, 16.34 SEER
 HEATING CAPACITY AT 55 DEG.F. ENTERING WATER TEMP.: 27770 BTUH, 3.62 COP
 FURNACE TYPE: ELECTRIC FURNACE EFFICIENCY: 100.00% AFUE

| HEAT LOAD BTUH | ELEC. COST \$/KWH | HEAT PUMP WITH ELECTRIC HEAT | ELECTRIC HEAT ONLY | |
|---|-------------------|------------------------------|--------------------|-------------------------|
| 30,000 | | | | |
| --- THEORETICAL ANNUAL HEATING COST --- | | | | |
| | | HEAT PUMP WITH ELECTRIC HEAT | ELECTRIC HEAT ONLY | |
| .05 | | 253 | 754 | |
| .06 | | 279 | 908 | |
| .07 | | 319 | 1060 | |
| .08 | | 349 | 1215 | |
| .09 | | 400 | 1412 | |
| .10 | | 453 | 1365 | |
| .12 | | 486 | 1517 | |
| .14 | | 603 | 1842 | |
| .16 | | 705 | 2127 | BALANCE POINT 7- DEG.F. |
| | | 801 | 2431 | |
| 35,000 | | | | |
| --- THEORETICAL ANNUAL HEATING COST --- | | | | |
| | | HEAT PUMP WITH ELECTRIC HEAT | ELECTRIC HEAT ONLY | |
| .05 | | 287 | 885 | |
| .06 | | 344 | 1060 | |
| .07 | | 400 | 1241 | |
| .08 | | 457 | 1416 | |
| .09 | | 519 | 1596 | |
| .10 | | 575 | 1771 | |
| .12 | | 688 | 2111 | |
| .14 | | 806 | 2484 | BALANCE POINT 3 DEG.F. |
| .16 | | 919 | 2838 | |
| 40,000 | | | | |
| --- THEORETICAL ANNUAL HEATING COST --- | | | | |
| | | HEAT PUMP WITH ELECTRIC HEAT | ELECTRIC HEAT ONLY | |
| .05 | | 321 | 1010 | |
| .06 | | 389 | 1213 | |
| .07 | | 451 | 1417 | |
| .08 | | 519 | 1619 | |
| .09 | | 581 | 1822 | |
| .10 | | 648 | 2025 | |
| .12 | | 778 | 2431 | |
| .14 | | 914 | 2838 | BALANCE POINT 11 DEG.F. |
| .16 | | 1038 | 3244 | |
| 50,000 | | | | |
| --- THEORETICAL ANNUAL HEATING COST --- | | | | |
| | | HEAT PUMP WITH ELECTRIC HEAT | ELECTRIC HEAT ONLY | |
| .05 | | 417 | 1263 | |
| .06 | | 504 | 1517 | |
| .07 | | 586 | 1771 | |
| .08 | | 671 | 2025 | |
| .09 | | 758 | 2279 | |
| .10 | | 840 | 2533 | |
| .12 | | 1004 | 3041 | |
| .14 | | 1173 | 3549 | BALANCE POINT 22 DEG.F. |
| .16 | | 1337 | 4057 | |
| 60,000 | | | | |
| --- THEORETICAL ANNUAL HEATING COST --- | | | | |
| | | HEAT PUMP WITH ELECTRIC HEAT | ELECTRIC HEAT ONLY | |
| .05 | | 547 | 1517 | |
| .06 | | 654 | 1822 | |
| .07 | | 767 | 2127 | |
| .08 | | 874 | 2431 | |
| .09 | | 981 | 2736 | |
| .10 | | 1094 | 3041 | |
| .12 | | 1294 | 3650 | |
| .14 | | 1523 | 4260 | BALANCE POINT 29 DEG.F. |
| .16 | | 1743 | 4869 | |

ANNUAL AIR CONDITIONING COST WHEN COOLING LOAD IS SIZED TO MATCH COOLING CAPACITY OF HEAT PUMP

\$.05 .06 .07 .08 .09 .10 .12 .14 .16 <-- ELECTRIC RATE \$/KWH
 <-- THEORETICAL AIR CONDITIONING COST

THE ABOVE ANNUAL HEATING AND COOLING OPERATING COSTS ARE THEORETICAL ESTIMATES ONLY AND ARE PROVIDED FOR A COMMON BASIS OF COMPARISON BETWEEN VARIOUS TYPES OF HEATING AND COOLING SYSTEMS. ACTUAL VALUES MAY VARY DEPENDING ON ACTUAL WEATHER CONDITIONS AND INDIVIDUAL USAGE PATTERN.

BARD MANUFACTURING COMPANY

DUAL FUEL ADD-ON HEAT PUMP GUIDE TO ENERGY COST SAVINGS

REGION 4
 HEAT PUMP MODEL: COMPRESSOR SECTION: MODEL: INDOOR: A3640-A
 COOLING CAPACITY AT 53 DEG. F. ENTERING WATER TEMP.: 30770 BTUH 16.34 SEER
 HEATING CAPACITY AT 53 DEG. F. ENTERING WATER TEMP.: 47710 BTUH 3.82 COP
 FURNACE TYPE: NATURAL GAS FURNACE EFFICIENCY: 78.00% AFUE

| HEAT LOSS BTUH | HEAT COST \$/KWH | NATURAL GAS COST - \$/THERM | | | | | | | | | | | | |
|----------------|------------------|-----------------------------|------|------|------|------|------|------|------|------|------|------|------|---|
| | | .35 | .40 | .45 | .50 | .55 | .60 | .65 | .70 | .75 | .80 | .90 | 1.00 | |
| 30,000 | \$ | 231 | 265 | 299 | 332 | 361 | 394 | 428 | 462 | 496 | 530 | 598 | 665 | <--THEORETICAL HEATING COST * FURNACE ONLY |
| .05 | \$ | 248 | 248 | 248 | 248 | 248 | 248 | 248 | 248 | 248 | 248 | 248 | 253 | THEORETICAL HEATING COST * FURN.+ HEAT PUMP \$ PER YEAR |
| .06 | \$ | 243 | 243 | 243 | 243 | 243 | 243 | 243 | 243 | 243 | 243 | 243 | 249 | |
| .07 | \$ | 244 | 244 | 244 | 244 | 244 | 244 | 244 | 244 | 244 | 244 | 244 | 249 | |
| .08 | \$ | 289 | 289 | 289 | 289 | 289 | 289 | 289 | 289 | 289 | 289 | 289 | 294 | |
| .09 | \$ | 240 | 240 | 240 | 240 | 240 | 240 | 240 | 240 | 240 | 240 | 240 | 245 | |
| .10 | \$ | 285 | 285 | 285 | 285 | 285 | 285 | 285 | 285 | 285 | 285 | 285 | 290 | |
| .12 | \$ | 581 | 581 | 581 | 581 | 581 | 581 | 581 | 581 | 581 | 581 | 581 | 586 | |
| .14 | \$ | 677 | 677 | 677 | 677 | 677 | 677 | 677 | 677 | 677 | 677 | 677 | 682 | |
| .16 | \$ | 778 | 778 | 778 | 778 | 778 | 778 | 778 | 778 | 778 | 778 | 778 | 784 | BALANCE POINT 7- DEG.F. |
| 35,000 | \$ | 270 | 310 | 344 | 383 | 423 | 462 | 502 | 541 | 581 | 620 | 694 | 773 | <--THEORETICAL HEATING COST * FURNACE ONLY |
| .05 | \$ | 276 | 276 | 282 | 282 | 282 | 282 | 282 | 282 | 287 | 287 | 287 | 287 | THEORETICAL HEATING COST * FURN.+ HEAT PUMP \$ PER YEAR |
| .06 | \$ | 332 | 332 | 338 | 338 | 338 | 338 | 338 | 338 | 344 | 344 | 344 | 344 | |
| .07 | \$ | 389 | 389 | 394 | 394 | 394 | 394 | 394 | 394 | 400 | 400 | 400 | 400 | |
| .08 | \$ | 440 | 440 | 445 | 445 | 445 | 445 | 445 | 445 | 451 | 451 | 451 | 451 | |
| .09 | \$ | 496 | 496 | 502 | 502 | 502 | 502 | 502 | 502 | 507 | 507 | 507 | 507 | |
| .10 | \$ | 552 | 552 | 558 | 558 | 558 | 558 | 558 | 558 | 564 | 564 | 564 | 564 | |
| .12 | \$ | 660 | 660 | 665 | 665 | 665 | 665 | 665 | 665 | 671 | 671 | 671 | 671 | |
| .14 | \$ | 767 | 767 | 773 | 773 | 773 | 773 | 773 | 773 | 778 | 778 | 778 | 778 | |
| .16 | \$ | 874 | 874 | 880 | 880 | 880 | 880 | 880 | 880 | 885 | 885 | 885 | 885 | BALANCE POINT 3 DEG.F. |
| 40,000 | \$ | 310 | 349 | 394 | 440 | 485 | 530 | 575 | 620 | 665 | 705 | 795 | 885 | <--THEORETICAL HEATING COST * FURNACE ONLY |
| .05 | \$ | 315 | 321 | 321 | 327 | 327 | 332 | 332 | 338 | 338 | 338 | 344 | 349 | THEORETICAL HEATING COST * FURN.+ HEAT PUMP \$ PER YEAR |
| .06 | \$ | 372 | 378 | 378 | 383 | 383 | 389 | 389 | 394 | 394 | 394 | 400 | 406 | |
| .07 | \$ | 434 | 440 | 440 | 445 | 445 | 451 | 451 | 457 | 457 | 457 | 462 | 468 | |
| .08 | \$ | 490 | 496 | 496 | 502 | 502 | 507 | 507 | 513 | 513 | 513 | 519 | 524 | |
| .09 | \$ | 552 | 558 | 558 | 564 | 564 | 569 | 569 | 575 | 575 | 575 | 581 | 586 | |
| .10 | \$ | 609 | 615 | 615 | 620 | 620 | 626 | 626 | 631 | 631 | 631 | 637 | 643 | |
| .12 | \$ | 727 | 733 | 733 | 739 | 739 | 744 | 744 | 750 | 750 | 750 | 756 | 761 | |
| .14 | \$ | 846 | 852 | 852 | 857 | 857 | 863 | 863 | 868 | 868 | 868 | 874 | 880 | |
| .16 | \$ | 964 | 970 | 970 | 976 | 976 | 981 | 981 | 987 | 987 | 987 | 993 | 998 | BALANCE POINT 11 DEG.F. |
| 50,000 | \$ | 383 | 440 | 496 | 552 | 609 | 665 | 716 | 773 | 829 | 885 | 998 | 1105 | <--THEORETICAL HEATING COST * FURNACE ONLY |
| .05 | \$ | 389 | 400 | 417 | 434 | 451 | 468 | 479 | 496 | 513 | 530 | 558 | 592 | THEORETICAL HEATING COST * FURN.+ HEAT PUMP \$ PER YEAR |
| .06 | \$ | 445 | 457 | 473 | 490 | 507 | 524 | 536 | 552 | 569 | 586 | 615 | 648 | |
| .07 | \$ | 502 | 513 | 530 | 547 | 564 | 581 | 592 | 609 | 626 | 643 | 671 | 705 | |
| .08 | \$ | 558 | 569 | 586 | 603 | 620 | 637 | 648 | 665 | 682 | 699 | 727 | 761 | |
| .09 | \$ | 615 | 626 | 643 | 660 | 677 | 694 | 705 | 722 | 739 | 756 | 784 | 818 | |
| .10 | \$ | 671 | 682 | 699 | 716 | 733 | 750 | 761 | 778 | 795 | 812 | 840 | 874 | |
| .12 | \$ | 778 | 789 | 806 | 823 | 840 | 857 | 868 | 885 | 902 | 919 | 947 | 981 | |
| .14 | \$ | 891 | 902 | 919 | 936 | 953 | 970 | 981 | 998 | 1015 | 1032 | 1060 | 1094 | |
| .16 | \$ | 1004 | 1015 | 1032 | 1049 | 1066 | 1083 | 1094 | 1111 | 1128 | 1145 | 1173 | 1207 | BALANCE POINT 22 DEG.F. |
| 60,000 | \$ | 462 | 530 | 598 | 665 | 727 | 795 | 863 | 931 | 998 | 1060 | 1196 | 1331 | <--THEORETICAL HEATING COST * FURNACE ONLY |
| .05 | \$ | 462 | 490 | 519 | 547 | 575 | 603 | 631 | 660 | 688 | 716 | 773 | 829 | THEORETICAL HEATING COST * FURN.+ HEAT PUMP \$ PER YEAR |
| .06 | \$ | 519 | 547 | 575 | 603 | 631 | 660 | 688 | 716 | 744 | 773 | 829 | 885 | |
| .07 | \$ | 575 | 598 | 626 | 654 | 682 | 710 | 739 | 767 | 795 | 823 | 880 | 936 | |
| .08 | \$ | 630 | 648 | 677 | 705 | 733 | 761 | 789 | 818 | 846 | 874 | 931 | 987 | |
| .09 | \$ | 677 | 705 | 733 | 761 | 789 | 818 | 846 | 874 | 902 | 931 | 987 | 1043 | |
| .10 | \$ | 727 | 754 | 782 | 810 | 838 | 866 | 894 | 922 | 950 | 981 | 1038 | 1094 | |
| .12 | \$ | 835 | 863 | 891 | 919 | 947 | 976 | 1004 | 1032 | 1060 | 1089 | 1145 | 1201 | |
| .14 | \$ | 942 | 970 | 998 | 1026 | 1055 | 1083 | 1111 | 1139 | 1168 | 1196 | 1252 | 1309 | |
| .16 | \$ | 1049 | 1077 | 1105 | 1134 | 1162 | 1190 | 1218 | 1247 | 1275 | 1303 | 1359 | 1416 | BALANCE POINT 29 DEG.F. |

ANNUAL AIR CONDITIONING COST WHEN COOLING LOAD IS SIZED TO MATCH COOLING CAPACITY OF HEAT PUMP

| | | | | | | | | | | |
|----|-----|-----|-----|-----|-----|-----|-----|-----|-----|--------------------------------------|
| \$ | .05 | .06 | .07 | .08 | .09 | .10 | .12 | .14 | .16 | <--ELECTRIC RATE \$/KWH |
| \$ | 75 | 90 | 105 | 120 | 135 | 150 | 180 | 210 | 241 | <--THEORETICAL AIR CONDITIONING COST |

THE ABOVE ANNUAL HEATING AND COOLING OPERATING COSTS ARE THEORETICAL ESTIMATES ONLY AND ARE PROVIDED FOR A COMMON BASIS OF COMPARISON BETWEEN VARIOUS TYPES OF HEATING AND COOLING SYSTEMS. ACTUAL VALUES MAY VARY DEPENDING ON ACTUAL WEATHER CONDITIONS AND INDIVIDUAL USAGE PATTERN.

BARD MANUFACTURING COMPANY
DUAL FUEL ADD-ON HEAT PUMP GUIDE TO ENERGY COST SAVINGS

REGION 4
 HEAT PUMP MODEL: COMPRESSOR SECTION: NCS30A INDOOR: AS6A0-A
 COOLING CAPACITY AT 53 DEG.F. ENTERING WATER TEMP.: 30/70 BTUH 16.34 BHP
 HEATING CAPACITY AT 53 DEG.F. ENTERING WATER TEMP.: 27/70 BTUH 3.52 COP
 FURNACE TYPE: FURN. OIL FURNACE EFFICIENCY: 78.00% A/FUE

| HEAT LOSS BTUH | ELEC. COST \$/KWH | HEATING OIL COST - \$/GALLON | | | | | | | | | | | | |
|----------------|-------------------|------------------------------|------|------|------|------|------|------|------|------|------|------|------|--|
| | | .70 | .80 | .90 | 1.00 | 1.10 | 1.20 | 1.30 | 1.40 | 1.50 | 1.60 | 1.70 | 1.80 | |
| 30,000 | \$ | 332 | 383 | 428 | 479 | 524 | 575 | 620 | 671 | 716 | 767 | 812 | 863 | <--THEORETICAL HEATING COST * FURNACE ONLY |
| | .05 | 248 | 248 | 248 | 248 | 248 | 248 | 253 | 253 | 253 | 253 | 253 | 253 | THEORETICAL HEATING COST * FURN. + HEAT PUMP \$ PER YEAR |
| | .06 | 344 | 344 | 344 | 344 | 344 | 344 | 349 | 349 | 349 | 349 | 349 | 349 | |
| | .07 | 389 | 389 | 389 | 389 | 389 | 389 | 394 | 394 | 394 | 394 | 394 | 394 | |
| | .08 | 440 | 440 | 440 | 440 | 440 | 440 | 445 | 445 | 445 | 445 | 445 | 445 | |
| | .09 | 485 | 485 | 485 | 485 | 485 | 485 | 490 | 490 | 490 | 490 | 490 | 490 | |
| | .10 | 531 | 531 | 531 | 531 | 531 | 531 | 536 | 536 | 536 | 536 | 536 | 536 | |
| | .12 | 581 | 581 | 581 | 581 | 581 | 581 | 586 | 586 | 586 | 586 | 586 | 586 | |
| | .14 | 677 | 677 | 677 | 677 | 677 | 677 | 682 | 682 | 682 | 682 | 682 | 682 | |
| | .16 | 778 | 778 | 778 | 778 | 778 | 778 | 784 | 784 | 784 | 784 | 784 | 784 | |
| | | | | | | | | | | | | | | |
| 35,000 | \$ | 389 | 445 | 502 | 558 | 615 | 671 | 727 | 784 | 835 | 891 | 947 | 1004 | <--THEORETICAL HEATING COST * FURNACE ONLY |
| | .05 | 282 | 282 | 282 | 282 | 287 | 287 | 287 | 287 | 293 | 293 | 293 | 293 | THEORETICAL HEATING COST * FURN. + HEAT PUMP \$ PER YEAR |
| | .06 | 338 | 338 | 338 | 338 | 344 | 344 | 344 | 344 | 349 | 349 | 349 | 349 | |
| | .07 | 394 | 394 | 394 | 394 | 400 | 400 | 400 | 400 | 406 | 406 | 406 | 406 | |
| | .08 | 445 | 445 | 445 | 445 | 451 | 451 | 451 | 451 | 457 | 457 | 457 | 457 | |
| | .09 | 502 | 502 | 502 | 502 | 507 | 507 | 507 | 507 | 513 | 513 | 513 | 513 | |
| | .10 | 558 | 558 | 558 | 558 | 564 | 564 | 564 | 564 | 569 | 569 | 569 | 569 | |
| | .12 | 615 | 615 | 615 | 615 | 621 | 621 | 621 | 621 | 627 | 627 | 627 | 627 | |
| | .14 | 677 | 677 | 677 | 677 | 683 | 683 | 683 | 683 | 689 | 689 | 689 | 689 | |
| | .16 | 880 | 880 | 880 | 880 | 885 | 885 | 885 | 885 | 891 | 891 | 891 | 891 | |
| | | | | | | | | | | | | | | |
| 40,000 | \$ | 445 | 507 | 575 | 637 | 699 | 767 | 829 | 891 | 959 | 1021 | 1083 | 1151 | <--THEORETICAL HEATING COST * FURNACE ONLY |
| | .05 | 321 | 321 | 332 | 332 | 338 | 344 | 344 | 349 | 355 | 355 | 361 | 361 | THEORETICAL HEATING COST * FURN. + HEAT PUMP \$ PER YEAR |
| | .06 | 378 | 383 | 389 | 389 | 394 | 400 | 400 | 406 | 411 | 411 | 417 | 417 | |
| | .07 | 440 | 445 | 451 | 451 | 457 | 462 | 462 | 468 | 473 | 473 | 479 | 479 | |
| | .08 | 496 | 502 | 507 | 507 | 513 | 519 | 519 | 524 | 530 | 530 | 536 | 536 | |
| | .09 | 558 | 564 | 569 | 569 | 575 | 581 | 581 | 586 | 592 | 592 | 598 | 598 | |
| | .10 | 615 | 620 | 626 | 626 | 631 | 637 | 637 | 643 | 648 | 648 | 654 | 654 | |
| | .12 | 677 | 683 | 689 | 689 | 695 | 701 | 701 | 707 | 712 | 712 | 718 | 718 | |
| | .14 | 857 | 863 | 869 | 869 | 874 | 880 | 880 | 886 | 891 | 891 | 897 | 897 | |
| | .16 | 970 | 976 | 981 | 981 | 987 | 993 | 993 | 998 | 1004 | 1004 | 1010 | 1010 | |
| | | | | | | | | | | | | | | |
| 50,000 | \$ | 558 | 637 | 716 | 795 | 880 | 959 | 1038 | 1117 | 1196 | 1280 | 1359 | 1438 | <--THEORETICAL HEATING COST * FURNACE ONLY |
| | .05 | 434 | 457 | 479 | 501 | 524 | 547 | 575 | 598 | 620 | 643 | 665 | 688 | THEORETICAL HEATING COST * FURN. + HEAT PUMP \$ PER YEAR |
| | .06 | 490 | 513 | 536 | 558 | 581 | 603 | 631 | 654 | 677 | 699 | 722 | 744 | |
| | .07 | 547 | 569 | 592 | 615 | 637 | 660 | 688 | 710 | 733 | 756 | 778 | 801 | |
| | .08 | 603 | 626 | 648 | 671 | 694 | 716 | 744 | 767 | 789 | 812 | 835 | 857 | |
| | .09 | 660 | 683 | 705 | 727 | 750 | 773 | 801 | 823 | 846 | 868 | 891 | 914 | |
| | .10 | 716 | 739 | 761 | 784 | 806 | 829 | 857 | 880 | 902 | 925 | 947 | 970 | |
| | .12 | 831 | 846 | 868 | 891 | 914 | 936 | 964 | 987 | 1010 | 1032 | 1055 | 1077 | |
| | .14 | 936 | 959 | 981 | 1004 | 1026 | 1049 | 1077 | 1100 | 1122 | 1145 | 1168 | 1190 | |
| | .16 | 1049 | 1072 | 1094 | 1117 | 1139 | 1162 | 1190 | 1213 | 1235 | 1258 | 1280 | 1303 | |
| | | | | | | | | | | | | | | |
| 60,000 | \$ | 671 | 767 | 863 | 959 | 1055 | 1151 | 1247 | 1342 | 1438 | 1534 | 1630 | 1726 | <--THEORETICAL HEATING COST * FURNACE ONLY |
| | .05 | 547 | 591 | 631 | 671 | 710 | 750 | 795 | 835 | 874 | 914 | 953 | 998 | THEORETICAL HEATING COST * FURN. + HEAT PUMP \$ PER YEAR |
| | .06 | 603 | 648 | 688 | 727 | 767 | 806 | 852 | 891 | 931 | 970 | 1010 | 1055 | |
| | .07 | 659 | 699 | 739 | 778 | 818 | 857 | 902 | 942 | 981 | 1021 | 1060 | 1105 | |
| | .08 | 706 | 750 | 789 | 829 | 868 | 908 | 953 | 993 | 1032 | 1072 | 1111 | 1156 | |
| | .09 | 761 | 806 | 846 | 885 | 925 | 964 | 1010 | 1049 | 1089 | 1128 | 1168 | 1213 | |
| | .10 | 817 | 857 | 897 | 936 | 976 | 1015 | 1060 | 1100 | 1139 | 1179 | 1218 | 1263 | |
| | .12 | 918 | 964 | 1004 | 1043 | 1083 | 1122 | 1168 | 1207 | 1247 | 1286 | 1326 | 1371 | |
| | .14 | 1026 | 1072 | 1111 | 1151 | 1190 | 1230 | 1275 | 1314 | 1354 | 1393 | 1433 | 1478 | |
| | .16 | 1134 | 1179 | 1218 | 1258 | 1297 | 1337 | 1382 | 1421 | 1461 | 1500 | 1540 | 1585 | |
| | | | | | | | | | | | | | | |

ANNUAL AIR CONDITIONING COST WHEN COOLING LOAD IS SIZED TO MATCH COOLING CAPACITY OF HEAT PUMP

| | .05 | .06 | .07 | .08 | .09 | .10 | .12 | .14 | .16 | |
|----|-----|-----|-----|-----|-----|-----|-----|-----|-----|--------------------------------------|
| \$ | 75 | 90 | 105 | 120 | 135 | 150 | 180 | 210 | 241 | <--ELECTRIC RATE \$/KWH |
| | | | | | | | | | | <--THEORETICAL AIR CONDITIONING COST |

THE ABOVE ANNUAL HEATING AND COOLING OPERATING COSTS ARE THEORETICAL ESTIMATES ONLY AND ARE PROVIDED FOR A COMMON BASIS OF COMPARISON BETWEEN VARIOUS TYPES OF HEATING AND COOLING SYSTEMS. ACTUAL VALUES MAY VARY DEPENDING ON ACTUAL WEATHER CONDITIONS AND INDIVIDUAL USAGE PATTERN.

BARD MANUFACTURING COMPANY

DUAL FUEL ADD-ON HEAT PUMP GUIDE TO ENERGY COST SAVINGS

REGION 4
 HEAT PUMP MODEL: COMPRESSOR SECTION: H0630A INDOOR: A36AG-A
 COOLING CAPACITY AT 53 DEG. F. ENTERING WATER TEMP.: 30/70 BTU/LH. 16.34 SEER
 HEATING CAPACITY AT 53 DEG. F. ENTERING WATER TEMP.: 27/70 BTU/LH. 3.62 COP
 FURNACE TYPE: PROGRAM GAS FURNACE EFFICIENCY: 78.00% AFUE

| HEAT PUMP COST \$/KWH | PROPANE GAS COST - \$/GALLON | HEATING COST \$ PER YEAR | | | | | | | | | | | | |
|-----------------------|------------------------------|--------------------------|------|------|------|------|------|------|------|------|------|------|------|---|
| | | .60 | .65 | .70 | .75 | .80 | .85 | .90 | .95 | 1.00 | 1.10 | 1.20 | 1.20 | |
| 30,000 | \$ | 434 | 473 | 507 | 547 | 581 | 620 | 654 | 694 | 727 | 801 | 874 | 874 | <--THEORETICAL HEATING COST * FURNACE ONLY |
| .05 | \$ | 448 | 488 | 522 | 562 | 596 | 635 | 669 | 708 | 742 | 816 | 889 | 889 | THEORETICAL HEATING COST * FURN.+ HEAT PUMP \$ PER YEAR |
| .06 | \$ | 462 | 502 | 536 | 576 | 610 | 649 | 683 | 722 | 756 | 830 | 903 | 903 | |
| .08 | \$ | 486 | 526 | 560 | 600 | 634 | 673 | 707 | 746 | 780 | 854 | 927 | 927 | |
| .10 | \$ | 510 | 550 | 584 | 624 | 658 | 697 | 731 | 770 | 804 | 878 | 951 | 951 | |
| .12 | \$ | 534 | 574 | 608 | 648 | 682 | 721 | 755 | 794 | 828 | 902 | 975 | 975 | |
| .14 | \$ | 558 | 598 | 632 | 672 | 706 | 745 | 779 | 818 | 852 | 926 | 999 | 999 | |
| .16 | \$ | 582 | 622 | 656 | 696 | 730 | 769 | 803 | 842 | 876 | 950 | 1023 | 1023 | BALANCE POINT 7- DEG.F. |
| 35,000 | \$ | 507 | 552 | 592 | 637 | 682 | 722 | 767 | 806 | 852 | 936 | 1021 | 1021 | <--THEORETICAL HEATING COST * FURNACE ONLY |
| .05 | \$ | 521 | 561 | 595 | 635 | 669 | 708 | 742 | 781 | 815 | 889 | 962 | 962 | THEORETICAL HEATING COST * FURN.+ HEAT PUMP \$ PER YEAR |
| .06 | \$ | 535 | 575 | 609 | 649 | 683 | 722 | 756 | 795 | 829 | 903 | 976 | 976 | |
| .08 | \$ | 559 | 599 | 633 | 673 | 707 | 746 | 780 | 819 | 853 | 927 | 1000 | 1000 | |
| .10 | \$ | 583 | 623 | 657 | 697 | 731 | 770 | 804 | 843 | 877 | 951 | 1024 | 1024 | |
| .12 | \$ | 607 | 647 | 681 | 721 | 755 | 794 | 828 | 867 | 901 | 975 | 1048 | 1048 | |
| .14 | \$ | 631 | 671 | 705 | 745 | 779 | 818 | 852 | 891 | 925 | 999 | 1072 | 1072 | |
| .16 | \$ | 655 | 695 | 729 | 769 | 803 | 842 | 876 | 915 | 949 | 1023 | 1096 | 1096 | BALANCE POINT 3 DEG.F. |
| 40,000 | \$ | 581 | 631 | 682 | 727 | 778 | 829 | 874 | 925 | 976 | 1072 | 1168 | 1168 | <--THEORETICAL HEATING COST * FURNACE ONLY |
| .05 | \$ | 595 | 635 | 669 | 709 | 743 | 782 | 816 | 855 | 889 | 963 | 1036 | 1036 | THEORETICAL HEATING COST * FURN.+ HEAT PUMP \$ PER YEAR |
| .06 | \$ | 609 | 649 | 683 | 723 | 757 | 796 | 830 | 869 | 903 | 977 | 1050 | 1050 | |
| .08 | \$ | 633 | 673 | 707 | 747 | 781 | 820 | 854 | 893 | 927 | 1001 | 1074 | 1074 | |
| .10 | \$ | 657 | 697 | 731 | 771 | 805 | 844 | 878 | 917 | 951 | 1025 | 1098 | 1098 | |
| .12 | \$ | 681 | 721 | 755 | 795 | 829 | 868 | 902 | 941 | 975 | 1049 | 1122 | 1122 | |
| .14 | \$ | 705 | 745 | 779 | 819 | 853 | 892 | 926 | 965 | 999 | 1073 | 1146 | 1146 | |
| .16 | \$ | 729 | 769 | 803 | 843 | 877 | 916 | 950 | 989 | 1023 | 1097 | 1170 | 1170 | BALANCE POINT 11 DEG.F. |
| 50,000 | \$ | 727 | 789 | 852 | 914 | 976 | 1032 | 1094 | 1156 | 1218 | 1337 | 1461 | 1461 | <--THEORETICAL HEATING COST * FURNACE ONLY |
| .05 | \$ | 741 | 803 | 865 | 927 | 989 | 1045 | 1107 | 1169 | 1231 | 1350 | 1474 | 1474 | THEORETICAL HEATING COST * FURN.+ HEAT PUMP \$ PER YEAR |
| .06 | \$ | 755 | 817 | 879 | 941 | 1003 | 1059 | 1121 | 1183 | 1245 | 1364 | 1488 | 1488 | |
| .08 | \$ | 779 | 841 | 903 | 965 | 1027 | 1083 | 1145 | 1207 | 1269 | 1388 | 1512 | 1512 | |
| .10 | \$ | 803 | 865 | 927 | 989 | 1051 | 1107 | 1169 | 1231 | 1293 | 1412 | 1536 | 1536 | |
| .12 | \$ | 827 | 889 | 951 | 1013 | 1075 | 1131 | 1193 | 1255 | 1317 | 1436 | 1560 | 1560 | |
| .14 | \$ | 851 | 913 | 975 | 1037 | 1099 | 1155 | 1217 | 1279 | 1341 | 1460 | 1584 | 1584 | |
| .16 | \$ | 875 | 937 | 999 | 1061 | 1123 | 1179 | 1241 | 1303 | 1365 | 1484 | 1608 | 1608 | BALANCE POINT 22 DEG.F. |
| 60,000 | \$ | 874 | 947 | 1021 | 1094 | 1168 | 1241 | 1314 | 1388 | 1461 | 1608 | 1754 | 1754 | <--THEORETICAL HEATING COST * FURNACE ONLY |
| .05 | \$ | 888 | 961 | 1035 | 1108 | 1182 | 1255 | 1329 | 1402 | 1476 | 1623 | 1769 | 1769 | THEORETICAL HEATING COST * FURN.+ HEAT PUMP \$ PER YEAR |
| .06 | \$ | 902 | 975 | 1049 | 1122 | 1196 | 1269 | 1343 | 1416 | 1490 | 1637 | 1783 | 1783 | |
| .08 | \$ | 926 | 999 | 1073 | 1146 | 1220 | 1293 | 1367 | 1440 | 1514 | 1661 | 1807 | 1807 | |
| .10 | \$ | 950 | 1023 | 1097 | 1170 | 1244 | 1317 | 1391 | 1464 | 1538 | 1685 | 1831 | 1831 | |
| .12 | \$ | 974 | 1047 | 1121 | 1194 | 1268 | 1341 | 1415 | 1488 | 1562 | 1709 | 1855 | 1855 | |
| .14 | \$ | 998 | 1071 | 1145 | 1218 | 1292 | 1365 | 1439 | 1512 | 1586 | 1733 | 1879 | 1879 | |
| .16 | \$ | 1022 | 1095 | 1169 | 1242 | 1316 | 1389 | 1463 | 1536 | 1610 | 1757 | 1903 | 1903 | BALANCE POINT 29 DEG.F. |

ANNUAL AIR CONDITIONING COST WHEN COOLING LOAD IS SIZED TO MATCH COOLING CAPACITY OF HEAT PUMP

| \$ | .05 | .06 | .07 | .08 | .09 | .10 | .12 | .14 | .16 | <--ELECTRIC RATE \$/KWH |
|----|-----|-----|-----|-----|-----|-----|-----|-----|-----|--------------------------------------|
| | 75 | 90 | 105 | 120 | 135 | 150 | 180 | 210 | 241 | <--THEORETICAL AIR CONDITIONING COST |

THE ABOVE ANNUAL HEATING AND COOLING OPERATING COSTS ARE THEORETICAL ESTIMATES ONLY AND ARE PROVIDED FOR A COMMON BASIS OF COMPARISON BETWEEN VARIOUS TYPES OF HEATING AND COOLING SYSTEMS. ACTUAL VALUES MAY VARY DEPENDING ON ACTUAL WEATHER CONDITIONS AND INDIVIDUAL USAGE PATTERN.

BARD MANUFACTURING COMPANY
 DUAL FUEL ADD-ON HEAT PUMP GUIDE TO ENERGY COST SAVINGS

REGION 4
 HEAT PUMP MODEL: COMPRESSOR SECTION: INDOOR: A3610-A
 COOLING CAPACITY AT 53 DEG. F. ENTERING WATER TEMP.: 36680 BTUH, 15.74 TONS
 HEATING CAPACITY AT 53 DEG. F. ENTERING WATER TEMP.: 35250 BTUH, 3.69 COP
 FURNACE TYPE: ELECTRIC FURNACE EFFICIENCY: 100.00% AFUE

HEAT
 LOSS
 BTUH
 ELEC.
 COST
 \$/KWH

35,000

--- THEORETICAL ANNUAL HEATING COST ---
 HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

| | | |
|-----|-----|------|
| .05 | 287 | 885 |
| .06 | 344 | 1060 |
| .07 | 406 | 1241 |
| .08 | 462 | 1416 |
| .09 | 519 | 1596 |
| .10 | 581 | 1771 |
| .12 | 689 | 2127 |
| .14 | 806 | 2482 |
| .16 | 925 | 2838 |

BALANCE POINT 13- DEG.F.

40,000

--- THEORETICAL ANNUAL HEATING COST ---
 HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

| | | |
|-----|------|------|
| .05 | 377 | 1010 |
| .06 | 394 | 1213 |
| .07 | 457 | 1416 |
| .08 | 524 | 1618 |
| .09 | 586 | 1827 |
| .10 | 648 | 2025 |
| .12 | 778 | 2431 |
| .14 | 914 | 2836 |
| .16 | 1043 | 3244 |

BALANCE POINT 4- DEG.F.

50,000

--- THEORETICAL ANNUAL HEATING COST ---
 HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

| | | |
|-----|------|------|
| .05 | 400 | 1263 |
| .06 | 473 | 1517 |
| .07 | 553 | 1771 |
| .08 | 637 | 2025 |
| .09 | 724 | 2279 |
| .10 | 806 | 2533 |
| .12 | 959 | 3041 |
| .14 | 1117 | 3549 |
| .16 | 1280 | 4057 |

BALANCE POINT 10 DEG.F.

60,000

--- THEORETICAL ANNUAL HEATING COST ---
 HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

| | | |
|-----|------|------|
| .05 | 485 | 1517 |
| .06 | 581 | 1832 |
| .07 | 683 | 2127 |
| .08 | 778 | 2431 |
| .09 | 880 | 2736 |
| .10 | 976 | 3041 |
| .12 | 1168 | 3650 |
| .14 | 1365 | 4260 |
| .16 | 1557 | 4869 |

BALANCE POINT 19 DEG.F.

70,000

--- THEORETICAL ANNUAL HEATING COST ---
 HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

| | | |
|-----|------|------|
| .05 | 598 | 1771 |
| .06 | 709 | 2127 |
| .07 | 840 | 2482 |
| .08 | 928 | 2838 |
| .09 | 1077 | 3193 |
| .10 | 1196 | 3549 |
| .12 | 1433 | 4260 |
| .14 | 1675 | 4971 |
| .16 | 1912 | 5682 |

BALANCE POINT 25 DEG.F.

ANNUAL AIR CONDITIONING COST WHEN COOLING LOAD IS SIZED TO MATCH COOLING CAPACITY OF HEAT PUMP

| | | | | | | | | | | |
|----|-----|-----|-----|-----|-----|-----|-----|-----|-----|--|
| \$ | .05 | .06 | .07 | .08 | .09 | .10 | .12 | .14 | .16 | |
| | 83 | 111 | 136 | 169 | 167 | 188 | 223 | 261 | 298 | |

<--ELECTRIC RATE \$/KWH
 <--THEORETICAL AIR CONDITIONING COST

THE ABOVE ANNUAL HEATING AND COOLING OPERATING COSTS ARE THEORETICAL ESTIMATES ONLY AND ARE PROVIDED FOR A COMMON BASIS OF COMPARISON BETWEEN VARIOUS TYPES OF HEATING AND COOLING SYSTEMS. ACTUAL VALUES MAY VARY DEPENDING ON ACTUAL WEATHER CONDITIONS AND INDIVIDUAL USAGE PATTERN.

BAIRD MANUFACTURING COMPANY

DUAL FUEL ADD-ON HEAT PUMP GUIDE TO ENERGY COST SAVINGS

REGION 4
 HEAT PUMP MODEL: COMPRESSION SECTION: MOS36A INDOOR: A36AC-A
 COOLING CAPACITY AT 53 DEG. F. ENTERING WATER TEMP.: 36680 BTUH 12.74 SEER
 HEATING CAPACITY AT 53 DEG. F. ENTERING WATER TEMP.: 35260 BTUH 3.69 COP
 FURNACE TYPE: NATURAL GAS FURNACE EFFICIENCY: 78.00% AFUE

| HEAT LOSS BTUH | ELEC. COST \$/KWH | NATURAL GAS COST - \$/THERM | | | | | | | | | | | | |
|----------------|-------------------|-----------------------------|------|------|------|------|------|------|------|------|------|------|------|--|
| | | .35 | .40 | .45 | .50 | .55 | .60 | .65 | .70 | .75 | .80 | .90 | | 1.00 |
| 35,000 | | \$ 270 | 310 | 344 | 383 | 423 | 462 | 502 | 541 | 581 | 620 | 694 | 773 | <--THEORETICAL HEATING COST * FURNACE ONLY |
| | .05 | 282 | 282 | 282 | 282 | 282 | 282 | 282 | 282 | 282 | 282 | 282 | 282 | THEORETICAL HEATING COST * FURN. + HEAT PUMP \$ PER YEAR |
| | .06 | 304 | 304 | 304 | 304 | 304 | 304 | 304 | 304 | 304 | 304 | 304 | 304 | |
| | .07 | 326 | 326 | 326 | 326 | 326 | 326 | 326 | 326 | 326 | 326 | 326 | 326 | |
| | .08 | 348 | 348 | 348 | 348 | 348 | 348 | 348 | 348 | 348 | 348 | 348 | 348 | |
| | .09 | 370 | 370 | 370 | 370 | 370 | 370 | 370 | 370 | 370 | 370 | 370 | 370 | |
| | .10 | 392 | 392 | 392 | 392 | 392 | 392 | 392 | 392 | 392 | 392 | 392 | 392 | |
| | .12 | 436 | 436 | 436 | 436 | 436 | 436 | 436 | 436 | 436 | 436 | 436 | 436 | |
| | .14 | 480 | 480 | 480 | 480 | 480 | 480 | 480 | 480 | 480 | 480 | 480 | 480 | |
| | .16 | 524 | 524 | 524 | 524 | 524 | 524 | 524 | 524 | 524 | 524 | 524 | 524 | |
| | | 897 | 897 | 897 | 897 | 897 | 897 | 897 | 897 | 897 | 897 | 902 | 902 | |
| 40,000 | | \$ 310 | 349 | 394 | 440 | 485 | 530 | 575 | 620 | 665 | 705 | 795 | 885 | <--THEORETICAL HEATING COST * FURNACE ONLY |
| | .05 | 315 | 315 | 315 | 315 | 315 | 315 | 315 | 315 | 315 | 315 | 315 | 315 | THEORETICAL HEATING COST * FURN. + HEAT PUMP \$ PER YEAR |
| | .06 | 337 | 337 | 337 | 337 | 337 | 337 | 337 | 337 | 337 | 337 | 337 | 337 | |
| | .07 | 359 | 359 | 359 | 359 | 359 | 359 | 359 | 359 | 359 | 359 | 359 | 359 | |
| | .08 | 381 | 381 | 381 | 381 | 381 | 381 | 381 | 381 | 381 | 381 | 381 | 381 | |
| | .09 | 403 | 403 | 403 | 403 | 403 | 403 | 403 | 403 | 403 | 403 | 403 | 403 | |
| | .10 | 425 | 425 | 425 | 425 | 425 | 425 | 425 | 425 | 425 | 425 | 425 | 425 | |
| | .12 | 469 | 469 | 469 | 469 | 469 | 469 | 469 | 469 | 469 | 469 | 469 | 469 | |
| | .14 | 513 | 513 | 513 | 513 | 513 | 513 | 513 | 513 | 513 | 513 | 513 | 513 | |
| | .16 | 557 | 557 | 557 | 557 | 557 | 557 | 557 | 557 | 557 | 557 | 557 | 557 | |
| | | 1010 | 1010 | 1010 | 1010 | 1010 | 1010 | 1010 | 1010 | 1015 | 1015 | 1015 | 1015 | |
| 50,000 | | \$ 383 | 440 | 496 | 552 | 609 | 665 | 716 | 773 | 829 | 885 | 998 | 1105 | <--THEORETICAL HEATING COST * FURNACE ONLY |
| | .05 | 389 | 389 | 389 | 389 | 389 | 389 | 389 | 389 | 389 | 389 | 389 | 389 | THEORETICAL HEATING COST * FURN. + HEAT PUMP \$ PER YEAR |
| | .06 | 411 | 411 | 411 | 411 | 411 | 411 | 411 | 411 | 411 | 411 | 411 | 411 | |
| | .07 | 433 | 433 | 433 | 433 | 433 | 433 | 433 | 433 | 433 | 433 | 433 | 433 | |
| | .08 | 455 | 455 | 455 | 455 | 455 | 455 | 455 | 455 | 455 | 455 | 455 | 455 | |
| | .09 | 477 | 477 | 477 | 477 | 477 | 477 | 477 | 477 | 477 | 477 | 477 | 477 | |
| | .10 | 499 | 499 | 499 | 499 | 499 | 499 | 499 | 499 | 499 | 499 | 499 | 499 | |
| | .12 | 543 | 543 | 543 | 543 | 543 | 543 | 543 | 543 | 543 | 543 | 543 | 543 | |
| | .14 | 587 | 587 | 587 | 587 | 587 | 587 | 587 | 587 | 587 | 587 | 587 | 587 | |
| | .16 | 631 | 631 | 631 | 631 | 631 | 631 | 631 | 631 | 631 | 631 | 631 | 631 | |
| | | 1190 | 1190 | 1196 | 1201 | 1207 | 1207 | 1207 | 1213 | 1213 | 1218 | 1224 | 1230 | |
| 60,000 | | \$ 462 | 530 | 598 | 665 | 727 | 795 | 863 | 931 | 998 | 1060 | 1196 | 1331 | <--THEORETICAL HEATING COST * FURNACE ONLY |
| | .05 | 467 | 467 | 467 | 467 | 467 | 467 | 467 | 467 | 467 | 467 | 467 | 467 | THEORETICAL HEATING COST * FURN. + HEAT PUMP \$ PER YEAR |
| | .06 | 489 | 489 | 489 | 489 | 489 | 489 | 489 | 489 | 489 | 489 | 489 | 489 | |
| | .07 | 511 | 511 | 511 | 511 | 511 | 511 | 511 | 511 | 511 | 511 | 511 | 511 | |
| | .08 | 533 | 533 | 533 | 533 | 533 | 533 | 533 | 533 | 533 | 533 | 533 | 533 | |
| | .09 | 555 | 555 | 555 | 555 | 555 | 555 | 555 | 555 | 555 | 555 | 555 | 555 | |
| | .10 | 577 | 577 | 577 | 577 | 577 | 577 | 577 | 577 | 577 | 577 | 577 | 577 | |
| | .12 | 621 | 621 | 621 | 621 | 621 | 621 | 621 | 621 | 621 | 621 | 621 | 621 | |
| | .14 | 665 | 665 | 665 | 665 | 665 | 665 | 665 | 665 | 665 | 665 | 665 | 665 | |
| | .16 | 709 | 709 | 709 | 709 | 709 | 709 | 709 | 709 | 709 | 709 | 709 | 709 | |
| | | 1275 | 1292 | 1303 | 1314 | 1326 | 1337 | 1354 | 1365 | 1376 | 1388 | 1416 | 1438 | |
| 70,000 | | \$ 541 | 620 | 694 | 773 | 852 | 931 | 1010 | 1083 | 1162 | 1241 | 1393 | 1551 | <--THEORETICAL HEATING COST * FURNACE ONLY |
| | .05 | 530 | 530 | 530 | 530 | 530 | 530 | 530 | 530 | 530 | 530 | 530 | 530 | THEORETICAL HEATING COST * FURN. + HEAT PUMP \$ PER YEAR |
| | .06 | 552 | 552 | 552 | 552 | 552 | 552 | 552 | 552 | 552 | 552 | 552 | 552 | |
| | .07 | 574 | 574 | 574 | 574 | 574 | 574 | 574 | 574 | 574 | 574 | 574 | 574 | |
| | .08 | 596 | 596 | 596 | 596 | 596 | 596 | 596 | 596 | 596 | 596 | 596 | 596 | |
| | .09 | 618 | 618 | 618 | 618 | 618 | 618 | 618 | 618 | 618 | 618 | 618 | 618 | |
| | .10 | 640 | 640 | 640 | 640 | 640 | 640 | 640 | 640 | 640 | 640 | 640 | 640 | |
| | .12 | 684 | 684 | 684 | 684 | 684 | 684 | 684 | 684 | 684 | 684 | 684 | 684 | |
| | .14 | 728 | 728 | 728 | 728 | 728 | 728 | 728 | 728 | 728 | 728 | 728 | 728 | |
| | .16 | 772 | 772 | 772 | 772 | 772 | 772 | 772 | 772 | 772 | 772 | 772 | 772 | |
| | | 1354 | 1376 | 1399 | 1421 | 1444 | 1467 | 1489 | 1512 | 1534 | 1557 | 1602 | 1642 | |

ANNUAL AIR CONDITIONING COST WHEN COOLING LOAD IS SIZED TO MATCH COOLING CAPACITY OF HEAT PUMP

| | | | | | | | | | | |
|----|-----|-----|-----|-----|-----|-----|-----|-----|-----|--------------------------------------|
| \$ | .05 | .06 | .07 | .08 | .09 | .10 | .12 | .14 | .16 | <--ELECTRIC RATE \$/KWH |
| | 93 | 111 | 130 | 149 | 167 | 188 | 223 | 261 | 298 | <--THEORETICAL AIR CONDITIONING COST |

THE ABOVE ANNUAL HEATING AND COOLING OPERATING COSTS ARE THEORETICAL ESTIMATES ONLY AND ARE PROVIDED FOR A COMMON BASIS OF COMPARISON BETWEEN VARIOUS TYPES OF HEATING AND COOLING SYSTEMS. ACTUAL VALUES MAY VARY DEPENDING ON ACTUAL WEATHER CONDITIONS AND INDIVIDUAL USAGE PATTERN.

BARD MANUFACTURING COMPANY
DUAL FUEL ADD-ON HEAT PUMP GUIDE TO ENERGY COST SAVINGS

REGION 4
 HEAT PUMP MODEL: COMPRESSOR SECTION: WDS36A INDOOR: A36AG-A
 COOLING CAPACITY AT 53 DEG. F. ENTERING WATER TEMP.: 36680 BTUH, 15.74 SEER
 HEATING CAPACITY AT 53 DEG. F. ENTERING WATER TEMP.: 35260 BTUH, 3.89 COP
 FURNACE TYPE: FUEL OIL FURNACE EFFICIENCY: 78.00% AFUE

| HEAT LOSS BTUH | ELEC. COST \$/KWH | HEATING OIL COST - \$/GALLON | | | | | | | | | | | | |
|----------------|-------------------|------------------------------|------|------|------|------|------|------|------|------|------|------|---------------------------|--|
| | | .70 | .80 | .90 | 1.00 | 1.10 | 1.20 | 1.30 | 1.40 | 1.50 | 1.60 | 1.70 | | 1.80 |
| 35,000 | \$ | 389 | 445 | 502 | 558 | 615 | 671 | 727 | 784 | 835 | 891 | 947 | 1004 | <--THEORETICAL HEATING COST * FURNACE ONLY |
| | .05 | 382 | 282 | 282 | 282 | 282 | 282 | 282 | 287 | 287 | 287 | 287 | 287 | THEORETICAL HEATING COST * FURN. + HEAT PUMP \$ PER YEAR |
| | .06 | 394 | 338 | 338 | 338 | 338 | 338 | 338 | 344 | 344 | 344 | 344 | 344 | |
| | .07 | 451 | 451 | 451 | 451 | 451 | 451 | 451 | 457 | 457 | 457 | 457 | 457 | |
| | .08 | 507 | 507 | 507 | 507 | 507 | 507 | 507 | 513 | 513 | 513 | 513 | 513 | |
| | .10 | 564 | 564 | 564 | 564 | 564 | 564 | 564 | 569 | 569 | 569 | 569 | 569 | |
| | .12 | 671 | 671 | 671 | 671 | 671 | 671 | 671 | 682 | 682 | 682 | 682 | 682 | |
| .16 | 897 | 897 | 897 | 897 | 897 | 897 | 897 | 902 | 902 | 902 | 902 | 902 | BALANCE POINT 13- DEG. F. | |
| 40,000 | \$ | 445 | 507 | 575 | 637 | 699 | 767 | 829 | 891 | 959 | 1021 | 1083 | 1151 | <--THEORETICAL HEATING COST * FURNACE ONLY |
| | .05 | 315 | 315 | 315 | 321 | 321 | 321 | 321 | 321 | 321 | 327 | 327 | 327 | THEORETICAL HEATING COST * FURN. + HEAT PUMP \$ PER YEAR |
| | .06 | 383 | 383 | 383 | 389 | 389 | 389 | 389 | 389 | 389 | 394 | 394 | 394 | |
| | .07 | 441 | 441 | 441 | 451 | 451 | 451 | 451 | 451 | 451 | 457 | 457 | 457 | |
| | .08 | 507 | 507 | 507 | 513 | 513 | 513 | 513 | 513 | 513 | 519 | 519 | 519 | |
| | .10 | 569 | 569 | 569 | 575 | 575 | 575 | 575 | 575 | 575 | 581 | 581 | 581 | |
| | .12 | 631 | 631 | 631 | 637 | 637 | 637 | 637 | 637 | 637 | 643 | 643 | 643 | |
| .16 | 880 | 880 | 880 | 885 | 885 | 885 | 885 | 885 | 885 | 891 | 891 | 891 | BALANCE POINT 4- DEG. F. | |
| 50,000 | \$ | 558 | 637 | 716 | 795 | 880 | 959 | 1038 | 1117 | 1196 | 1280 | 1359 | 1438 | <--THEORETICAL HEATING COST * FURNACE ONLY |
| | .05 | 400 | 400 | 406 | 411 | 417 | 423 | 423 | 428 | 434 | 440 | 445 | 445 | THEORETICAL HEATING COST * FURN. + HEAT PUMP \$ PER YEAR |
| | .06 | 473 | 473 | 479 | 485 | 490 | 496 | 496 | 502 | 507 | 513 | 519 | 519 | |
| | .07 | 541 | 541 | 547 | 553 | 558 | 564 | 564 | 569 | 575 | 581 | 586 | 586 | |
| | .08 | 615 | 615 | 620 | 626 | 631 | 637 | 637 | 643 | 648 | 654 | 660 | 660 | |
| | .10 | 688 | 688 | 694 | 699 | 705 | 710 | 710 | 716 | 722 | 727 | 733 | 733 | |
| | .12 | 761 | 761 | 767 | 773 | 778 | 784 | 784 | 789 | 795 | 801 | 806 | 806 | |
| .16 | 1055 | 1055 | 1060 | 1066 | 1072 | 1077 | 1077 | 1083 | 1089 | 1094 | 1100 | 1100 | BALANCE POINT 10 DEG. F. | |
| 60,000 | \$ | 671 | 767 | 863 | 959 | 1055 | 1151 | 1247 | 1342 | 1438 | 1534 | 1630 | 1726 | <--THEORETICAL HEATING COST * FURNACE ONLY |
| | .05 | 496 | 513 | 530 | 552 | 569 | 586 | 603 | 620 | 637 | 660 | 677 | 694 | THEORETICAL HEATING COST * FURN. + HEAT PUMP \$ PER YEAR |
| | .06 | 569 | 586 | 603 | 626 | 643 | 660 | 677 | 694 | 710 | 733 | 750 | 767 | |
| | .07 | 643 | 660 | 677 | 699 | 716 | 733 | 750 | 767 | 784 | 806 | 823 | 840 | |
| | .08 | 717 | 739 | 756 | 778 | 795 | 812 | 829 | 846 | 863 | 885 | 902 | 919 | |
| | .10 | 868 | 885 | 902 | 925 | 942 | 959 | 976 | 993 | 1010 | 1032 | 1049 | 1066 | |
| | .12 | 1015 | 1032 | 1049 | 1072 | 1089 | 1105 | 1122 | 1139 | 1156 | 1179 | 1196 | 1213 | |
| .16 | 1314 | 1331 | 1348 | 1371 | 1388 | 1405 | 1421 | 1438 | 1455 | 1478 | 1495 | 1512 | BALANCE POINT 19 DEG. F. | |
| 70,000 | \$ | 784 | 891 | 1004 | 1117 | 1230 | 1342 | 1455 | 1568 | 1675 | 1788 | 1901 | 2014 | <--THEORETICAL HEATING COST * FURNACE ONLY |
| | .05 | 603 | 631 | 646 | 699 | 727 | 761 | 795 | 823 | 857 | 891 | 919 | 953 | THEORETICAL HEATING COST * FURN. + HEAT PUMP \$ PER YEAR |
| | .06 | 677 | 705 | 739 | 773 | 801 | 835 | 868 | 897 | 931 | 964 | 993 | 1026 | |
| | .07 | 750 | 778 | 812 | 846 | 874 | 908 | 942 | 970 | 1004 | 1038 | 1066 | 1100 | |
| | .08 | 829 | 857 | 891 | 925 | 953 | 987 | 1021 | 1049 | 1083 | 1117 | 1145 | 1179 | |
| | .10 | 902 | 931 | 964 | 998 | 1026 | 1060 | 1094 | 1122 | 1156 | 1190 | 1218 | 1252 | |
| | .12 | 976 | 1004 | 1038 | 1072 | 1100 | 1134 | 1168 | 1196 | 1230 | 1263 | 1292 | 1326 | |
| .16 | 1280 | 1309 | 1342 | 1376 | 1405 | 1438 | 1472 | 1500 | 1534 | 1568 | 1596 | 1630 | BALANCE POINT 25 DEG. F. | |

ANNUAL AIR CONDITIONING COST WHEN COOLING LOAD IS SIZED TO MATCH COOLING CAPACITY OF HEAT PUMP

| ELEC. RATE \$/KWH | THEORETICAL AIR CONDITIONING COST |
|-------------------|-----------------------------------|
| .05 | 93 |
| .06 | 111 |
| .07 | 130 |
| .08 | 149 |
| .09 | 167 |
| .10 | 186 |
| .12 | 223 |
| .14 | 261 |
| .16 | 298 |

THE ABOVE ANNUAL HEATING AND COOLING OPERATING COSTS ARE THEORETICAL ESTIMATES ONLY AND ARE PROVIDED FOR A COMMON BASIS OF COMPARISON BETWEEN VARIOUS TYPES OF HEATING AND COOLING SYSTEMS. ACTUAL VALUES MAY VARY DEPENDING ON ACTUAL WEATHER CONDITIONS AND INDIVIDUAL USAGE PATTERN.

BARD MANUFACTURING COMPANY
DUAL FUEL ADD-ON HEAT PUMP GUIDE TO ENERGY COST SAVINGS

REGION 4
 HEAT PUMP MODEL: COMPRESSOR SECTION NOS35A INDOOR A3640-A
 COOLING CAPACITY AT 53 DEG. F. ENTERING WATER TEMP.: 36680 BTUH, 15.74 SCOP
 HEATING CAPACITY AT 53 DEG. F. ENTERING WATER TEMP.: 45280 BTUH, 3.69 COP
 FURNACE TYPE: PROPANE GAS FURNACE EFFICIENCY: 78.00% AFUE

| HEAT LOSS BTUH | HEAT PUMP COST \$/KWHP | PROPANE GAS COST - \$/GALLON | | | | | | | | | | | | | |
|----------------|------------------------|------------------------------|------|------|------|------|------|------|------|------|------|------|---------------------------|--|--|
| | | .60 | .65 | .70 | .75 | .80 | .85 | .90 | .95 | 1.00 | 1.10 | 1.20 | 1.20 | | |
| 35,000 | \$ | 507 | 552 | 592 | 637 | 682 | 722 | 767 | 806 | 852 | 936 | 1021 | 1021 | <--THEORETICAL HEATING COST * FURNACE ONLY | |
| | .05 | 782 | 782 | 782 | 782 | 782 | 787 | 787 | 787 | 787 | 787 | 787 | 787 | THEORETICAL HEATING COST * FURN. + HEAT PUMP \$ PER YEAR | |
| | .06 | 782 | 782 | 782 | 782 | 782 | 787 | 787 | 787 | 787 | 787 | 787 | 787 | | |
| | .07 | 394 | 394 | 394 | 394 | 394 | 400 | 400 | 400 | 400 | 400 | 400 | 400 | | |
| | .08 | 451 | 451 | 451 | 451 | 451 | 457 | 457 | 457 | 457 | 457 | 457 | 457 | | |
| | .09 | 507 | 507 | 507 | 507 | 507 | 513 | 513 | 513 | 513 | 513 | 513 | 513 | | |
| .10 | 564 | 564 | 564 | 564 | 564 | 571 | 571 | 571 | 571 | 571 | 571 | 571 | | | |
| .12 | 677 | 677 | 677 | 677 | 677 | 682 | 682 | 682 | 682 | 682 | 682 | 682 | BALANCE POINT 13- DEG. F. | | |
| .14 | 784 | 784 | 784 | 784 | 784 | 789 | 789 | 789 | 789 | 789 | 789 | 789 | | | |
| .16 | 897 | 897 | 897 | 897 | 897 | 902 | 902 | 902 | 902 | 902 | 902 | 902 | | | |
| 40,000 | \$ | 581 | 631 | 682 | 727 | 778 | 829 | 874 | 925 | 976 | 1072 | 1168 | | 1168 | <--THEORETICAL HEATING COST * FURNACE ONLY |
| | .05 | 315 | 321 | 321 | 321 | 321 | 321 | 321 | 321 | 321 | 321 | 321 | | 321 | THEORETICAL HEATING COST * FURN. + HEAT PUMP \$ PER YEAR |
| | .06 | 389 | 389 | 389 | 389 | 389 | 389 | 389 | 389 | 389 | 389 | 389 | | 389 | |
| | .07 | 445 | 451 | 451 | 451 | 451 | 451 | 451 | 451 | 451 | 451 | 451 | 451 | | |
| | .08 | 507 | 513 | 513 | 513 | 513 | 513 | 513 | 513 | 513 | 513 | 513 | 513 | | |
| | .09 | 569 | 575 | 575 | 575 | 575 | 575 | 575 | 575 | 575 | 575 | 575 | 575 | | |
| .10 | 631 | 637 | 637 | 637 | 637 | 637 | 637 | 637 | 637 | 637 | 637 | 637 | | | |
| .12 | 756 | 761 | 761 | 761 | 761 | 761 | 761 | 761 | 761 | 761 | 761 | 761 | BALANCE POINT 4- DEG. F. | | |
| .14 | 880 | 885 | 885 | 885 | 885 | 885 | 885 | 885 | 885 | 885 | 885 | 885 | | | |
| .16 | 1010 | 1015 | 1015 | 1015 | 1015 | 1015 | 1015 | 1015 | 1015 | 1015 | 1021 | 1021 | | | |
| 50,000 | \$ | 727 | 789 | 852 | 914 | 976 | 1032 | 1094 | 1156 | 1218 | 1337 | 1461 | | 1461 | <--THEORETICAL HEATING COST * FURNACE ONLY |
| | .05 | 406 | 411 | 411 | 417 | 423 | 423 | 428 | 434 | 434 | 440 | 451 | | 451 | THEORETICAL HEATING COST * FURN. + HEAT PUMP \$ PER YEAR |
| | .06 | 479 | 485 | 485 | 490 | 490 | 496 | 502 | 507 | 507 | 513 | 524 | | 524 | |
| | .07 | 547 | 552 | 552 | 558 | 558 | 564 | 569 | 575 | 575 | 581 | 592 | 592 | | |
| | .08 | 620 | 626 | 626 | 631 | 637 | 643 | 648 | 654 | 654 | 660 | 665 | 665 | | |
| | .09 | 694 | 699 | 699 | 705 | 710 | 716 | 722 | 727 | 727 | 733 | 739 | 739 | | |
| .10 | 767 | 773 | 773 | 778 | 784 | 789 | 795 | 795 | 795 | 801 | 812 | 812 | | | |
| .12 | 914 | 919 | 919 | 925 | 931 | 936 | 942 | 942 | 942 | 947 | 959 | 959 | BALANCE POINT 10 DEG. F. | | |
| .14 | 1060 | 1066 | 1066 | 1072 | 1077 | 1083 | 1089 | 1089 | 1089 | 1094 | 1105 | 1105 | | | |
| .16 | 1207 | 1213 | 1213 | 1218 | 1224 | 1224 | 1230 | 1235 | 1235 | 1241 | 1252 | 1252 | | | |
| 60,000 | \$ | 874 | 947 | 1021 | 1094 | 1168 | 1241 | 1314 | 1388 | 1461 | 1608 | 1754 | | 1754 | <--THEORETICAL HEATING COST * FURNACE ONLY |
| | .05 | 536 | 547 | 564 | 575 | 592 | 603 | 615 | 631 | 643 | 671 | 699 | | 699 | THEORETICAL HEATING COST * FURN. + HEAT PUMP \$ PER YEAR |
| | .06 | 609 | 620 | 637 | 648 | 665 | 677 | 688 | 705 | 716 | 744 | 773 | | 773 | |
| | .07 | 682 | 694 | 710 | 722 | 739 | 750 | 761 | 778 | 789 | 818 | 846 | 846 | | |
| | .08 | 761 | 773 | 789 | 801 | 818 | 829 | 840 | 857 | 868 | 897 | 925 | 925 | | |
| | .09 | 835 | 846 | 863 | 874 | 891 | 902 | 914 | 931 | 942 | 970 | 998 | 998 | | |
| .10 | 908 | 919 | 936 | 947 | 964 | 976 | 987 | 1004 | 1015 | 1043 | 1072 | 1072 | | | |
| .12 | 1055 | 1066 | 1083 | 1094 | 1111 | 1123 | 1134 | 1151 | 1161 | 1190 | 1218 | 1218 | BALANCE POINT 19 DEG. F. | | |
| .14 | 1207 | 1218 | 1235 | 1247 | 1263 | 1275 | 1286 | 1303 | 1314 | 1342 | 1371 | 1371 | | | |
| .16 | 1354 | 1365 | 1382 | 1393 | 1410 | 1421 | 1433 | 1450 | 1461 | 1489 | 1517 | 1517 | | | |
| 70,000 | \$ | 1021 | 1105 | 1190 | 1280 | 1365 | 1450 | 1534 | 1619 | 1704 | 1878 | 2048 | | 2048 | <--THEORETICAL HEATING COST * FURNACE ONLY |
| | .05 | 671 | 694 | 716 | 744 | 767 | 789 | 818 | 840 | 863 | 914 | 959 | | 959 | THEORETICAL HEATING COST * FURN. + HEAT PUMP \$ PER YEAR |
| | .06 | 744 | 767 | 789 | 818 | 840 | 863 | 891 | 914 | 936 | 987 | 1032 | | 1032 | |
| | .07 | 818 | 840 | 863 | 891 | 914 | 936 | 964 | 987 | 1010 | 1060 | 1105 | 1105 | | |
| | .08 | 897 | 919 | 942 | 970 | 993 | 1015 | 1043 | 1066 | 1089 | 1139 | 1184 | 1184 | | |
| | .09 | 970 | 993 | 1015 | 1043 | 1066 | 1089 | 1117 | 1139 | 1162 | 1213 | 1258 | 1258 | | |
| .10 | 1043 | 1066 | 1089 | 1117 | 1139 | 1162 | 1190 | 1213 | 1235 | 1286 | 1331 | 1331 | | | |
| .12 | 1196 | 1218 | 1241 | 1269 | 1292 | 1314 | 1342 | 1365 | 1388 | 1438 | 1484 | 1484 | BALANCE POINT 25 DEG. F. | | |
| .14 | 1348 | 1371 | 1393 | 1421 | 1444 | 1467 | 1495 | 1517 | 1540 | 1591 | 1636 | 1636 | | | |
| .16 | 1495 | 1517 | 1540 | 1568 | 1591 | 1613 | 1642 | 1664 | 1687 | 1737 | 1783 | 1783 | | | |

ANNUAL AIR CONDITIONING COST WHEN COOLING LOAD IS SIZED TO MATCH COOLING CAPACITY OF HEAT PUMP

| | .05 | .06 | .07 | .08 | .09 | .10 | .12 | .14 | .16 | |
|----|-----|-----|-----|-----|-----|-----|-----|-----|-----|--------------------------------------|
| \$ | 93 | 111 | 130 | 149 | 167 | 186 | 223 | 261 | 298 | <--ELECTRIC RATE \$/KWH |
| | | | | | | | | | | <--THEORETICAL AIR CONDITIONING COST |

THE ABOVE ANNUAL HEATING AND COOLING OPERATING COSTS ARE THEORETICAL ESTIMATES ONLY AND ARE PROVIDED FOR A COMMON BASIS OF COMPARISON BETWEEN VARIOUS TYPES OF HEATING AND COOLING SYSTEMS. ACTUAL VALUES MAY VARY DEPENDING ON ACTUAL WEATHER CONDITIONS AND INDIVIDUAL USAGE PATTERNS.

BARD MANUFACTURING COMPANY
DUAL FUEL ADD-ON HEAT PUMP GUIDE TO ENERGY COST SAVINGS

REGION 4
 HEAT PUMP MODEL: COMPRESSOR SECTION: NO5424 INDOOR: A4240-A
 COOLING CAPACITY AT 53 DEG.F. ENTERING WATER TEMP.: 43320 BTUH, 1.75 SEER
 HEATING CAPACITY AT 53 DEG.F. ENTERING WATER TEMP.: 41500 BTUH, 3.59 COP
 FURNACE TYPE: ELECTRIC FURNACE EFFICIENCY: 100.00% AFUE

| HEAT LOSS BTUH | HEAT COST \$/KWH | --- THEORETICAL ANNUAL HEATING COST --- | |
|----------------|------------------|---|--------------------------|
| | | HEAT PUMP WITH ELECTRIC HEAT | ELECTRIC HEAT ONLY |
| 40,000 | | | |
| .05 | | 338 | 1010 |
| .06 | | 411 | 1213 |
| .07 | | 479 | 1416 |
| .08 | | 547 | 1619 |
| .09 | | 615 | 1822 |
| .10 | | 682 | 2025 |
| .11 | | 749 | 2228 |
| .12 | | 817 | 2431 |
| .13 | | 884 | 2634 |
| .14 | | 952 | 2837 |
| .15 | | 1019 | 3040 |
| .16 | | 1089 | 3244 |
| | | | BALANCE POINT 16- DEG.F. |
| 50,000 | | | |
| .05 | | 417 | 1263 |
| .06 | | 496 | 1517 |
| .07 | | 561 | 1771 |
| .08 | | 625 | 2025 |
| .09 | | 689 | 2279 |
| .10 | | 753 | 2533 |
| .11 | | 817 | 2787 |
| .12 | | 881 | 3041 |
| .13 | | 945 | 3295 |
| .14 | | 1009 | 3549 |
| .15 | | 1073 | 3803 |
| .16 | | 1137 | 4057 |
| | | | BALANCE POINT 0 DEG.F. |
| 60,000 | | | |
| .05 | | 497 | 1517 |
| .06 | | 582 | 1822 |
| .07 | | 667 | 2127 |
| .08 | | 752 | 2431 |
| .09 | | 837 | 2736 |
| .10 | | 922 | 3041 |
| .11 | | 1007 | 3345 |
| .12 | | 1092 | 3650 |
| .13 | | 1177 | 3955 |
| .14 | | 1262 | 4260 |
| .15 | | 1347 | 4565 |
| .16 | | 1432 | 4869 |
| | | | BALANCE POINT 11 DEG.F. |
| 70,000 | | | |
| .05 | | 581 | 1771 |
| .06 | | 679 | 2127 |
| .07 | | 776 | 2483 |
| .08 | | 874 | 2838 |
| .09 | | 971 | 3193 |
| .10 | | 1069 | 3549 |
| .11 | | 1166 | 3904 |
| .12 | | 1264 | 4260 |
| .13 | | 1361 | 4615 |
| .14 | | 1459 | 4971 |
| .15 | | 1556 | 5326 |
| .16 | | 1654 | 5682 |
| | | | BALANCE POINT 19 DEG.F. |
| 80,000 | | | |
| .05 | | 668 | 2025 |
| .06 | | 779 | 2431 |
| .07 | | 890 | 2837 |
| .08 | | 1001 | 3243 |
| .09 | | 1112 | 3649 |
| .10 | | 1223 | 4055 |
| .11 | | 1334 | 4461 |
| .12 | | 1445 | 4867 |
| .13 | | 1556 | 5273 |
| .14 | | 1667 | 5679 |
| .15 | | 1778 | 6085 |
| .16 | | 1889 | 6491 |
| | | | BALANCE POINT 24 DEG.F. |

ANNUAL AIR CONDITIONING COST WHEN COOLING LOAD IS SIZED TO MATCH COOLING CAPACITY OF HEAT PUMP

| | | | | | | | | | | |
|----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|
| \$ | 106 | 127 | 149 | 170 | 191 | 213 | 235 | 258 | 280 | 317 |
|----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|

-- ELECTRIC RATE \$/KWH
 -- THEORETICAL AIR CONDITIONING COST

THE ABOVE ANNUAL HEATING AND COOLING OPERATING COSTS ARE THEORETICAL ESTIMATES ONLY AND ARE PROVIDED FOR A COMMON BASIS OF COMPARISON BETWEEN VARIOUS TYPES OF HEATING AND COOLING SYSTEMS. ACTUAL VALUES MAY VARY DEPENDING ON ACTUAL WEATHER CONDITIONS AND INDIVIDUAL USAGE PATTERN.

BARD MANUFACTURING COMPANY
DUAL FUEL ADD-ON HEAT PUMP GUIDE TO ENERGY COST SAVINGS

REGION 4
 HEAT PUMP MODEL: COMPRESSOR SECTION: NOS42A INDOOR: A42AG-A
 COOLING CAPACITY AT 53 DEG. F. ENTERING WATER TEMP.: 43320 BTUH 16.45 SEER
 HEATING CAPACITY AT 53 DEG. F. ENTERING WATER TEMP.: 41500 BTUH 3.59 COP
 FURNACE TYPE: NATURAL GAS FURNACE EFFICIENCY: 76.00% AFUE

| HEAT LOSS BTUH | HEAT COST \$/KWH | NATURAL GAS COST - \$/THERM | | | | | | | | | | | | | |
|----------------|--|-----------------------------|------|------|------|------|------|------|------|------|------|------|--------------------------|--|--|
| | | .35 | .40 | .45 | .50 | .55 | .60 | .65 | .70 | .75 | .80 | .90 | | 1.00 | |
| 40,000 | .06 .08 .10 .12 .14 .16 | \$ 310 | 349 | 394 | 440 | 485 | 530 | 575 | 620 | 665 | 705 | 795 | 885 | <--THEORETICAL HEATING COST * FURNACE ONLY | |
| | | 332 | 332 | 332 | 332 | 332 | 332 | 332 | 332 | 332 | 332 | 338 | 338 | 338 | THEORETICAL HEATING COST * FURN. + HEAT PUMP \$ PER YEAR |
| | | 400 | 400 | 400 | 400 | 400 | 400 | 400 | 400 | 400 | 400 | 406 | 406 | 406 | |
| | | 468 | 468 | 468 | 468 | 468 | 468 | 468 | 468 | 468 | 468 | 473 | 473 | 473 | |
| | | 530 | 530 | 530 | 530 | 530 | 530 | 530 | 530 | 530 | 530 | 536 | 536 | 536 | |
| | | 598 | 598 | 598 | 598 | 598 | 598 | 598 | 598 | 598 | 598 | 603 | 603 | 603 | |
| | | 665 | 665 | 665 | 665 | 665 | 665 | 665 | 665 | 665 | 665 | 671 | 671 | 671 | |
| | | 735 | 735 | 735 | 735 | 735 | 735 | 735 | 735 | 735 | 735 | 741 | 741 | 741 | |
| | | 805 | 805 | 805 | 805 | 805 | 805 | 805 | 805 | 805 | 805 | 811 | 811 | 811 | |
| | | 875 | 875 | 875 | 875 | 875 | 875 | 875 | 875 | 875 | 875 | 881 | 881 | 881 | |
| 945 | 945 | 945 | 945 | 945 | 945 | 945 | 945 | 945 | 945 | 951 | 951 | 951 | BALANCE POINT 16- DEG.F. | | |
| 1015 | 1055 | 1055 | 1055 | 1055 | 1055 | 1055 | 1055 | 1055 | 1055 | 1060 | 1060 | 1060 | | | |
| 50,000 | .08 .10 .12 .14 .16 | \$ 380 | 440 | 496 | 552 | 609 | 665 | 716 | 773 | 829 | 885 | 998 | 1105 | <--THEORETICAL HEATING COST * FURNACE ONLY | |
| | | 406 | 406 | 406 | 411 | 411 | 411 | 411 | 411 | 411 | 411 | 417 | 417 | 417 | THEORETICAL HEATING COST * FURN. + HEAT PUMP \$ PER YEAR |
| | | 485 | 485 | 485 | 490 | 490 | 490 | 490 | 490 | 490 | 490 | 496 | 496 | 496 | |
| | | 564 | 564 | 564 | 569 | 569 | 569 | 569 | 569 | 569 | 569 | 575 | 575 | 575 | |
| | | 643 | 643 | 643 | 648 | 648 | 648 | 648 | 648 | 648 | 648 | 654 | 654 | 654 | |
| | | 722 | 722 | 722 | 727 | 727 | 727 | 727 | 727 | 727 | 727 | 733 | 733 | 733 | |
| | | 801 | 801 | 801 | 806 | 806 | 806 | 806 | 806 | 806 | 806 | 812 | 812 | 812 | |
| | | 880 | 880 | 880 | 885 | 885 | 885 | 885 | 885 | 885 | 885 | 891 | 891 | 891 | |
| | | 959 | 959 | 959 | 964 | 964 | 964 | 964 | 964 | 964 | 964 | 970 | 970 | 970 | |
| | | 1038 | 1038 | 1038 | 1043 | 1043 | 1043 | 1043 | 1043 | 1043 | 1043 | 1049 | 1049 | 1049 | |
| 1117 | 1117 | 1117 | 1122 | 1122 | 1122 | 1122 | 1122 | 1122 | 1122 | 1128 | 1128 | 1128 | BALANCE POINT 0 DEG.F. | | |
| 1200 | 1280 | 1280 | 1286 | 1286 | 1286 | 1286 | 1286 | 1286 | 1286 | 1292 | 1292 | 1292 | | | |
| 60,000 | .10 .12 .14 .16 | \$ 462 | 530 | 598 | 665 | 727 | 795 | 863 | 931 | 998 | 1060 | 1196 | 1331 | <--THEORETICAL HEATING COST * FURNACE ONLY | |
| | | 473 | 473 | 479 | 485 | 485 | 490 | 496 | 496 | 496 | 502 | 507 | 513 | 519 | THEORETICAL HEATING COST * FURN. + HEAT PUMP \$ PER YEAR |
| | | 554 | 554 | 559 | 565 | 565 | 571 | 577 | 577 | 577 | 583 | 588 | 594 | 599 | |
| | | 635 | 635 | 640 | 646 | 646 | 652 | 658 | 658 | 658 | 664 | 669 | 675 | 680 | |
| | | 716 | 716 | 721 | 727 | 727 | 733 | 739 | 739 | 739 | 745 | 751 | 757 | 763 | |
| | | 797 | 797 | 802 | 808 | 808 | 814 | 820 | 820 | 820 | 826 | 832 | 838 | 844 | |
| | | 878 | 878 | 883 | 889 | 889 | 895 | 901 | 901 | 901 | 907 | 913 | 919 | 925 | |
| | | 959 | 959 | 964 | 970 | 970 | 976 | 982 | 982 | 982 | 988 | 994 | 1000 | 1006 | |
| | | 1040 | 1040 | 1045 | 1051 | 1051 | 1057 | 1063 | 1063 | 1063 | 1069 | 1075 | 1081 | 1087 | |
| | | 1121 | 1121 | 1126 | 1132 | 1132 | 1138 | 1144 | 1144 | 1144 | 1150 | 1156 | 1162 | 1168 | |
| 1202 | 1282 | 1282 | 1288 | 1288 | 1288 | 1288 | 1288 | 1288 | 1288 | 1294 | 1294 | 1294 | BALANCE POINT 11 DEG.F. | | |
| 1461 | 1461 | 1467 | 1472 | 1472 | 1478 | 1484 | 1484 | 1484 | 1489 | 1495 | 1500 | 1506 | | | |
| 70,000 | .12 .14 .16 | \$ 541 | 620 | 694 | 773 | 852 | 931 | 1010 | 1083 | 1162 | 1241 | 1393 | 1551 | <--THEORETICAL HEATING COST * FURNACE ONLY | |
| | | 547 | 558 | 575 | 592 | 603 | 620 | 631 | 648 | 660 | 677 | 705 | 733 | THEORETICAL HEATING COST * FURN. + HEAT PUMP \$ PER YEAR | |
| | | 627 | 627 | 633 | 639 | 639 | 645 | 651 | 657 | 657 | 663 | 669 | 675 | | 681 |
| | | 707 | 707 | 713 | 719 | 719 | 725 | 731 | 737 | 737 | 743 | 749 | 755 | 761 | |
| | | 787 | 787 | 793 | 799 | 799 | 805 | 811 | 817 | 817 | 823 | 829 | 835 | 841 | |
| | | 867 | 867 | 873 | 879 | 879 | 885 | 891 | 897 | 897 | 903 | 909 | 915 | 921 | |
| | | 947 | 947 | 953 | 959 | 959 | 965 | 971 | 977 | 977 | 983 | 989 | 995 | 1001 | |
| | | 1027 | 1027 | 1033 | 1039 | 1039 | 1045 | 1051 | 1057 | 1057 | 1063 | 1069 | 1075 | 1081 | |
| | | 1107 | 1107 | 1113 | 1119 | 1119 | 1125 | 1131 | 1137 | 1137 | 1143 | 1149 | 1155 | 1161 | |
| | | 1187 | 1187 | 1193 | 1199 | 1199 | 1205 | 1211 | 1217 | 1217 | 1223 | 1229 | 1235 | 1241 | |
| 1267 | 1267 | 1273 | 1279 | 1279 | 1285 | 1291 | 1297 | 1297 | 1303 | 1309 | 1315 | 1321 | BALANCE POINT 19 DEG.F. | | |
| 1529 | 1540 | 1557 | 1574 | 1585 | 1602 | 1613 | 1630 | 1642 | 1658 | 1687 | 1715 | | | | |
| 80,000 | .14 .16 | \$ 620 | 705 | 795 | 885 | 976 | 1060 | 1151 | 1241 | 1331 | 1416 | 1596 | 1771 | <--THEORETICAL HEATING COST * FURNACE ONLY | |
| | | 620 | 648 | 671 | 699 | 722 | 750 | 773 | 801 | 823 | 852 | 902 | 953 | THEORETICAL HEATING COST * FURN. + HEAT PUMP \$ PER YEAR | |
| | | 705 | 705 | 711 | 717 | 717 | 723 | 729 | 735 | 735 | 741 | 747 | 753 | | 759 |
| | | 790 | 790 | 796 | 802 | 808 | 814 | 820 | 826 | 826 | 832 | 838 | 844 | 850 | |
| | | 875 | 875 | 881 | 887 | 887 | 893 | 899 | 905 | 905 | 911 | 917 | 923 | 929 | |
| | | 960 | 960 | 966 | 972 | 972 | 978 | 984 | 990 | 990 | 996 | 1002 | 1008 | 1014 | |
| | | 1045 | 1045 | 1051 | 1057 | 1057 | 1063 | 1069 | 1075 | 1075 | 1081 | 1087 | 1093 | 1099 | |
| | | 1130 | 1130 | 1136 | 1142 | 1142 | 1148 | 1154 | 1160 | 1160 | 1166 | 1172 | 1178 | 1184 | |
| | | 1215 | 1215 | 1221 | 1227 | 1227 | 1233 | 1239 | 1245 | 1245 | 1251 | 1257 | 1263 | 1269 | |
| | | 1300 | 1300 | 1306 | 1312 | 1312 | 1318 | 1324 | 1330 | 1330 | 1336 | 1342 | 1348 | 1354 | |
| 1385 | 1385 | 1391 | 1397 | 1397 | 1403 | 1409 | 1415 | 1415 | 1421 | 1427 | 1433 | 1439 | BALANCE POINT 24 DEG.F. | | |
| 1596 | 1625 | 1647 | 1675 | 1698 | 1726 | 1749 | 1777 | 1799 | 1828 | 1878 | 1929 | | | | |

ANNUAL AIR CONDITIONING COST WHEN COOLING LOAD IS SIZED TO MATCH COOLING CAPACITY OF HEAT PUMP

| | .05 | .06 | .07 | .08 | .09 | .10 | .12 | .14 | .16 | |
|----|-----|-----|-----|-----|-----|-----|-----|-----|-----|--------------------------------------|
| \$ | 106 | 127 | 149 | 170 | 191 | 213 | 255 | 298 | 341 | <--ELECTRIC RATE \$/KWH |
| | | | | | | | | | | <--THEORETICAL AIR CONDITIONING COST |

THE ABOVE ANNUAL HEATING AND COOLING OPERATING COSTS ARE THEORETICAL ESTIMATES ONLY AND ARE PROVIDED FOR A COMMON BASIS OF COMPARISON BETWEEN VARIOUS TYPES OF HEATING AND COOLING SYSTEMS. ACTUAL VALUES MAY VARY DEPENDING ON ACTUAL WEATHER CONDITIONS AND INDIVIDUAL USAGE PATTERN.

BAIRD MANUFACTURING COMPANY

DUAL FUEL ADD-ON HEAT PUMP GUIDE TO ENERGY COST SAVINGS

REGION 4
 HEAT PUMP MODEL COMPRESSION SECTION NOS12A INDOOR A12AC-A
 COOLING CAPACITY AT 53 DEG.F. ENTERING WATER TEMP.: 43320 BTUH, 16.45 SEER
 HEATING CAPACITY AT 53 DEG.F. ENTERING WATER TEMP.: 41500 BTUH, 3.59 COP
 FURNACE TYPE FUEL OIL FURNACE EFFICIENCY 78.0% AFUE

| HEAT LOSS BTUH | ELEC. COST \$/KWH | HEATING OIL COST - \$/GALLON | | | | | | | | | | | | |
|----------------|-------------------|------------------------------|------|------|------|------|------|------|------|------|------|------|------|--|
| | | .70 | .80 | .90 | 1.00 | 1.10 | 1.20 | 1.30 | 1.40 | 1.50 | 1.60 | 1.70 | 1.80 | |
| 40,000 | | \$ 445 | 507 | 575 | 637 | 699 | 767 | 829 | 891 | 959 | 1021 | 1083 | 1151 | <--THEORETICAL HEATING COST * FURNACE ONLY |
| | .05 | \$ 332 | 332 | 332 | 332 | 338 | 338 | 338 | 338 | 338 | 338 | 338 | 344 | THEORETICAL HEATING COST * FURN. + HEAT PUMP \$ PER YEAR |
| | .06 | \$ 400 | 400 | 400 | 400 | 406 | 406 | 406 | 406 | 406 | 406 | 406 | 411 | |
| | .07 | \$ 468 | 468 | 468 | 468 | 473 | 473 | 473 | 473 | 473 | 473 | 473 | 479 | |
| | .08 | \$ 536 | 536 | 536 | 536 | 541 | 541 | 541 | 541 | 541 | 541 | 541 | 547 | |
| | .10 | \$ 604 | 604 | 604 | 604 | 609 | 609 | 609 | 609 | 609 | 609 | 609 | 615 | |
| | .12 | \$ 672 | 672 | 672 | 672 | 677 | 677 | 677 | 677 | 677 | 677 | 677 | 683 | BALANCE POINT 16- DEG.F. |
| | .14 | \$ 740 | 740 | 740 | 740 | 745 | 745 | 745 | 745 | 745 | 745 | 745 | 751 | |
| | .16 | \$ 808 | 808 | 808 | 808 | 813 | 813 | 813 | 813 | 813 | 813 | 813 | 819 | |
| | | \$ 876 | 876 | 876 | 876 | 881 | 881 | 881 | 881 | 881 | 881 | 881 | 887 | |
| | | \$ 944 | 944 | 944 | 944 | 949 | 949 | 949 | 949 | 949 | 949 | 949 | 955 | |
| 50,000 | | \$ 558 | 637 | 716 | 795 | 880 | 959 | 1038 | 1117 | 1196 | 1280 | 1359 | 1438 | <--THEORETICAL HEATING COST * FURNACE ONLY |
| | .05 | \$ 411 | 411 | 411 | 411 | 417 | 417 | 417 | 417 | 423 | 423 | 423 | 423 | THEORETICAL HEATING COST * FURN. + HEAT PUMP \$ PER YEAR |
| | .06 | \$ 490 | 490 | 490 | 490 | 496 | 496 | 496 | 496 | 502 | 502 | 502 | 502 | |
| | .07 | \$ 569 | 569 | 569 | 569 | 575 | 575 | 575 | 575 | 581 | 581 | 581 | 581 | |
| | .08 | \$ 648 | 648 | 648 | 648 | 654 | 654 | 654 | 654 | 660 | 660 | 660 | 660 | |
| | .10 | \$ 727 | 727 | 727 | 727 | 733 | 733 | 733 | 733 | 739 | 739 | 739 | 739 | |
| | .12 | \$ 806 | 806 | 806 | 806 | 812 | 812 | 812 | 812 | 818 | 818 | 818 | 818 | BALANCE POINT 0 DEG.F. |
| | .14 | \$ 885 | 885 | 885 | 885 | 891 | 891 | 891 | 891 | 897 | 897 | 897 | 897 | |
| | .16 | \$ 964 | 964 | 964 | 964 | 970 | 970 | 970 | 970 | 976 | 976 | 976 | 976 | |
| | | \$ 1043 | 1043 | 1043 | 1043 | 1049 | 1049 | 1049 | 1049 | 1055 | 1055 | 1055 | 1055 | |
| | | \$ 1122 | 1122 | 1122 | 1122 | 1128 | 1128 | 1128 | 1128 | 1134 | 1134 | 1134 | 1134 | |
| 60,000 | | \$ 671 | 767 | 863 | 959 | 1055 | 1151 | 1247 | 1342 | 1438 | 1534 | 1630 | 1726 | <--THEORETICAL HEATING COST * FURNACE ONLY |
| | .05 | \$ 485 | 490 | 496 | 502 | 507 | 513 | 519 | 524 | 530 | 536 | 541 | 547 | THEORETICAL HEATING COST * FURN. + HEAT PUMP \$ PER YEAR |
| | .06 | \$ 575 | 581 | 586 | 592 | 597 | 603 | 609 | 615 | 620 | 626 | 631 | 637 | |
| | .07 | \$ 665 | 671 | 677 | 682 | 688 | 694 | 699 | 705 | 710 | 716 | 722 | 727 | |
| | .08 | \$ 754 | 761 | 767 | 773 | 778 | 784 | 789 | 795 | 801 | 806 | 812 | 817 | |
| | .10 | \$ 844 | 851 | 857 | 863 | 868 | 874 | 880 | 885 | 891 | 897 | 902 | 908 | |
| | .12 | \$ 933 | 941 | 947 | 953 | 959 | 964 | 970 | 975 | 981 | 987 | 993 | 998 | BALANCE POINT 11 DEG.F. |
| | .14 | \$ 1022 | 1030 | 1036 | 1042 | 1048 | 1053 | 1059 | 1065 | 1071 | 1076 | 1082 | 1088 | |
| | .16 | \$ 1111 | 1119 | 1125 | 1131 | 1137 | 1143 | 1148 | 1154 | 1160 | 1166 | 1171 | 1177 | |
| | | \$ 1200 | 1208 | 1214 | 1220 | 1226 | 1231 | 1237 | 1243 | 1249 | 1254 | 1260 | 1266 | |
| | | \$ 1289 | 1297 | 1303 | 1309 | 1315 | 1320 | 1326 | 1332 | 1338 | 1343 | 1349 | 1355 | |
| 70,000 | | \$ 784 | 891 | 1004 | 1117 | 1230 | 1342 | 1455 | 1568 | 1675 | 1788 | 1901 | 2014 | <--THEORETICAL HEATING COST * FURNACE ONLY |
| | .05 | \$ 592 | 615 | 631 | 654 | 677 | 694 | 716 | 739 | 756 | 778 | 801 | 818 | THEORETICAL HEATING COST * FURN. + HEAT PUMP \$ PER YEAR |
| | .06 | \$ 682 | 705 | 722 | 744 | 767 | 784 | 806 | 829 | 846 | 868 | 891 | 908 | |
| | .07 | \$ 773 | 796 | 812 | 835 | 857 | 874 | 897 | 919 | 936 | 959 | 981 | 998 | |
| | .08 | \$ 863 | 886 | 902 | 925 | 947 | 964 | 987 | 1010 | 1026 | 1049 | 1072 | 1095 | |
| | .10 | \$ 953 | 976 | 993 | 1015 | 1038 | 1055 | 1077 | 1100 | 1117 | 1139 | 1162 | 1184 | |
| | .12 | \$ 1043 | 1066 | 1077 | 1100 | 1122 | 1139 | 1162 | 1184 | 1201 | 1224 | 1247 | 1263 | BALANCE POINT 19 DEG.F. |
| | .14 | \$ 1133 | 1241 | 1258 | 1280 | 1303 | 1320 | 1342 | 1365 | 1384 | 1405 | 1427 | 1444 | |
| | .16 | \$ 1223 | 1331 | 1348 | 1371 | 1394 | 1410 | 1433 | 1456 | 1475 | 1498 | 1521 | 1544 | |
| | | \$ 1313 | 1421 | 1438 | 1461 | 1484 | 1500 | 1523 | 1546 | 1563 | 1585 | 1608 | 1631 | |
| | | \$ 1403 | 1511 | 1528 | 1551 | 1574 | 1590 | 1613 | 1636 | 1653 | 1680 | 1703 | 1726 | |
| 80,000 | | \$ 891 | 1021 | 1151 | 1280 | 1405 | 1534 | 1664 | 1788 | 1918 | 2048 | 2172 | 2302 | <--THEORETICAL HEATING COST * FURNACE ONLY |
| | .05 | \$ 699 | 739 | 773 | 812 | 846 | 885 | 919 | 959 | 993 | 1026 | 1066 | 1100 | THEORETICAL HEATING COST * FURN. + HEAT PUMP \$ PER YEAR |
| | .06 | \$ 784 | 823 | 857 | 897 | 931 | 970 | 1004 | 1043 | 1077 | 1111 | 1151 | 1184 | |
| | .07 | \$ 873 | 914 | 947 | 987 | 1021 | 1060 | 1094 | 1134 | 1168 | 1201 | 1241 | 1275 | |
| | .08 | \$ 963 | 1004 | 1038 | 1077 | 1111 | 1151 | 1184 | 1224 | 1258 | 1292 | 1331 | 1365 | |
| | .10 | \$ 1053 | 1094 | 1128 | 1168 | 1201 | 1241 | 1275 | 1314 | 1348 | 1382 | 1421 | 1455 | |
| | .12 | \$ 1143 | 1184 | 1218 | 1258 | 1286 | 1326 | 1359 | 1399 | 1433 | 1467 | 1506 | 1540 | BALANCE POINT 24 DEG.F. |
| | .14 | \$ 1233 | 1274 | 1308 | 1348 | 1381 | 1421 | 1454 | 1494 | 1528 | 1562 | 1601 | 1635 | |
| | .16 | \$ 1323 | 1364 | 1398 | 1438 | 1471 | 1511 | 1544 | 1584 | 1618 | 1652 | 1691 | 1725 | |
| | | \$ 1413 | 1454 | 1488 | 1528 | 1561 | 1601 | 1634 | 1674 | 1708 | 1742 | 1781 | 1815 | |
| | | \$ 1503 | 1544 | 1578 | 1618 | 1651 | 1691 | 1724 | 1764 | 1798 | 1832 | 1871 | 1905 | |

ANNUAL AIR CONDITIONING COST WHEN COOLING LOAD IS SIZED TO MATCH COOLING CAPACITY OF HEAT PUMP

| | | | | | | | | | | |
|----|-----|-----|-----|-----|-----|-----|-----|-----|-----|--------------------------------------|
| | .05 | .06 | .07 | .08 | .09 | .10 | .12 | .14 | .16 | <--ELECTRIC RATE \$/KWH |
| \$ | 108 | 127 | 149 | 170 | 191 | 213 | 255 | 298 | 341 | <--THEORETICAL AIR CONDITIONING COST |

THE ABOVE ANNUAL HEATING AND COOLING OPERATING COSTS ARE THEORETICAL ESTIMATES ONLY AND ARE PROVIDED FOR A COMMON BASIS OF COMPARISON BETWEEN VARIOUS TYPES OF HEATING AND COOLING SYSTEMS. ACTUAL VALUES MAY VARY DEPENDING ON ACTUAL WEATHER CONDITIONS AND INDIVIDUAL USAGE PATTERN.

BAIRD MANUFACTURING COMPANY
DUAL FUEL ADD-ON HEAT PUMP GUIDE TO ENERGY COST SAVINGS

REGION 4
 HEAT PUMP MODEL: COMPRESSOR SECTION NOS42A INDOOR A42HO-A
 COOLING CAPACITY AT 53 DEG.F. ENTERING WATER TEMP.: 43320 BTUH, 16.25 SEER
 HEATING CAPACITY AT 53 DEG.F. ENTERING WATER TEMP.: 41500 BTUH, 3.59 COP
 FURNACE TYPE PROPANE GAS FURNACE EFFICIENCY 78.00% AFUE

| HEAT LOSS BTUH | ELEC. COST \$/KWH | PROPANE GAS COST - \$/GALLON | | | | | | | | | | | | | |
|----------------|-------------------|------------------------------|------|------|------|------|------|------|------|------|------|------|------|--|---|
| | | .60 | .65 | .70 | .75 | .80 | .85 | .90 | .95 | 1.00 | 1.10 | 1.20 | 1.20 | | |
| 40,000 | \$ | 581 | 631 | 682 | 727 | 778 | 829 | 874 | 925 | 976 | 1072 | 1168 | 1168 | ---THEORETICAL HEATING COST * FURNACE ONLY | |
| .05 | \$ | 332 | 332 | 332 | 338 | 338 | 338 | 338 | 338 | 338 | 338 | 338 | 344 | 344 | THEORETICAL HEATING COST * FURN.+ HEAT PUMP \$ PER YEAR |
| .06 | \$ | 400 | 400 | 400 | 406 | 406 | 406 | 406 | 406 | 406 | 406 | 406 | 411 | 411 | |
| .07 | \$ | 468 | 468 | 468 | 473 | 473 | 473 | 473 | 473 | 473 | 473 | 473 | 479 | 479 | |
| .08 | \$ | 530 | 530 | 530 | 536 | 536 | 536 | 536 | 536 | 536 | 536 | 536 | 541 | 541 | |
| .09 | \$ | 598 | 598 | 598 | 603 | 603 | 603 | 603 | 603 | 603 | 603 | 603 | 609 | 609 | |
| .10 | \$ | 665 | 665 | 665 | 671 | 671 | 671 | 671 | 671 | 671 | 671 | 671 | 677 | 677 | |
| .12 | \$ | 795 | 795 | 795 | 801 | 801 | 801 | 801 | 801 | 801 | 801 | 801 | 806 | 806 | |
| .14 | \$ | 925 | 925 | 925 | 931 | 931 | 931 | 931 | 931 | 931 | 931 | 931 | 936 | 936 | |
| .16 | \$ | 1055 | 1055 | 1055 | 1060 | 1060 | 1060 | 1060 | 1060 | 1060 | 1060 | 1060 | 1066 | 1066 | BALANCE POINT 16- DEG.F. |
| 50,000 | \$ | 727 | 789 | 852 | 914 | 976 | 1032 | 1094 | 1156 | 1218 | 1337 | 1461 | 1461 | ---THEORETICAL HEATING COST * FURNACE ONLY | |
| .05 | \$ | 411 | 411 | 417 | 417 | 417 | 417 | 417 | 417 | 423 | 423 | 423 | 423 | 423 | THEORETICAL HEATING COST * FURN.+ HEAT PUMP \$ PER YEAR |
| .06 | \$ | 490 | 490 | 496 | 496 | 496 | 496 | 496 | 496 | 502 | 502 | 502 | 502 | 502 | |
| .07 | \$ | 569 | 569 | 575 | 575 | 575 | 575 | 575 | 575 | 581 | 581 | 581 | 581 | 581 | |
| .08 | \$ | 648 | 648 | 654 | 654 | 654 | 654 | 654 | 654 | 660 | 660 | 660 | 660 | 660 | |
| .09 | \$ | 727 | 727 | 733 | 733 | 733 | 733 | 733 | 733 | 739 | 739 | 739 | 739 | 739 | |
| .10 | \$ | 806 | 806 | 812 | 812 | 812 | 812 | 812 | 812 | 818 | 818 | 818 | 818 | 818 | |
| .12 | \$ | 964 | 964 | 970 | 970 | 970 | 970 | 970 | 970 | 976 | 976 | 976 | 976 | 976 | |
| .14 | \$ | 1122 | 1122 | 1128 | 1128 | 1128 | 1128 | 1128 | 1128 | 1134 | 1134 | 1134 | 1134 | 1134 | |
| .16 | \$ | 1286 | 1286 | 1292 | 1292 | 1292 | 1292 | 1292 | 1292 | 1297 | 1297 | 1297 | 1297 | 1297 | BALANCE POINT 0 DEG.F. |
| 60,000 | \$ | 874 | 947 | 1021 | 1094 | 1168 | 1241 | 1314 | 1388 | 1461 | 1608 | 1754 | 1754 | ---THEORETICAL HEATING COST * FURNACE ONLY | |
| .05 | \$ | 496 | 496 | 502 | 507 | 513 | 519 | 524 | 530 | 536 | 541 | 541 | 541 | 541 | THEORETICAL HEATING COST * FURN.+ HEAT PUMP \$ PER YEAR |
| .06 | \$ | 580 | 586 | 592 | 598 | 603 | 609 | 615 | 620 | 626 | 631 | 631 | 631 | 631 | |
| .07 | \$ | 671 | 677 | 683 | 688 | 694 | 699 | 705 | 710 | 716 | 722 | 722 | 722 | 722 | |
| .08 | \$ | 767 | 767 | 773 | 778 | 784 | 789 | 795 | 801 | 806 | 812 | 812 | 812 | 812 | |
| .09 | \$ | 857 | 857 | 863 | 868 | 874 | 880 | 885 | 891 | 897 | 902 | 902 | 902 | 902 | |
| .10 | \$ | 947 | 947 | 953 | 959 | 964 | 964 | 970 | 976 | 981 | 987 | 993 | 993 | 993 | |
| .12 | \$ | 1128 | 1128 | 1134 | 1139 | 1145 | 1151 | 1156 | 1162 | 1168 | 1173 | 1173 | 1173 | 1173 | |
| .14 | \$ | 1309 | 1309 | 1314 | 1320 | 1326 | 1331 | 1337 | 1342 | 1348 | 1354 | 1354 | 1354 | 1354 | |
| .16 | \$ | 1484 | 1484 | 1489 | 1495 | 1500 | 1506 | 1512 | 1517 | 1523 | 1529 | 1529 | 1529 | 1529 | BALANCE POINT 11 DEG.F. |
| 70,000 | \$ | 1021 | 1105 | 1190 | 1280 | 1365 | 1450 | 1534 | 1619 | 1704 | 1878 | 2048 | 2048 | ---THEORETICAL HEATING COST * FURNACE ONLY | |
| .05 | \$ | 637 | 654 | 665 | 682 | 699 | 716 | 733 | 744 | 761 | 795 | 829 | 829 | 829 | THEORETICAL HEATING COST * FURN.+ HEAT PUMP \$ PER YEAR |
| .06 | \$ | 757 | 774 | 786 | 803 | 819 | 836 | 853 | 865 | 885 | 919 | 919 | 919 | 919 | |
| .07 | \$ | 878 | 895 | 907 | 924 | 940 | 957 | 974 | 987 | 1004 | 1038 | 1010 | 1010 | 1010 | |
| .08 | \$ | 998 | 1015 | 1026 | 1043 | 1060 | 1077 | 1094 | 1105 | 1122 | 1156 | 1190 | 1190 | 1190 | |
| .09 | \$ | 1083 | 1100 | 1111 | 1128 | 1145 | 1162 | 1179 | 1190 | 1207 | 1241 | 1275 | 1275 | 1275 | |
| .10 | \$ | 1263 | 1280 | 1292 | 1309 | 1326 | 1344 | 1359 | 1371 | 1388 | 1421 | 1455 | 1455 | 1455 | |
| .12 | \$ | 1444 | 1461 | 1472 | 1489 | 1506 | 1523 | 1540 | 1551 | 1568 | 1602 | 1636 | 1636 | 1636 | |
| .14 | \$ | 1619 | 1636 | 1647 | 1664 | 1681 | 1698 | 1715 | 1726 | 1743 | 1777 | 1811 | 1811 | 1811 | BALANCE POINT 19 DEG.F. |
| 80,000 | \$ | 1168 | 1263 | 1365 | 1461 | 1557 | 1658 | 1754 | 1850 | 1952 | 2144 | 2341 | 2341 | ---THEORETICAL HEATING COST * FURNACE ONLY | |
| .05 | \$ | 778 | 806 | 835 | 863 | 891 | 919 | 947 | 976 | 1004 | 1055 | 1111 | 1111 | 1111 | THEORETICAL HEATING COST * FURN.+ HEAT PUMP \$ PER YEAR |
| .06 | \$ | 863 | 891 | 919 | 947 | 976 | 1004 | 1032 | 1060 | 1089 | 1139 | 1196 | 1196 | 1196 | |
| .07 | \$ | 953 | 981 | 1010 | 1038 | 1066 | 1094 | 1122 | 1151 | 1179 | 1230 | 1286 | 1286 | 1286 | |
| .08 | \$ | 1043 | 1071 | 1100 | 1128 | 1156 | 1184 | 1212 | 1241 | 1269 | 1320 | 1376 | 1376 | 1376 | |
| .09 | \$ | 1134 | 1162 | 1190 | 1218 | 1247 | 1275 | 1303 | 1331 | 1359 | 1410 | 1467 | 1467 | 1467 | |
| .10 | \$ | 1218 | 1247 | 1275 | 1303 | 1331 | 1359 | 1388 | 1416 | 1444 | 1495 | 1551 | 1551 | 1551 | |
| .12 | \$ | 1399 | 1427 | 1455 | 1483 | 1511 | 1540 | 1568 | 1596 | 1625 | 1675 | 1731 | 1731 | 1731 | |
| .14 | \$ | 1574 | 1602 | 1630 | 1658 | 1687 | 1715 | 1743 | 1771 | 1799 | 1850 | 1907 | 1907 | 1907 | |
| .16 | \$ | 1754 | 1783 | 1811 | 1839 | 1867 | 1895 | 1924 | 1952 | 1980 | 2031 | 2087 | 2087 | 2087 | BALANCE POINT 24 DEG.F. |

ANNUAL AIR CONDITIONING COST WHEN COOLING LOAD IS SIZED TO MATCH COOLING CAPACITY OF HEAT PUMP

| | .05 | .06 | .07 | .08 | .09 | .10 | .12 | .14 | .16 | |
|----|-----|-----|-----|-----|-----|-----|-----|-----|-----|--------------------------------------|
| \$ | 108 | 127 | 149 | 170 | 191 | 213 | 255 | 298 | 341 | ---ELECTRIC RATE \$/KWH |
| | | | | | | | | | | ---THEORETICAL AIR CONDITIONING COST |

THE ABOVE ANNUAL HEATING AND COOLING OPERATING COSTS ARE THEORETICAL ESTIMATES ONLY AND ARE PROVIDED FOR A COMMON BASIS OF COMPARISON BETWEEN VARIOUS TYPES OF HEATING AND COOLING SYSTEMS. ACTUAL VALUES MAY VARY DEPENDING ON ACTUAL WEATHER CONDITIONS AND INDIVIDUAL USAGE PATTERN.

BARD MANUFACTURING COMPANY
 DUAL FUEL ADD-ON HEAT PUMP GUIDE TO ENERGY COST SAVINGS

REGION 4
 HEAT PUMP MODEL: OUTDOOR 24HRPDA 24HRPDA/A30AQ-A
 (INDOOR A30AQ-A)
 RATED COOLING CAP.: BTUH(95) 24000, SEER 9.69
 RATED HEATING CAP.: BTUH(47) 24800, COP(47) 2.90, HSPF 6.40 MIN. DER REG IV
 BTUH(17) 12500, COP(17) 1.90
 FURNACE TYPE ELECTRIC FURNACE EFFICIENCY 100.00 % AFUE

HEAT PUMP COST \$/KWH
 ELEC. COST \$/KWH

25,000

--- THEORETICAL ANNUAL HEATING COST ---
 HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

| | | |
|-----|------|------|
| .05 | 332 | 631 |
| .06 | 400 | 756 |
| .07 | 473 | 886 |
| .08 | 541 | 1010 |
| .09 | 603 | 1139 |
| .10 | 671 | 1263 |
| .11 | 734 | 1391 |
| .12 | 802 | 1517 |
| .14 | 942 | 1771 |
| .16 | 1077 | 2025 |

BALANCE POINT 21 DEG.F.

30,000

--- THEORETICAL ANNUAL HEATING COST ---
 HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

| | | |
|-----|------|------|
| .05 | 411 | 756 |
| .06 | 490 | 908 |
| .07 | 575 | 1060 |
| .08 | 654 | 1213 |
| .09 | 733 | 1365 |
| .10 | 812 | 1517 |
| .11 | 891 | 1672 |
| .12 | 970 | 1822 |
| .14 | 1139 | 2177 |
| .16 | 1303 | 2431 |

BALANCE POINT 25 DEG.F.

35,000

--- THEORETICAL ANNUAL HEATING COST ---
 HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

| | | |
|-----|------|------|
| .05 | 485 | 885 |
| .06 | 586 | 1060 |
| .07 | 677 | 1241 |
| .08 | 778 | 1416 |
| .09 | 874 | 1596 |
| .10 | 970 | 1771 |
| .11 | 1068 | 1947 |
| .12 | 1169 | 2122 |
| .14 | 1359 | 2482 |
| .16 | 1557 | 2838 |

BALANCE POINT 29 DEG.F.

40,000

--- THEORETICAL ANNUAL HEATING COST ---
 HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

| | | |
|-----|------|------|
| .05 | 569 | 1010 |
| .06 | 672 | 1213 |
| .07 | 777 | 1416 |
| .08 | 886 | 1619 |
| .09 | 991 | 1822 |
| .10 | 1091 | 2025 |
| .11 | 1194 | 2231 |
| .12 | 1299 | 2431 |
| .14 | 1586 | 2838 |
| .16 | 1817 | 3244 |

BALANCE POINT 31 DEG.F.

50,000

--- THEORETICAL ANNUAL HEATING COST ---
 HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

| | | |
|-----|------|------|
| .05 | 750 | 1263 |
| .06 | 902 | 1517 |
| .07 | 1059 | 1771 |
| .08 | 1221 | 2025 |
| .09 | 1389 | 2279 |
| .10 | 1559 | 2533 |
| .11 | 1734 | 2787 |
| .12 | 1914 | 3041 |
| .14 | 2110 | 3549 |
| .16 | 2415 | 4057 |

BALANCE POINT 36 DEG.F.

ANNUAL AIR CONDITIONING COST WHEN COOLING LOAD IS SIZED TO MATCH COOLING CAPACITY OF HEAT PUMP

| | | | | | | | | | |
|----|-----|-----|-----|-----|-----|-----|-----|-----|-----|
| \$ | .05 | .06 | .07 | .08 | .09 | .10 | .12 | .14 | .16 |
| | 99 | 118 | 138 | 158 | 178 | 198 | 237 | 277 | 317 |

<--ELECTRIC RATE \$/KWH
 <--THEORETICAL AIR CONDITIONING COST

THE ABOVE ANNUAL HEATING AND COOLING OPERATING COSTS ARE THEORETICAL ESTIMATES ONLY AND ARE PROVIDED FOR A COMMON BASIS OF COMPARISON BETWEEN VARIOUS TYPES OF HEATING AND COOLING SYSTEMS. ACTUAL VALUES MAY VARY DEPENDING ON ACTUAL WEATHER CONDITIONS AND INDIVIDUAL USAGE PATTERN.

BARD MANUFACTURING COMPANY

DUAL FUEL ADD-ON HEAT PUMP GUIDE TO ENERGY COST SAVINGS

REGION 4
 HEAT PUMP MODEL: OUTDOOR 24URP0A / INDOOR A30N0-A
 ARI RATED COOLING CAP.: BTUH (95) 24000 SEER 9.69
 ARI RATED HEATING CAP.: BTUH (47) 24000 COP (17) 2.90, HSPF 6.40 MIN. DHR REG IV
 FURNACE TYPE NATURAL GAS FURNACE EFFICIENCY 78.00 % AFUE

| HEAT LOSS BTUH | ELEC. COST \$/KWH | NATURAL GAS COST - \$/THERM | | | | | | | | | | | | |
|----------------|-------------------|-----------------------------|-----|-----|------|------|------|------|------|------|------|------|------|---|
| | | .35 | .40 | .45 | .50 | .55 | .60 | .65 | .70 | .75 | .80 | .90 | | 1.00 |
| 25,000 | \$ | 191 | 220 | 248 | 276 | 304 | 332 | 355 | 383 | 411 | 440 | 496 | 552 | <--THEORETICAL HEATING COST * FURNACE ONLY |
| .05 | \$ | 282 | 287 | 293 | 299 | 304 | 310 | 315 | 321 | 327 | 332 | 338 | 349 | THEORETICAL HEATING COST * FURN.+ HEAT PUMP \$ PER YEAR |
| .06 | \$ | 334 | 338 | 344 | 349 | 355 | 361 | 366 | 372 | 378 | 383 | 389 | 400 | |
| .07 | \$ | 378 | 383 | 389 | 394 | 400 | 406 | 411 | 417 | 422 | 428 | 434 | 445 | |
| .08 | \$ | 428 | 434 | 440 | 445 | 451 | 457 | 462 | 468 | 473 | 479 | 485 | 496 | |
| .09 | \$ | 479 | 485 | 490 | 496 | 502 | 507 | 513 | 519 | 524 | 530 | 536 | 547 | |
| .10 | \$ | 530 | 536 | 541 | 547 | 552 | 558 | 564 | 569 | 575 | 581 | 587 | 598 | |
| .12 | \$ | 634 | 640 | 646 | 651 | 657 | 663 | 668 | 674 | 680 | 686 | 692 | 703 | BALANCE POINT 21 DEG.F. |
| .14 | \$ | 727 | 733 | 739 | 744 | 750 | 756 | 761 | 767 | 773 | 778 | 784 | 795 | |
| .16 | \$ | 823 | 829 | 835 | 840 | 846 | 852 | 857 | 863 | 868 | 874 | 880 | 891 | |
| 30,000 | \$ | 231 | 265 | 299 | 332 | 361 | 394 | 428 | 462 | 496 | 530 | 598 | 665 | |
| .05 | \$ | 321 | 327 | 333 | 349 | 355 | 366 | 378 | 389 | 394 | 406 | 423 | 445 | THEORETICAL HEATING COST * FURN.+ HEAT PUMP \$ PER YEAR |
| .06 | \$ | 372 | 378 | 389 | 400 | 406 | 417 | 428 | 440 | 445 | 457 | 473 | 496 | |
| .07 | \$ | 424 | 428 | 440 | 451 | 457 | 468 | 479 | 490 | 496 | 507 | 524 | 547 | |
| .08 | \$ | 473 | 479 | 490 | 502 | 507 | 519 | 530 | 541 | 547 | 558 | 575 | 598 | |
| .09 | \$ | 524 | 530 | 541 | 552 | 558 | 569 | 581 | 592 | 598 | 609 | 626 | 648 | |
| .10 | \$ | 575 | 581 | 592 | 603 | 609 | 620 | 631 | 643 | 648 | 660 | 677 | 699 | |
| .12 | \$ | 677 | 683 | 689 | 699 | 705 | 716 | 727 | 739 | 744 | 756 | 773 | 795 | BALANCE POINT 25 DEG.F. |
| .14 | \$ | 773 | 778 | 789 | 801 | 806 | 818 | 829 | 840 | 848 | 857 | 874 | 897 | |
| .16 | \$ | 874 | 880 | 891 | 902 | 908 | 919 | 931 | 942 | 947 | 959 | 976 | 998 | |
| 35,000 | \$ | 270 | 310 | 344 | 383 | 423 | 462 | 502 | 541 | 581 | 620 | 694 | 773 | |
| .05 | \$ | 344 | 351 | 378 | 394 | 411 | 428 | 445 | 462 | 479 | 496 | 524 | 558 | THEORETICAL HEATING COST * FURN.+ HEAT PUMP \$ PER YEAR |
| .06 | \$ | 389 | 394 | 406 | 423 | 440 | 457 | 473 | 490 | 496 | 514 | 541 | 581 | |
| .07 | \$ | 434 | 439 | 451 | 468 | 485 | 502 | 519 | 536 | 541 | 569 | 596 | 648 | |
| .08 | \$ | 479 | 485 | 513 | 530 | 547 | 564 | 581 | 598 | 615 | 631 | 660 | 694 | |
| .09 | \$ | 524 | 530 | 541 | 552 | 558 | 569 | 581 | 592 | 603 | 615 | 631 | 660 | |
| .10 | \$ | 575 | 581 | 592 | 603 | 609 | 620 | 631 | 643 | 648 | 660 | 677 | 699 | |
| .12 | \$ | 683 | 689 | 699 | 716 | 733 | 750 | 767 | 784 | 801 | 818 | 848 | 880 | BALANCE POINT 29 DEG.F. |
| .14 | \$ | 781 | 789 | 795 | 812 | 829 | 846 | 863 | 880 | 897 | 914 | 942 | 976 | |
| .16 | \$ | 882 | 888 | 895 | 902 | 919 | 936 | 953 | 970 | 987 | 1004 | 1032 | 1066 | |
| 40,000 | \$ | 310 | 349 | 394 | 440 | 485 | 530 | 575 | 620 | 665 | 705 | 795 | 885 | |
| .05 | \$ | 389 | 411 | 428 | 445 | 468 | 485 | 502 | 524 | 541 | 558 | 598 | 637 | THEORETICAL HEATING COST * FURN.+ HEAT PUMP \$ PER YEAR |
| .06 | \$ | 440 | 464 | 479 | 496 | 519 | 536 | 555 | 575 | 592 | 609 | 648 | 688 | |
| .07 | \$ | 490 | 513 | 530 | 547 | 569 | 586 | 603 | 626 | 643 | 660 | 699 | 739 | |
| .08 | \$ | 541 | 564 | 581 | 598 | 620 | 637 | 654 | 677 | 694 | 710 | 750 | 789 | |
| .09 | \$ | 592 | 615 | 631 | 648 | 671 | 688 | 705 | 727 | 744 | 761 | 801 | 840 | |
| .10 | \$ | 643 | 665 | 682 | 699 | 722 | 739 | 759 | 778 | 795 | 812 | 852 | 891 | |
| .12 | \$ | 750 | 773 | 789 | 806 | 829 | 846 | 863 | 885 | 902 | 919 | 959 | 998 | BALANCE POINT 31 DEG.F. |
| .14 | \$ | 852 | 874 | 891 | 908 | 931 | 947 | 964 | 987 | 1004 | 1021 | 1060 | 1100 | |
| .16 | \$ | 953 | 976 | 993 | 1010 | 1032 | 1049 | 1066 | 1089 | 1105 | 1122 | 1162 | 1201 | |
| 50,000 | \$ | 383 | 440 | 496 | 552 | 609 | 665 | 716 | 773 | 829 | 885 | 998 | 1105 | |
| .05 | \$ | 465 | 479 | 513 | 541 | 581 | 609 | 643 | 677 | 710 | 744 | 812 | 874 | THEORETICAL HEATING COST * FURN.+ HEAT PUMP \$ PER YEAR |
| .06 | \$ | 520 | 524 | 558 | 581 | 626 | 654 | 688 | 723 | 756 | 789 | 857 | 919 | |
| .07 | \$ | 575 | 589 | 603 | 637 | 671 | 699 | 733 | 767 | 801 | 835 | 902 | 964 | |
| .08 | \$ | 620 | 626 | 643 | 677 | 710 | 739 | 773 | 806 | 840 | 874 | 942 | 1004 | |
| .09 | \$ | 660 | 666 | 682 | 716 | 750 | 784 | 818 | 853 | 885 | 919 | 987 | 1049 | |
| .10 | \$ | 700 | 706 | 722 | 756 | 790 | 823 | 857 | 891 | 925 | 959 | 1026 | 1088 | |
| .12 | \$ | 806 | 812 | 828 | 862 | 896 | 914 | 947 | 981 | 1015 | 1049 | 1117 | 1179 | BALANCE POINT 36 DEG.F. |
| .14 | \$ | 906 | 912 | 928 | 962 | 996 | 1030 | 1064 | 1098 | 1134 | 1201 | 1263 | 1325 | |
| .16 | \$ | 979 | 985 | 997 | 1021 | 1055 | 1083 | 1117 | 1151 | 1184 | 1218 | 1286 | 1348 | |

ANNUAL AIR CONDITIONING COST WHEN COOLING LOAD IS SIZED TO MATCH COOLING CAPACITY OF HEAT PUMP

| | | | | | | | | | | |
|----|-----|-----|-----|-----|-----|-----|-----|-----|-----|--------------------------------------|
| \$ | .06 | .06 | .07 | .08 | .09 | .10 | .12 | .14 | .16 | <--ELECTRIC RATE \$/KWH |
| \$ | .99 | 118 | 138 | 158 | 178 | 198 | 237 | 277 | 317 | <--THEORETICAL AIR CONDITIONING COST |

THE ABOVE ANNUAL HEATING AND COOLING OPERATING COSTS ARE THEORETICAL ESTIMATES ONLY AND ARE PROVIDED FOR A COMMON BASIS OF COMPARISON BETWEEN VARIOUS TYPES OF HEATING AND COOLING SYSTEMS. ACTUAL VALUES MAY VARY DEPENDING ON ACTUAL WEATHER CONDITIONS AND INDIVIDUAL USAGE PATTERN.

BARD MANUFACTURING COMPANY

DUAL FUEL ADD-ON HEAT PUMP GUIDE TO ENERGY COST SAVINGS

REGION 4
 HEAT PUMP MODEL: 24URPQA/300Q-A
 24URPQA/300Q-A
 INDOOR 300Q-A
 AIR RATED COOLING CAP.: BTUH (95) 24000 SEER 9.69
 AIR RATED HEATING CAP.: BTUH (47) 21600 COP(47) 2.30 SEFP 6.40 MIN.DBR REG IV
 BTUH (17) 12500 COP(17) 1.30
 FURNACE TYPE FURN. OIL FURNACE EFFICIENCY 78.00 % AFUE

| HEAT LOSS BTUH | ELEC. COST \$/KWH | HEATING OIL COST - \$/GALLON | | | | | | | | | | | | | |
|----------------|-------------------|------------------------------|------|------|------|------|------|------|------|------|------|------|------|---|--|
| | | .70 | .80 | .90 | 1.00 | 1.10 | 1.20 | 1.30 | 1.40 | 1.50 | 1.60 | 1.70 | | 1.80 | |
| 25,000 | \$ | 276 | 315 | 355 | 394 | 440 | 479 | 519 | 558 | 598 | 637 | 677 | 716 | ---THEORETICAL HEATING COST * FURNACE ONLY | |
| .05 | \$ | 299 | 310 | 315 | 321 | 322 | 328 | 334 | 349 | 361 | 366 | 372 | 383 | THEORETICAL HEATING COST * FURN.+ HEAT PUMP | |
| .06 | \$ | 345 | 361 | 366 | 372 | 373 | 383 | 389 | 394 | 400 | 411 | 417 | 423 | \$ PER YEAR | |
| .07 | \$ | 391 | 406 | 411 | 417 | 428 | 434 | 440 | 445 | 451 | 462 | 468 | 474 | | |
| .08 | \$ | 445 | 457 | 464 | 468 | 479 | 485 | 490 | 496 | 507 | 513 | 519 | 524 | | |
| .09 | \$ | 498 | 507 | 513 | 519 | 530 | 536 | 541 | 547 | 558 | 564 | 569 | 574 | | |
| .10 | \$ | 547 | 558 | 564 | 569 | 581 | 586 | 592 | 598 | 609 | 615 | 620 | 625 | | |
| .12 | \$ | 643 | 651 | 657 | 662 | 677 | 682 | 688 | 694 | 705 | 710 | 716 | 721 | | |
| .14 | \$ | 744 | 756 | 761 | 767 | 778 | 784 | 789 | 795 | 806 | 812 | 818 | 823 | BALANCE POINT 21 DEG.F. | |
| .16 | \$ | 840 | 852 | 857 | 863 | 874 | 880 | 885 | 891 | 902 | 908 | 914 | 925 | | |
| 30,000 | \$ | 332 | 383 | 428 | 479 | 524 | 575 | 620 | 671 | 716 | 767 | 812 | 863 | ---THEORETICAL HEATING COST * FURNACE ONLY | |
| .05 | \$ | 349 | 361 | 378 | 389 | 406 | 417 | 434 | 445 | 457 | 473 | 485 | 502 | THEORETICAL HEATING COST * FURN.+ HEAT PUMP | |
| .06 | \$ | 400 | 411 | 428 | 440 | 457 | 468 | 485 | 496 | 507 | 524 | 536 | 553 | \$ PER YEAR | |
| .07 | \$ | 451 | 462 | 479 | 490 | 507 | 519 | 536 | 547 | 564 | 575 | 586 | 603 | | |
| .08 | \$ | 502 | 513 | 530 | 541 | 558 | 569 | 586 | 598 | 609 | 626 | 637 | 654 | | |
| .09 | \$ | 553 | 564 | 581 | 592 | 609 | 620 | 637 | 648 | 660 | 677 | 688 | 705 | | |
| .10 | \$ | 603 | 615 | 631 | 643 | 660 | 671 | 688 | 699 | 710 | 727 | 739 | 756 | | |
| .12 | \$ | 699 | 710 | 727 | 739 | 756 | 767 | 784 | 795 | 806 | 823 | 835 | 852 | | |
| .14 | \$ | 801 | 812 | 829 | 840 | 857 | 868 | 885 | 897 | 908 | 925 | 936 | 953 | BALANCE POINT 25 DEG.F. | |
| .16 | \$ | 902 | 914 | 931 | 942 | 959 | 970 | 987 | 998 | 1010 | 1026 | 1038 | 1055 | | |
| 35,000 | \$ | 389 | 445 | 502 | 558 | 615 | 671 | 727 | 784 | 835 | 891 | 947 | 1004 | ---THEORETICAL HEATING COST * FURNACE ONLY | |
| .05 | \$ | 394 | 423 | 445 | 468 | 490 | 513 | 541 | 564 | 586 | 609 | 631 | 660 | THEORETICAL HEATING COST * FURN.+ HEAT PUMP | |
| .06 | \$ | 445 | 468 | 490 | 513 | 536 | 558 | 581 | 603 | 631 | 654 | 677 | 705 | \$ PER YEAR | |
| .07 | \$ | 496 | 513 | 536 | 558 | 581 | 603 | 631 | 654 | 677 | 699 | 722 | 750 | | |
| .08 | \$ | 547 | 564 | 581 | 603 | 626 | 648 | 677 | 699 | 727 | 744 | 767 | 795 | | |
| .09 | \$ | 598 | 609 | 631 | 654 | 677 | 699 | 727 | 750 | 773 | 795 | 818 | 846 | | |
| .10 | \$ | 648 | 654 | 677 | 699 | 727 | 744 | 773 | 795 | 818 | 840 | 863 | 891 | | |
| .12 | \$ | 716 | 744 | 767 | 789 | 813 | 835 | 863 | 885 | 908 | 931 | 953 | 981 | | |
| .14 | \$ | 812 | 840 | 863 | 885 | 908 | 931 | 959 | 981 | 1004 | 1026 | 1049 | 1077 | BALANCE POINT 29 DEG.F. | |
| .16 | \$ | 902 | 931 | 953 | 976 | 998 | 1021 | 1049 | 1072 | 1094 | 1117 | 1139 | 1168 | | |
| 40,000 | \$ | 445 | 507 | 575 | 637 | 699 | 767 | 829 | 891 | 959 | 1021 | 1083 | 1151 | ---THEORETICAL HEATING COST * FURNACE ONLY | |
| .05 | \$ | 451 | 473 | 502 | 530 | 558 | 586 | 609 | 637 | 665 | 694 | 722 | 744 | THEORETICAL HEATING COST * FURN.+ HEAT PUMP | |
| .06 | \$ | 502 | 524 | 552 | 581 | 609 | 637 | 660 | 688 | 716 | 744 | 773 | 795 | \$ PER YEAR | |
| .07 | \$ | 553 | 575 | 603 | 631 | 660 | 688 | 710 | 739 | 767 | 795 | 823 | 846 | | |
| .08 | \$ | 603 | 626 | 654 | 682 | 710 | 739 | 761 | 789 | 816 | 846 | 874 | 897 | | |
| .09 | \$ | 654 | 677 | 705 | 733 | 761 | 789 | 813 | 840 | 868 | 897 | 925 | 947 | | |
| .10 | \$ | 705 | 727 | 756 | 784 | 812 | 840 | 863 | 891 | 919 | 947 | 976 | 998 | | |
| .12 | \$ | 812 | 840 | 863 | 891 | 919 | 947 | 970 | 998 | 1026 | 1055 | 1083 | 1105 | | |
| .14 | \$ | 914 | 936 | 964 | 993 | 1021 | 1049 | 1072 | 1100 | 1128 | 1156 | 1184 | 1207 | BALANCE POINT 31 DEG.F. | |
| .16 | \$ | 1015 | 1038 | 1066 | 1094 | 1122 | 1151 | 1173 | 1201 | 1230 | 1258 | 1286 | 1309 | | |
| 50,000 | \$ | 558 | 637 | 716 | 795 | 880 | 959 | 1038 | 1117 | 1196 | 1280 | 1359 | 1438 | ---THEORETICAL HEATING COST * FURNACE ONLY | |
| .05 | \$ | 547 | 598 | 643 | 694 | 739 | 789 | 835 | 885 | 931 | 976 | 1026 | 1072 | THEORETICAL HEATING COST * FURN.+ HEAT PUMP | |
| .06 | \$ | 598 | 643 | 688 | 739 | 784 | 835 | 880 | 931 | 976 | 1021 | 1072 | 1117 | \$ PER YEAR | |
| .07 | \$ | 648 | 688 | 733 | 784 | 829 | 880 | 925 | 976 | 1021 | 1066 | 1117 | 1162 | | |
| .08 | \$ | 699 | 739 | 784 | 823 | 868 | 919 | 964 | 1015 | 1060 | 1105 | 1156 | 1201 | | |
| .09 | \$ | 749 | 789 | 835 | 886 | 934 | 984 | 1030 | 1080 | 1125 | 1171 | 1217 | 1266 | | |
| .10 | \$ | 799 | 839 | 886 | 934 | 984 | 1030 | 1080 | 1125 | 1171 | 1217 | 1266 | 1316 | | |
| .12 | \$ | 899 | 947 | 993 | 1043 | 1094 | 1145 | 1196 | 1247 | 1298 | 1349 | 1391 | 1436 | | |
| .14 | \$ | 999 | 1047 | 1093 | 1143 | 1194 | 1245 | 1296 | 1347 | 1398 | 1449 | 1491 | 1546 | BALANCE POINT 36 DEG.F. | |
| .16 | \$ | 1099 | 1147 | 1193 | 1243 | 1294 | 1345 | 1396 | 1447 | 1498 | 1549 | 1591 | 1646 | | |

ANNUAL AIR CONDITIONING COST WHEN COOLING LOAD IS SIZED TO MATCH COOLING CAPACITY OF HEAT PUMP

| | .05 | .06 | .07 | .08 | .09 | .10 | .12 | .14 | .16 | |
|----|-----|-----|-----|-----|-----|-----|-----|-----|-----|--------------------------------------|
| \$ | 99 | 118 | 138 | 158 | 178 | 198 | 237 | 277 | 317 | --- |
| | | | | | | | | | | ---ELECTRIC RATE \$/KWH |
| | | | | | | | | | | ---THEORETICAL AIR CONDITIONING COST |

THE ABOVE ANNUAL HEATING AND COOLING OPERATING COSTS ARE THEORETICAL ESTIMATES ONLY AND ARE PROVIDED FOR A COMMON BASIS OF COMPARISON BETWEEN VARIOUS TYPES OF HEATING AND COOLING SYSTEMS. ACTUAL VALUES MAY VARY DEPENDING ON ACTUAL WEATHER CONDITIONS AND INDIVIDUAL USAGE PATTERN.

BARO MANUFACTURING COMPANY
DUAL FUEL ADD-ON HEAT PUMP GUIDE TO ENERGY COST SAVINGS

REGION 4
 HEAT PUMP MODEL: OUTDOOR 24URPQA 24URPQA/A30A0-A INDOOR A30A0-A
 RATED COOLING CAP.: BTU/H (95) 24000 SEER 9.63
 RATED HEATING CAP.: BTU/H (47) 24000 COP(47) 2.90 HSPF 6.40 MIN. OHR REG IV
 BTU/H (17) 12500 COP(17) 1.80
 FURNACE TYPE PROPANE GAS FURNACE EFFICIENCY 78.00 % AEU8

| HEAT LOSS BTU/H | ELEC. COST \$/KWH | PROPANE GAS COST - \$/GALLON | | | | | | | | | | | | |
|-----------------|-------------------|------------------------------|------|------|------|------|------|------|------|------|------|------|------|--|
| | | .60 | .65 | .70 | .75 | .80 | .85 | .90 | .95 | 1.00 | 1.10 | 1.20 | | 1.20 |
| 25,000 | | \$ 361 | 394 | 423 | 457 | 485 | 513 | 547 | 575 | 609 | 665 | 727 | 727 | <---THEORETICAL HEATING COST * FURNACE ONLY |
| | .05 | \$ 315 | 321 | 327 | 332 | 338 | 344 | 349 | 355 | 361 | 372 | 383 | 383 | THEORETICAL HEATING COST * FURN. + HEAT PUMP \$ PER YEAR |
| | .06 | 366 | 374 | 378 | 383 | 389 | 394 | 400 | 406 | 411 | 423 | 434 | 434 | |
| | .07 | 417 | 428 | 433 | 438 | 444 | 449 | 455 | 461 | 467 | 480 | 491 | 491 | |
| | .08 | 468 | 482 | 487 | 492 | 498 | 503 | 509 | 515 | 521 | 535 | 546 | 546 | |
| | .09 | 519 | 535 | 540 | 545 | 551 | 556 | 562 | 568 | 574 | 590 | 601 | 601 | |
| | .10 | 570 | 588 | 593 | 598 | 604 | 610 | 616 | 622 | 628 | 645 | 656 | 656 | |
| | .12 | 621 | 641 | 646 | 651 | 657 | 663 | 669 | 675 | 681 | 700 | 711 | 711 | |
| | .14 | 672 | 694 | 699 | 704 | 710 | 716 | 722 | 728 | 734 | 754 | 765 | 765 | |
| | .16 | 723 | 747 | 752 | 757 | 763 | 769 | 775 | 781 | 787 | 808 | 819 | 819 | BALANCE POINT 21 DEG.F. |
| 30,000 | | \$ 434 | 473 | 507 | 547 | 581 | 620 | 654 | 694 | 727 | 801 | 874 | 874 | <---THEORETICAL HEATING COST * FURNACE ONLY |
| | .05 | \$ 378 | 389 | 400 | 411 | 423 | 434 | 445 | 451 | 462 | 485 | 502 | 502 | THEORETICAL HEATING COST * FURN. + HEAT PUMP \$ PER YEAR |
| | .06 | 428 | 440 | 451 | 462 | 473 | 484 | 490 | 497 | 503 | 526 | 552 | 552 | |
| | .07 | 479 | 490 | 502 | 513 | 524 | 530 | 541 | 547 | 554 | 578 | 603 | 603 | |
| | .08 | 530 | 541 | 552 | 564 | 575 | 581 | 592 | 603 | 615 | 637 | 654 | 654 | |
| | .09 | 581 | 592 | 603 | 615 | 626 | 631 | 643 | 654 | 665 | 688 | 705 | 705 | |
| | .10 | 631 | 642 | 654 | 665 | 676 | 682 | 694 | 705 | 716 | 739 | 756 | 756 | |
| | .12 | 682 | 704 | 709 | 714 | 720 | 726 | 732 | 738 | 744 | 765 | 782 | 782 | |
| | .14 | 733 | 756 | 761 | 766 | 772 | 778 | 784 | 790 | 796 | 817 | 834 | 834 | |
| | .16 | 784 | 808 | 813 | 818 | 824 | 830 | 836 | 842 | 848 | 869 | 886 | 886 | BALANCE POINT 25 DEG.F. |
| 35,000 | | \$ 507 | 552 | 592 | 637 | 682 | 722 | 767 | 806 | 852 | 936 | 1021 | 1021 | <---THEORETICAL HEATING COST * FURNACE ONLY |
| | .05 | \$ 445 | 468 | 485 | 502 | 519 | 536 | 558 | 575 | 592 | 626 | 665 | 665 | THEORETICAL HEATING COST * FURN. + HEAT PUMP \$ PER YEAR |
| | .06 | 496 | 519 | 530 | 541 | 552 | 564 | 575 | 586 | 607 | 641 | 680 | 680 | |
| | .07 | 547 | 560 | 571 | 582 | 593 | 604 | 615 | 626 | 637 | 671 | 710 | 710 | |
| | .08 | 598 | 611 | 622 | 633 | 644 | 655 | 666 | 677 | 688 | 722 | 756 | 756 | |
| | .09 | 649 | 662 | 673 | 684 | 695 | 706 | 717 | 728 | 739 | 773 | 807 | 807 | |
| | .10 | 700 | 713 | 724 | 735 | 746 | 757 | 768 | 779 | 790 | 824 | 858 | 858 | |
| | .12 | 751 | 764 | 775 | 786 | 797 | 808 | 819 | 830 | 841 | 875 | 909 | 909 | |
| | .14 | 802 | 815 | 826 | 837 | 848 | 859 | 870 | 881 | 892 | 926 | 960 | 960 | |
| | .16 | 853 | 866 | 877 | 888 | 899 | 910 | 921 | 932 | 943 | 977 | 1011 | 1011 | BALANCE POINT 29 DEG.F. |
| 40,000 | | \$ 581 | 631 | 682 | 727 | 778 | 829 | 874 | 925 | 976 | 1072 | 1168 | 1168 | <---THEORETICAL HEATING COST * FURNACE ONLY |
| | .05 | \$ 507 | 530 | 547 | 569 | 592 | 609 | 631 | 654 | 671 | 710 | 756 | 756 | THEORETICAL HEATING COST * FURN. + HEAT PUMP \$ PER YEAR |
| | .06 | 558 | 581 | 598 | 620 | 643 | 660 | 682 | 705 | 722 | 761 | 806 | 806 | |
| | .07 | 609 | 631 | 648 | 671 | 694 | 710 | 733 | 756 | 773 | 812 | 857 | 857 | |
| | .08 | 660 | 682 | 699 | 722 | 744 | 761 | 784 | 806 | 823 | 863 | 908 | 908 | |
| | .09 | 711 | 733 | 750 | 773 | 795 | 812 | 835 | 857 | 874 | 914 | 959 | 959 | |
| | .10 | 762 | 784 | 801 | 823 | 845 | 863 | 885 | 908 | 925 | 964 | 1010 | 1010 | |
| | .12 | 813 | 835 | 852 | 874 | 896 | 910 | 933 | 955 | 972 | 1011 | 1117 | 1117 | |
| | .14 | 864 | 886 | 903 | 925 | 947 | 965 | 983 | 1001 | 1019 | 1058 | 1163 | 1163 | |
| | .16 | 915 | 937 | 954 | 976 | 998 | 1020 | 1042 | 1064 | 1086 | 1125 | 1230 | 1230 | BALANCE POINT 31 DEG.F. |
| 50,000 | | \$ 727 | 789 | 852 | 914 | 976 | 1032 | 1094 | 1156 | 1218 | 1337 | 1461 | 1461 | <---THEORETICAL HEATING COST * FURNACE ONLY |
| | .05 | \$ 648 | 688 | 722 | 761 | 795 | 835 | 868 | 908 | 942 | 1015 | 1089 | 1089 | THEORETICAL HEATING COST * FURN. + HEAT PUMP \$ PER YEAR |
| | .06 | 699 | 733 | 767 | 806 | 840 | 880 | 914 | 953 | 987 | 1060 | 1134 | 1134 | |
| | .07 | 750 | 778 | 812 | 852 | 885 | 925 | 959 | 998 | 1032 | 1105 | 1179 | 1179 | |
| | .08 | 801 | 835 | 869 | 909 | 942 | 981 | 1015 | 1054 | 1088 | 1161 | 1235 | 1235 | |
| | .09 | 852 | 886 | 920 | 960 | 993 | 1032 | 1071 | 1110 | 1144 | 1217 | 1291 | 1291 | |
| | .10 | 903 | 937 | 971 | 1011 | 1044 | 1083 | 1122 | 1161 | 1195 | 1268 | 1342 | 1342 | |
| | .12 | 954 | 988 | 1022 | 1062 | 1095 | 1134 | 1173 | 1212 | 1246 | 1319 | 1393 | 1393 | |
| | .14 | 1005 | 1039 | 1073 | 1113 | 1146 | 1185 | 1224 | 1263 | 1297 | 1370 | 1444 | 1444 | |
| | .16 | 1056 | 1090 | 1124 | 1164 | 1197 | 1236 | 1275 | 1314 | 1348 | 1421 | 1495 | 1495 | BALANCE POINT 36 DEG.F. |

ANNUAL AIR CONDITIONING COST WHEN COOLING LOAD IS SIZED TO MATCH COOLING CAPACITY OF HEAT PUMP

| | .05 | .06 | .07 | .08 | .09 | .10 | .12 | .14 | .16 | |
|----|-----|-----|-----|-----|-----|-----|-----|-----|-----|---------------------------------------|
| \$ | 99 | 118 | 138 | 158 | 178 | 198 | 237 | 277 | 317 | <---ELECTRIC RATE \$/KWH |
| | | | | | | | | | | <---THEORETICAL AIR CONDITIONING COST |

THE ABOVE ANNUAL HEATING AND COOLING OPERATING COSTS ARE THEORETICAL ESTIMATES ONLY AND ARE PROVIDED FOR A COMMON BASIS OF COMPARISON BETWEEN VARIOUS TYPES OF HEATING AND COOLING SYSTEMS. ACTUAL VALUES MAY VARY DEPENDING ON ACTUAL WEATHER CONDITIONS AND INDIVIDUAL USAGE PATTERN.

BARD MANUFACTURING COMPANY

DUAL FUEL ADD-ON HEAT PUMP GUIDE TO ENERGY COST SAVINGS

REGION 4
 HEAT PUMP MODEL: 24URPFB/A3640-A
 OUTDOOR 24URPFB INDOOR A3640-A
 RATED COOLING CAP.: 6700 (95) 24000 SEER10.50
 RATED HEATING CAP.: 6700 (47) 28200 COP(47) 3.10, HSPF 7.50 MIN. DR. REG IV
 FURNACE TYPE ELECTRIC FURNACE EFFICIENCY 100.00 X AFUE

HEAT LOSS BTUH
 ELEC. COST \$/KWH

25,000

--- THEORETICAL ANNUAL HEATING COST ---
 HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

| | | |
|-----|-----|------|
| .05 | 293 | 631 |
| .06 | 349 | 756 |
| .07 | 406 | 885 |
| .08 | 462 | 1010 |
| .09 | 524 | 1139 |
| .10 | 586 | 1273 |
| .11 | 652 | 1411 |
| .12 | 718 | 1554 |
| .14 | 818 | 1771 |
| .16 | 936 | 2025 |

BALANCE POINT 19 DEG.F.

30,000

--- THEORETICAL ANNUAL HEATING COST ---
 HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

| | | |
|-----|------|------|
| .05 | 355 | 756 |
| .06 | 428 | 908 |
| .07 | 507 | 1060 |
| .08 | 594 | 1213 |
| .09 | 643 | 1365 |
| .10 | 716 | 1517 |
| .11 | 798 | 1672 |
| .12 | 857 | 1822 |
| .14 | 998 | 2127 |
| .16 | 1139 | 2431 |

BALANCE POINT 24 DEG.F.

35,000

--- THEORETICAL ANNUAL HEATING COST ---
 HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

| | | |
|-----|------|------|
| .05 | 428 | 885 |
| .06 | 513 | 1060 |
| .07 | 603 | 1241 |
| .08 | 682 | 1416 |
| .09 | 773 | 1596 |
| .10 | 857 | 1771 |
| .11 | 932 | 1947 |
| .12 | 1002 | 2127 |
| .14 | 1201 | 2482 |
| .16 | 1371 | 2838 |

BALANCE POINT 27 DEG.F.

40,000

--- THEORETICAL ANNUAL HEATING COST ---
 HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

| | | |
|-----|------|------|
| .05 | 507 | 1010 |
| .06 | 609 | 1213 |
| .07 | 710 | 1416 |
| .08 | 812 | 1619 |
| .09 | 914 | 1822 |
| .10 | 1021 | 2025 |
| .11 | 1128 | 2231 |
| .12 | 1241 | 2431 |
| .14 | 1471 | 2838 |
| .16 | 1625 | 3244 |

BALANCE POINT 31 DEG.F.

50,000

--- THEORETICAL ANNUAL HEATING COST ---
 HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

| | | |
|-----|------|------|
| .05 | 688 | 1241 |
| .06 | 829 | 1517 |
| .07 | 964 | 1771 |
| .08 | 1105 | 2025 |
| .09 | 1241 | 2279 |
| .10 | 1382 | 2533 |
| .11 | 1523 | 2787 |
| .12 | 1652 | 3041 |
| .14 | 1932 | 3549 |
| .16 | 2206 | 4057 |

BALANCE POINT 36 DEG.F.

ANNUAL AIR CONDITIONING COST WHEN COOLING LOAD IS SIZED TO MATCH COOLING CAPACITY OF HEAT PUMP

| | | | | | | | | | | |
|----|-----|-----|-----|-----|-----|-----|-----|-----|-----|--|
| | .05 | .06 | .07 | .08 | .09 | .10 | .12 | .14 | .16 | |
| \$ | 87 | 105 | 122 | 140 | 157 | 175 | 210 | 245 | 280 | |

<-- ELECTRIC RATE \$/KWH
 <-- THEORETICAL AIR CONDITIONING COST

THE ABOVE ANNUAL HEATING AND COOLING OPERATING COSTS ARE THEORETICAL ESTIMATES ONLY AND ARE PROVIDED FOR A COMMON BASIS OF COMPARISON BETWEEN VARIOUS TYPES OF HEATING AND COOLING SYSTEMS. ACTUAL VALUES MAY VARY DEPENDING ON ACTUAL WEATHER CONDITIONS AND INDIVIDUAL USAGE PATTERN.

BARD MANUFACTURING COMPANY

DUAL FUEL ADD-ON HEAT PUMP GUIDE TO ENERGY COST SAVINGS

REGION 4
 HEAT PUMP MODEL: OUTDOOR 24HRPCB 240RPCB/A36AQ-A INDOOR A36AQ-A
 ARI RATED COOLING CAP.: BTUH (95) 24000 SEER 10.50
 ARI RATED HEATING CAP.: BTUH (47) 23600 COP (47) 3.10 HSPF 7.50 MIN. DHR REG IV
 FURNACE TYPE NATURAL GAS FURNACE EFFICIENCY 78.00 % AFUE

| HEAT LOSS BTUH | ELEC. COST \$/KWH | NATURAL GAS COST - \$/THERM | | | | | | | | | | | | |
|----------------|-------------------|-----------------------------|-----|-----|-----|-----|-----|------|------|------|------|------|------|--|
| | | .35 | .40 | .45 | .50 | .55 | .60 | .65 | .70 | .75 | .80 | .90 | | 1.00 |
| 25,000 | \$ | 191 | 220 | 248 | 276 | 304 | 332 | 355 | 383 | 411 | 440 | 496 | 552 | <--THEORETICAL HEATING COST * FURNACE ONLY |
| | | 248 | 253 | 259 | 265 | 270 | 276 | 282 | 287 | 293 | 299 | 304 | 315 | THEORETICAL HEATING COST * FURN. + HEAT PUMP |
| | | 293 | 303 | 309 | 310 | 315 | 321 | 327 | 332 | 338 | 344 | 349 | 361 | \$ PER YEAR |
| | | 332 | 338 | 344 | 349 | 355 | 361 | 366 | 372 | 378 | 383 | 389 | 400 | |
| | | 378 | 383 | 389 | 394 | 400 | 406 | 411 | 417 | 423 | 428 | 434 | 445 | |
| | | 423 | 428 | 434 | 440 | 445 | 451 | 457 | 462 | 468 | 473 | 479 | 490 | |
| | | 468 | 473 | 479 | 485 | 490 | 496 | 502 | 507 | 513 | 519 | 524 | 530 | |
| | | 513 | 519 | 524 | 530 | 536 | 541 | 547 | 552 | 558 | 563 | 569 | 575 | |
| | | 558 | 563 | 569 | 575 | 581 | 586 | 592 | 597 | 603 | 609 | 615 | 621 | |
| | | 603 | 609 | 615 | 621 | 626 | 631 | 637 | 643 | 648 | 654 | 660 | 665 | |
| | | 648 | 654 | 660 | 665 | 671 | 677 | 682 | 688 | 694 | 699 | 705 | 711 | BALANCE POINT 19 DEG.F. |
| | | 705 | 711 | 717 | 722 | 728 | 733 | 739 | 744 | 750 | 756 | 761 | 767 | |
| | | 744 | 750 | 756 | 761 | 767 | 773 | 778 | 784 | 789 | 795 | 801 | 806 | |
| 30,000 | \$ | 231 | 265 | 299 | 332 | 361 | 394 | 428 | 462 | 496 | 530 | 598 | 665 | <--THEORETICAL HEATING COST * FURNACE ONLY |
| | | 287 | 293 | 304 | 315 | 321 | 332 | 344 | 355 | 361 | 372 | 389 | 411 | THEORETICAL HEATING COST * FURN. + HEAT PUMP |
| | | 332 | 338 | 344 | 349 | 355 | 361 | 366 | 372 | 378 | 383 | 389 | 400 | \$ PER YEAR |
| | | 378 | 383 | 389 | 394 | 400 | 406 | 411 | 417 | 423 | 428 | 434 | 445 | |
| | | 417 | 423 | 428 | 434 | 440 | 445 | 451 | 457 | 462 | 468 | 473 | 479 | |
| | | 468 | 473 | 479 | 485 | 490 | 496 | 502 | 507 | 513 | 519 | 524 | 530 | |
| | | 513 | 519 | 524 | 530 | 536 | 541 | 547 | 552 | 558 | 563 | 569 | 575 | |
| | | 558 | 563 | 569 | 575 | 581 | 586 | 592 | 597 | 603 | 609 | 615 | 621 | |
| | | 603 | 609 | 615 | 621 | 626 | 631 | 637 | 643 | 648 | 654 | 660 | 665 | |
| | | 648 | 654 | 660 | 665 | 671 | 677 | 682 | 688 | 694 | 699 | 705 | 711 | BALANCE POINT 24 DEG.F. |
| | | 705 | 711 | 717 | 722 | 728 | 733 | 739 | 744 | 750 | 756 | 761 | 767 | |
| | | 744 | 750 | 756 | 761 | 767 | 773 | 778 | 784 | 789 | 795 | 801 | 806 | |
| | | 789 | 795 | 801 | 806 | 812 | 817 | 823 | 829 | 834 | 840 | 846 | 852 | |
| 35,000 | \$ | 270 | 310 | 344 | 383 | 423 | 462 | 502 | 541 | 581 | 620 | 694 | 773 | <--THEORETICAL HEATING COST * FURNACE ONLY |
| | | 315 | 332 | 349 | 366 | 383 | 400 | 417 | 434 | 451 | 468 | 496 | 530 | THEORETICAL HEATING COST * FURN. + HEAT PUMP |
| | | 355 | 372 | 389 | 406 | 423 | 440 | 457 | 473 | 490 | 507 | 536 | 569 | \$ PER YEAR |
| | | 394 | 411 | 428 | 445 | 462 | 479 | 496 | 513 | 530 | 547 | 575 | 609 | |
| | | 434 | 451 | 468 | 485 | 502 | 519 | 536 | 552 | 569 | 586 | 615 | 648 | |
| | | 473 | 490 | 507 | 524 | 541 | 558 | 575 | 592 | 609 | 626 | 654 | 688 | |
| | | 513 | 530 | 547 | 564 | 581 | 598 | 615 | 631 | 648 | 665 | 694 | 727 | |
| | | 552 | 569 | 586 | 603 | 620 | 637 | 654 | 671 | 688 | 705 | 734 | 767 | |
| | | 591 | 609 | 626 | 643 | 660 | 677 | 694 | 710 | 727 | 744 | 773 | 806 | |
| | | 630 | 648 | 665 | 682 | 699 | 716 | 733 | 750 | 767 | 784 | 813 | 846 | |
| | | 669 | 688 | 705 | 722 | 739 | 756 | 773 | 790 | 807 | 824 | 853 | 886 | |
| | | 708 | 727 | 744 | 761 | 778 | 795 | 812 | 829 | 846 | 863 | 892 | 925 | BALANCE POINT 27 DEG.F. |
| | | 747 | 766 | 784 | 801 | 818 | 835 | 852 | 869 | 886 | 903 | 932 | 965 | |
| | | 786 | 805 | 823 | 840 | 857 | 874 | 891 | 908 | 925 | 942 | 971 | 1004 | |
| 40,000 | \$ | 310 | 349 | 394 | 440 | 485 | 530 | 575 | 620 | 665 | 705 | 795 | 885 | <--THEORETICAL HEATING COST * FURNACE ONLY |
| | | 355 | 378 | 394 | 411 | 434 | 451 | 468 | 490 | 507 | 524 | 564 | 603 | THEORETICAL HEATING COST * FURN. + HEAT PUMP |
| | | 400 | 423 | 440 | 457 | 479 | 496 | 513 | 530 | 547 | 564 | 609 | 648 | \$ PER YEAR |
| | | 445 | 468 | 485 | 502 | 524 | 541 | 558 | 575 | 592 | 609 | 654 | 694 | |
| | | 485 | 513 | 530 | 547 | 564 | 581 | 598 | 615 | 631 | 648 | 694 | 734 | |
| | | 524 | 541 | 558 | 575 | 592 | 609 | 626 | 643 | 660 | 677 | 722 | 762 | |
| | | 563 | 581 | 598 | 615 | 631 | 648 | 665 | 682 | 699 | 716 | 761 | 801 | |
| | | 603 | 620 | 637 | 654 | 671 | 688 | 705 | 722 | 739 | 756 | 801 | 841 | |
| | | 642 | 660 | 677 | 694 | 710 | 727 | 744 | 761 | 778 | 795 | 840 | 880 | |
| | | 681 | 699 | 716 | 733 | 750 | 767 | 784 | 801 | 818 | 835 | 880 | 919 | |
| | | 720 | 738 | 755 | 772 | 789 | 806 | 823 | 840 | 857 | 874 | 919 | 958 | |
| | | 759 | 777 | 794 | 811 | 828 | 845 | 862 | 879 | 896 | 913 | 958 | 997 | BALANCE POINT 31 DEG.F. |
| | | 798 | 816 | 833 | 850 | 867 | 884 | 901 | 918 | 935 | 952 | 997 | 1036 | |
| | | 837 | 855 | 872 | 889 | 906 | 923 | 940 | 957 | 974 | 991 | 1036 | 1075 | |
| 50,000 | \$ | 383 | 440 | 496 | 552 | 609 | 665 | 716 | 773 | 829 | 885 | 998 | 1105 | <--THEORETICAL HEATING COST * FURNACE ONLY |
| | | 417 | 451 | 485 | 519 | 552 | 581 | 615 | 648 | 682 | 716 | 784 | 846 | THEORETICAL HEATING COST * FURN. + HEAT PUMP |
| | | 457 | 490 | 524 | 558 | 592 | 620 | 654 | 688 | 722 | 756 | 823 | 885 | \$ PER YEAR |
| | | 496 | 530 | 564 | 598 | 631 | 660 | 694 | 727 | 761 | 795 | 863 | 925 | |
| | | 536 | 569 | 603 | 637 | 671 | 705 | 739 | 773 | 807 | 841 | 909 | 971 | |
| | | 575 | 609 | 643 | 677 | 710 | 744 | 778 | 812 | 846 | 880 | 948 | 1010 | |
| | | 614 | 648 | 682 | 716 | 750 | 784 | 818 | 852 | 886 | 920 | 988 | 1050 | |
| | | 653 | 687 | 721 | 755 | 789 | 823 | 857 | 891 | 925 | 959 | 1027 | 1089 | |
| | | 692 | 726 | 760 | 794 | 828 | 862 | 896 | 930 | 964 | 998 | 1066 | 1128 | |
| | | 731 | 765 | 799 | 833 | 867 | 901 | 935 | 969 | 1003 | 1037 | 1105 | 1167 | BALANCE POINT 36 DEG.F. |
| | | 770 | 804 | 838 | 872 | 906 | 940 | 974 | 1008 | 1042 | 1076 | 1144 | 1206 | |
| | | 809 | 843 | 877 | 911 | 945 | 979 | 1013 | 1047 | 1081 | 1115 | 1183 | 1245 | |

ANNUAL AIR CONDITIONING COST WHEN COOLING LOAD IS SIZED TO MATCH COOLING CAPACITY OF HEAT PUMP
 \$.05 .06 .07 .08 .09 .10 .12 .14 .16
 87 105 122 140 157 175 210 245 280
 <--ELECTRIC RATE \$/KWH
 <--THEORETICAL AIR CONDITIONING COST

THE ABOVE ANNUAL HEATING AND COOLING OPERATING COSTS ARE THEORETICAL ESTIMATES ONLY AND ARE PROVIDED FOR A COMMON BASIS OF COMPARISON BETWEEN VARIOUS TYPES OF HEATING AND COOLING SYSTEMS. ACTUAL VALUES MAY VARY DEPENDING ON ACTUAL WEATHER CONDITIONS AND INDIVIDUAL USAGE PATTERN.

BARD MANUFACTURING COMPANY

DUAL FUEL ADD-ON HEAT PUMP GUIDE TO ENERGY COST SAVINGS

REGION 4
 HEAT PUMP MODEL: OUTDOOR 24URP08 24URP08/A36AG-A INDOOR A36AG-A
 ARI RATED COOLING CAP.: BTUH (95) 43000 SEER10.50
 ARI RATED HEATING CAP.: BTUH (47) 23600 COP(47) 3.10 HSPF 1.50 MIN.DHR REG IV
 FURNACE TYPE FURN. OIL FURNACE EFFICIENCY 78.00 % A/E/V

| HEAT LOSS BTUH | HEAT COST \$/KWH | HEATING OIL COST - \$/GALLON | | | | | | | | | | | | | |
|-------------------|---------------------|------------------------------|-----|------|------|------|------|------|------|------|------|------|------|---|---|
| | | .70 | .80 | .90 | 1.00 | 1.10 | 1.20 | 1.30 | 1.40 | 1.50 | 1.60 | 1.70 | 1.80 | | |
| 25,000 | \$ | 276 | 315 | 355 | 394 | 440 | 479 | 519 | 558 | 598 | 637 | 677 | 716 | <--THEORETICAL HEATING COST * FURNACE ONLY | |
| .05 | \$ | 265 | 276 | 282 | 287 | 299 | 304 | 310 | 315 | 327 | 332 | 338 | 349 | THEORETICAL HEATING COST * FURN. + HEAT PUMP \$ PER YEAR | |
| .06 | \$ | 310 | 321 | 327 | 332 | 344 | 349 | 355 | 361 | 372 | 378 | 383 | 394 | | |
| .07 | \$ | 349 | 361 | 366 | 372 | 383 | 389 | 394 | 400 | 411 | 417 | 423 | 434 | | |
| .08 | \$ | 394 | 406 | 411 | 417 | 428 | 434 | 440 | 445 | 457 | 462 | 468 | 479 | | |
| .09 | \$ | 440 | 451 | 457 | 462 | 473 | 479 | 485 | 490 | 502 | 507 | 513 | 524 | | |
| .10 | \$ | 479 | 490 | 496 | 502 | 513 | 519 | 524 | 530 | 541 | 547 | 552 | 564 | | |
| .12 | \$ | 564 | 575 | 581 | 586 | 598 | 603 | 609 | 615 | 626 | 631 | 637 | 648 | BALANCE POINT 19 DEG.F. | |
| .14 | \$ | 654 | 665 | 671 | 677 | 688 | 694 | 699 | 705 | 716 | 722 | 727 | 739 | | |
| .16 | \$ | 739 | 750 | 756 | 761 | 773 | 778 | 784 | 789 | 801 | 806 | 812 | 823 | | |
| 30,000 | \$ | 332 | 383 | 428 | 479 | 524 | 575 | 620 | 671 | 716 | 767 | 812 | 863 | | <--THEORETICAL HEATING COST * FURNACE ONLY |
| .05 | \$ | 315 | 327 | 344 | 355 | 372 | 383 | 400 | 411 | 423 | 440 | 451 | 468 | | THEORETICAL HEATING COST * FURN. + HEAT PUMP \$ PER YEAR |
| .06 | \$ | 361 | 372 | 389 | 400 | 417 | 428 | 445 | 457 | 468 | 485 | 496 | 513 | | |
| .07 | \$ | 406 | 417 | 434 | 445 | 462 | 473 | 490 | 502 | 513 | 530 | 541 | 558 | | |
| .08 | \$ | 445 | 457 | 473 | 485 | 502 | 513 | 530 | 541 | 557 | 569 | 581 | 598 | | |
| .09 | \$ | 490 | 502 | 519 | 530 | 547 | 558 | 575 | 586 | 598 | 615 | 626 | 643 | | |
| .10 | \$ | 536 | 547 | 564 | 575 | 592 | 603 | 620 | 631 | 643 | 660 | 671 | 688 | | |
| .12 | \$ | 626 | 637 | 654 | 665 | 682 | 694 | 710 | 722 | 733 | 750 | 761 | 778 | BALANCE POINT 24 DEG.F. | |
| .14 | \$ | 710 | 722 | 739 | 750 | 767 | 778 | 795 | 806 | 818 | 835 | 846 | 863 | | |
| .16 | \$ | 801 | 812 | 829 | 840 | 857 | 868 | 885 | 897 | 908 | 925 | 936 | 953 | | |
| 35,000 | \$ | 389 | 445 | 502 | 558 | 615 | 671 | 727 | 784 | 835 | 891 | 947 | 1004 | | <--THEORETICAL HEATING COST * FURNACE ONLY |
| .05 | \$ | 366 | 394 | 417 | 440 | 462 | 485 | 513 | 536 | 558 | 581 | 603 | 631 | | THEORETICAL HEATING COST * FURN. + HEAT PUMP \$ PER YEAR |
| .06 | \$ | 406 | 434 | 457 | 479 | 502 | 524 | 552 | 575 | 598 | 620 | 643 | 671 | | |
| .07 | \$ | 445 | 473 | 496 | 519 | 541 | 564 | 592 | 615 | 637 | 660 | 682 | 710 | | |
| .08 | \$ | 485 | 513 | 536 | 558 | 581 | 603 | 631 | 654 | 677 | 699 | 722 | 750 | | |
| .09 | \$ | 524 | 552 | 575 | 598 | 620 | 643 | 671 | 694 | 716 | 739 | 761 | 789 | | |
| .10 | \$ | 564 | 592 | 615 | 637 | 660 | 682 | 710 | 733 | 756 | 778 | 801 | 829 | | |
| .12 | \$ | 643 | 671 | 694 | 716 | 739 | 761 | 789 | 812 | 835 | 857 | 880 | 908 | BALANCE POINT 27 DEG.F. | |
| .14 | \$ | 727 | 750 | 773 | 795 | 818 | 846 | 874 | 897 | 919 | 942 | 964 | 993 | | |
| .16 | \$ | 806 | 835 | 857 | 880 | 902 | 925 | 953 | 976 | 998 | 1021 | 1043 | 1072 | | |
| 40,000 | \$ | 445 | 507 | 575 | 637 | 699 | 767 | 829 | 891 | 959 | 1021 | 1083 | 1151 | | <--THEORETICAL HEATING COST * FURNACE ONLY |
| .05 | \$ | 417 | 440 | 468 | 496 | 524 | 552 | 575 | 603 | 631 | 660 | 688 | 710 | | THEORETICAL HEATING COST * FURN. + HEAT PUMP \$ PER YEAR |
| .06 | \$ | 462 | 485 | 513 | 541 | 569 | 598 | 620 | 648 | 677 | 705 | 733 | 756 | | |
| .07 | \$ | 507 | 530 | 558 | 586 | 615 | 643 | 665 | 694 | 722 | 750 | 778 | 801 | | |
| .08 | \$ | 552 | 575 | 603 | 631 | 660 | 688 | 710 | 739 | 767 | 795 | 823 | 846 | | |
| .09 | \$ | 598 | 620 | 648 | 677 | 705 | 733 | 756 | 784 | 812 | 840 | 868 | 891 | | |
| .10 | \$ | 643 | 665 | 694 | 722 | 750 | 778 | 801 | 829 | 857 | 885 | 914 | 936 | | |
| .12 | \$ | 710 | 739 | 767 | 795 | 823 | 846 | 874 | 897 | 919 | 942 | 1004 | 1036 | BALANCE POINT 31 DEG.F. | |
| .14 | \$ | 823 | 846 | 874 | 902 | 931 | 959 | 981 | 1010 | 1038 | 1066 | 1094 | 1117 | | |
| .16 | \$ | 914 | 936 | 964 | 993 | 1021 | 1049 | 1072 | 1100 | 1128 | 1156 | 1184 | 1207 | | |
| 50,000 | \$ | 558 | 637 | 716 | 795 | 880 | 959 | 1038 | 1117 | 1196 | 1280 | 1359 | 1438 | | <--THEORETICAL HEATING COST * FURNACE ONLY |
| .05 | \$ | 519 | 549 | 615 | 665 | 710 | 761 | 806 | 857 | 902 | 947 | 998 | 1043 | | THEORETICAL HEATING COST * FURN. + HEAT PUMP \$ PER YEAR |
| .06 | \$ | 558 | 609 | 654 | 705 | 750 | 801 | 846 | 897 | 942 | 987 | 1038 | 1083 | | |
| .07 | \$ | 598 | 648 | 694 | 744 | 789 | 840 | 885 | 936 | 981 | 1026 | 1077 | 1122 | | |
| .08 | \$ | 637 | 688 | 733 | 784 | 829 | 880 | 925 | 976 | 1021 | 1066 | 1117 | 1162 | | |
| .09 | \$ | 677 | 727 | 772 | 818 | 863 | 914 | 959 | 1010 | 1055 | 1100 | 1151 | 1196 | | |
| .10 | \$ | 710 | 761 | 806 | 857 | 902 | 953 | 998 | 1049 | 1094 | 1139 | 1190 | 1235 | | |
| .12 | \$ | 784 | 835 | 880 | 931 | 976 | 1026 | 1072 | 1122 | 1168 | 1213 | 1263 | 1309 | BALANCE POINT 36 DEG.F. | |
| .14 | \$ | 863 | 914 | 959 | 1010 | 1055 | 1105 | 1151 | 1201 | 1247 | 1293 | 1342 | 1388 | | |
| .16 | \$ | 936 | 987 | 1032 | 1083 | 1128 | 1179 | 1224 | 1275 | 1320 | 1365 | 1416 | 1461 | | |

ANNUAL AIR CONDITIONING COST WHEN COOLING LOAD IS SIZED TO MATCH COOLING CAPACITY OF HEAT PUMP

| | .05 | .06 | .07 | .08 | .09 | .10 | .12 | .14 | .16 | |
|----|-----|-----|-----|-----|-----|-----|-----|-----|-----|--------------------------------------|
| \$ | 87 | 105 | 122 | 140 | 157 | 175 | 210 | 245 | 280 | <--ELECTRIC RATE \$/KWH |
| | | | | | | | | | | <--THEORETICAL AIR CONDITIONING COST |

THE ABOVE ANNUAL HEATING AND COOLING OPERATING COSTS ARE THEORETICAL ESTIMATES ONLY AND ARE PROVIDED FOR A COMMON BASIS OF COMPARISON BETWEEN VARIOUS TYPES OF HEATING AND COOLING SYSTEMS. ACTUAL VALUES MAY VARY DEPENDING ON ACTUAL WEATHER CONDITIONS AND INDIVIDUAL USAGE PATTERN.

BARD MANUFACTURING COMPANY

DUAL FUEL ADD-ON HEAT PUMP GUIDE TO ENERGY COST SAVINGS

REGION 4
 HEAT PUMP MODEL: OUTDOOR 24URP08 24URP08/A36AO-A INDOOR A36AO-A
 ARI RATED COOLING CAP.: BTUH (95) 23000 SEER10.50
 ARI RATED HEATING CAP.: BTUH (47) 23500 COP(47) 3.10 HSPF 7.50 MIN. DNR DEG IV
 FURNACE TYPE PROPANE GAS FURNACE EFFICIENCY 78.00 X AFUE

| HEAT LOSS BTUH | ELEC. COST \$/KWH | PROPANE GAS COST - \$/GALLON | | | | | | | | | | | | |
|----------------|-------------------|------------------------------|------|------|------|------|------|------|------|------|------|------|------|--|
| | | .60 | .65 | .70 | .75 | .80 | .85 | .90 | .95 | 1.00 | 1.10 | 1.20 | 1.20 | |
| 25,000 | \$ | 361 | 394 | 423 | 457 | 485 | 513 | 547 | 575 | 609 | 665 | 727 | 727 | <--THEORETICAL HEATING COST * FURNACE ONLY |
| .05 | \$ | 282 | 287 | 293 | 299 | 304 | 310 | 315 | 321 | 327 | 338 | 349 | 349 | THEORETICAL HEATING COST * FURN. + HEAT PUMP \$ PER YEAR |
| .06 | \$ | 329 | 335 | 341 | 347 | 353 | 359 | 365 | 371 | 377 | 388 | 394 | 394 | |
| .07 | \$ | 366 | 372 | 378 | 383 | 389 | 394 | 400 | 406 | 411 | 423 | 424 | 424 | |
| .08 | \$ | 411 | 417 | 423 | 428 | 434 | 440 | 445 | 451 | 457 | 468 | 474 | 474 | |
| .09 | \$ | 457 | 463 | 468 | 473 | 479 | 485 | 490 | 496 | 502 | 513 | 524 | 524 | |
| .10 | \$ | 496 | 502 | 507 | 513 | 519 | 524 | 530 | 536 | 541 | 552 | 564 | 564 | |
| .12 | \$ | 581 | 587 | 592 | 598 | 603 | 609 | 615 | 620 | 626 | 637 | 648 | 648 | |
| .14 | \$ | 671 | 677 | 682 | 688 | 694 | 699 | 705 | 710 | 716 | 727 | 739 | 739 | |
| .16 | \$ | 756 | 761 | 767 | 773 | 778 | 784 | 789 | 795 | 801 | 812 | 823 | 823 | BALANCE POINT 19 DEG.F. |
| 30,000 | \$ | 434 | 473 | 507 | 547 | 581 | 620 | 654 | 694 | 727 | 801 | 874 | 874 | <--THEORETICAL HEATING COST * FURNACE ONLY |
| .05 | \$ | 344 | 355 | 366 | 378 | 389 | 394 | 406 | 417 | 428 | 451 | 468 | 468 | THEORETICAL HEATING COST * FURN. + HEAT PUMP \$ PER YEAR |
| .06 | \$ | 400 | 405 | 411 | 417 | 423 | 429 | 435 | 441 | 447 | 458 | 468 | 468 | |
| .07 | \$ | 434 | 440 | 445 | 451 | 457 | 463 | 469 | 475 | 481 | 492 | 503 | 503 | |
| .08 | \$ | 473 | 479 | 485 | 490 | 496 | 502 | 507 | 513 | 519 | 530 | 541 | 541 | |
| .09 | \$ | 507 | 513 | 519 | 524 | 530 | 536 | 541 | 547 | 552 | 564 | 575 | 575 | |
| .10 | \$ | 547 | 552 | 558 | 564 | 569 | 575 | 581 | 587 | 592 | 603 | 614 | 614 | |
| .12 | \$ | 620 | 626 | 631 | 637 | 643 | 648 | 654 | 659 | 665 | 676 | 688 | 688 | |
| .14 | \$ | 705 | 710 | 716 | 722 | 727 | 733 | 739 | 744 | 750 | 761 | 772 | 772 | |
| .16 | \$ | 829 | 840 | 852 | 863 | 874 | 880 | 891 | 902 | 914 | 936 | 953 | 953 | BALANCE POINT 24 DEG.F. |
| 35,000 | \$ | 507 | 552 | 592 | 637 | 682 | 722 | 767 | 806 | 852 | 936 | 1021 | 1021 | <--THEORETICAL HEATING COST * FURNACE ONLY |
| .05 | \$ | 417 | 440 | 457 | 473 | 490 | 507 | 530 | 547 | 564 | 598 | 637 | 637 | THEORETICAL HEATING COST * FURN. + HEAT PUMP \$ PER YEAR |
| .06 | \$ | 457 | 479 | 496 | 513 | 530 | 547 | 569 | 586 | 603 | 637 | 677 | 677 | |
| .07 | \$ | 496 | 519 | 536 | 553 | 569 | 586 | 609 | 626 | 643 | 677 | 716 | 716 | |
| .08 | \$ | 536 | 558 | 575 | 592 | 609 | 626 | 648 | 665 | 682 | 716 | 755 | 755 | |
| .09 | \$ | 575 | 598 | 615 | 631 | 648 | 665 | 688 | 705 | 722 | 755 | 795 | 795 | |
| .10 | \$ | 615 | 637 | 654 | 671 | 688 | 705 | 727 | 744 | 761 | 795 | 835 | 835 | |
| .12 | \$ | 694 | 716 | 733 | 750 | 767 | 784 | 806 | 823 | 840 | 874 | 914 | 914 | |
| .14 | \$ | 778 | 801 | 818 | 835 | 852 | 868 | 891 | 908 | 925 | 959 | 998 | 998 | |
| .16 | \$ | 857 | 880 | 897 | 914 | 931 | 947 | 970 | 987 | 1004 | 1038 | 1077 | 1077 | BALANCE POINT 27 DEG.F. |
| 40,000 | \$ | 581 | 631 | 682 | 727 | 778 | 829 | 874 | 925 | 976 | 1072 | 1168 | 1168 | <--THEORETICAL HEATING COST * FURNACE ONLY |
| .05 | \$ | 473 | 496 | 513 | 536 | 558 | 575 | 598 | 620 | 637 | 677 | 722 | 722 | THEORETICAL HEATING COST * FURN. + HEAT PUMP \$ PER YEAR |
| .06 | \$ | 519 | 541 | 558 | 581 | 603 | 620 | 643 | 665 | 682 | 722 | 767 | 767 | |
| .07 | \$ | 558 | 586 | 603 | 626 | 648 | 665 | 688 | 710 | 727 | 767 | 812 | 812 | |
| .08 | \$ | 604 | 631 | 648 | 671 | 694 | 710 | 733 | 756 | 778 | 812 | 852 | 852 | |
| .09 | \$ | 654 | 677 | 694 | 716 | 739 | 756 | 778 | 801 | 818 | 857 | 902 | 902 | |
| .10 | \$ | 694 | 722 | 739 | 761 | 784 | 801 | 823 | 846 | 863 | 902 | 947 | 947 | |
| .12 | \$ | 789 | 812 | 829 | 852 | 874 | 891 | 914 | 936 | 953 | 993 | 1038 | 1038 | |
| .14 | \$ | 880 | 902 | 919 | 942 | 964 | 981 | 1004 | 1026 | 1043 | 1083 | 1128 | 1128 | |
| .16 | \$ | 970 | 993 | 1010 | 1032 | 1055 | 1072 | 1094 | 1117 | 1134 | 1173 | 1218 | 1218 | BALANCE POINT 31 DEG.F. |
| 50,000 | \$ | 727 | 789 | 852 | 914 | 976 | 1032 | 1094 | 1156 | 1218 | 1337 | 1461 | 1461 | <--THEORETICAL HEATING COST * FURNACE ONLY |
| .05 | \$ | 620 | 660 | 694 | 733 | 767 | 806 | 840 | 880 | 914 | 987 | 1060 | 1060 | THEORETICAL HEATING COST * FURN. + HEAT PUMP \$ PER YEAR |
| .06 | \$ | 660 | 699 | 733 | 773 | 806 | 846 | 880 | 919 | 953 | 1026 | 1100 | 1100 | |
| .07 | \$ | 699 | 739 | 773 | 812 | 845 | 885 | 919 | 959 | 993 | 1066 | 1139 | 1139 | |
| .08 | \$ | 739 | 778 | 812 | 852 | 885 | 925 | 959 | 998 | 1032 | 1105 | 1179 | 1179 | |
| .09 | \$ | 773 | 812 | 846 | 885 | 919 | 959 | 993 | 1032 | 1066 | 1139 | 1213 | 1213 | |
| .10 | \$ | 812 | 852 | 885 | 925 | 959 | 998 | 1032 | 1072 | 1105 | 1179 | 1252 | 1252 | |
| .12 | \$ | 885 | 925 | 959 | 998 | 1032 | 1072 | 1105 | 1145 | 1179 | 1252 | 1326 | 1326 | |
| .14 | \$ | 964 | 1004 | 1038 | 1077 | 1111 | 1151 | 1184 | 1224 | 1258 | 1331 | 1405 | 1405 | |
| .16 | \$ | 1038 | 1077 | 1111 | 1151 | 1184 | 1224 | 1258 | 1297 | 1331 | 1405 | 1478 | 1478 | BALANCE POINT 36 DEG.F. |

ANNUAL AIR CONDITIONING COST WHEN COOLING LOAD IS SIZED TO MATCH COOLING CAPACITY OF HEAT PUMP

| \$ | .05 | .06 | .07 | .08 | .09 | .10 | .12 | .14 | .16 | |
|----|-----|-----|-----|-----|-----|-----|-----|-----|-----|--------------------------------------|
| | 87 | 105 | 122 | 140 | 157 | 175 | 210 | 245 | 280 | <--ELECTRIC RATE \$/KWH |
| | | | | | | | | | | <--THEORETICAL AIR CONDITIONING COST |

THE ABOVE ANNUAL HEATING AND COOLING OPERATING COSTS ARE THEORETICAL ESTIMATES ONLY AND ARE PROVIDED FOR A COMMON BASIS OF COMPARISON BETWEEN VARIOUS TYPES OF HEATING AND COOLING SYSTEMS. ACTUAL VALUES MAY VARY DEPENDING ON ACTUAL WEATHER CONDITIONS AND INDIVIDUAL USAGE PATTERN.

BARD MANUFACTURING COMPANY
 DUAL FUEL ADD-ON HEAT PUMP GUIDE TO ENERGY COST SAVINGS

REGION 4
 HEAT PUMP MODEL: OUTDOOR COILS FOR 30HPOR/A36AO-A INDOOR A36AO-A
 RATED COOLING CAP.: BTUH (95) 28800 SEER 9.19
 RATED HEATING CAP.: BTUH (47) 28800 COP (47) 2.00 HSPF 6.90 MIN. DHR REG IV
 PURCHASE TYPE ELECTRIC PURCHASE EFFICIENCY 100.00 % ARIE

| HEAT LOSS BTUH | HEAT COST \$/KWH | --- THEORETICAL ANNUAL HEATING COST --- | |
|----------------|------------------|---|-------------------------|
| | | HEAT PUMP WITH ELECTRIC HEAT | ELECTRIC HEAT ONLY |
| 30,000 | | | |
| | .05 | 372 | 756 |
| | .06 | 451 | 908 |
| | .07 | 530 | 1060 |
| | .08 | 598 | 1213 |
| | .09 | 677 | 1365 |
| | .10 | 750 | 1517 |
| | .12 | 902 | 1822 |
| | .14 | 1049 | 2127 |
| | .16 | 1201 | 2431 |
| | | | BALANCE POINT 20 DEG.F. |
| 35,000 | | | |
| | .05 | 445 | 895 |
| | .06 | 530 | 1060 |
| | .07 | 620 | 1241 |
| | .08 | 710 | 1416 |
| | .09 | 795 | 1596 |
| | .10 | 885 | 1771 |
| | .12 | 1066 | 2127 |
| | .14 | 1241 | 2482 |
| | .16 | 1410 | 2838 |
| | | | BALANCE POINT 23 DEG.F. |
| 40,000 | | | |
| | .05 | 513 | 1010 |
| | .06 | 615 | 1213 |
| | .07 | 716 | 1416 |
| | .08 | 818 | 1619 |
| | .09 | 919 | 1822 |
| | .10 | 1026 | 2025 |
| | .12 | 1230 | 2431 |
| | .14 | 1438 | 2838 |
| | .16 | 1642 | 3244 |
| | | | BALANCE POINT 27 DEG.F. |
| 50,000 | | | |
| | .05 | 627 | 1263 |
| | .06 | 806 | 1517 |
| | .07 | 943 | 1771 |
| | .08 | 1077 | 2025 |
| | .09 | 1213 | 2279 |
| | .10 | 1348 | 2533 |
| | .12 | 1619 | 3041 |
| | .14 | 1890 | 3549 |
| | .16 | 2155 | 4057 |
| | | | BALANCE POINT 32 DEG.F. |
| 60,000 | | | |
| | .05 | 863 | 1517 |
| | .06 | 1033 | 1822 |
| | .07 | 1207 | 2127 |
| | .08 | 1376 | 2431 |
| | .09 | 1551 | 2736 |
| | .10 | 1721 | 3041 |
| | .12 | 2070 | 3650 |
| | .14 | 2409 | 4260 |
| | .16 | 2753 | 4869 |
| | | | BALANCE POINT 36 DEG.F. |

ANNUAL AIR CONDITIONING COST WHEN COOLING LOAD IS SIZED TO MATCH COOLING CAPACITY OF HEAT PUMP

| | .05 | .06 | .07 | .08 | .09 | .10 | .12 | .14 | .16 | |
|----|-----|-----|-----|-----|-----|-----|-----|-----|-----|---------------------------------------|
| \$ | 122 | 147 | 171 | 196 | 220 | 245 | 294 | 343 | 392 | <-- ELECTRIC RATE 5/KWH |
| | | | | | | | | | | <-- THEORETICAL AIR CONDITIONING COST |

THE ABOVE ANNUAL HEATING AND COOLING OPERATING COSTS ARE THEORETICAL ESTIMATES ONLY AND ARE PROVIDED FOR A COMMON BASIS OF COMPARISON BETWEEN VARIOUS TYPES OF HEATING AND COOLING SYSTEMS. ACTUAL VALUES MAY VARY DEPENDING ON ACTUAL WEATHER CONDITIONS AND INDIVIDUAL USAGE PATTERN.

BARD MANUFACTURING COMPANY
DUAL FUEL ADD-ON HEAT PUMP GUIDE TO ENERGY COST SAVINGS

REGION 4
 HEAT PUMP MODEL: OUTDOOR 30RHP08 30RHP09/A36AQ-A INDOOR A36AQ-A
 ARI RATED COOLING CAP.: BTUH (95) 28200 SEER 9.19
 ARI RATED HEATING CAP.: BTUH (47) 28000 COP (47) 3.00 HSPF 6.90 MIN. OHR REG IV
 FURNACE TYPE NATURAL GAS FURNACE EFFICIENCY 78.00 % AFUE

| HEAT LOSS BTUH | HEAT PUMP COST \$/KWH | NATURAL GAS COST - \$/THERM | | | | | | | | | | | | | |
|----------------|-----------------------|-----------------------------|------|------|------|------|------|------|------|------|------|------|------|--|--|
| | | .35 | .40 | .45 | .50 | .55 | .60 | .65 | .70 | .75 | .80 | .90 | | 1.00 | |
| 30,000 | \$ | 231 | 265 | 299 | 332 | 361 | 394 | 428 | 462 | 496 | 530 | 598 | 665 | ---THEORETICAL HEATING COST * FURNACE ONLY | |
| .05 | \$ | 327 | 332 | 338 | 344 | 349 | 355 | 361 | 366 | 372 | 383 | 394 | 406 | THEORETICAL HEATING COST * FURN. + HEAT PUMP \$ PER YEAR | |
| .06 | \$ | 383 | 389 | 394 | 400 | 406 | 411 | 417 | 423 | 428 | 440 | 451 | 462 | | |
| .07 | \$ | 434 | 440 | 445 | 451 | 457 | 462 | 468 | 473 | 479 | 490 | 502 | 513 | | |
| .08 | \$ | 490 | 496 | 502 | 507 | 513 | 519 | 524 | 530 | 536 | 547 | 558 | 569 | | |
| .09 | \$ | 547 | 552 | 558 | 564 | 569 | 575 | 581 | 586 | 592 | 603 | 615 | 626 | | |
| .10 | \$ | 603 | 609 | 615 | 620 | 626 | 631 | 637 | 643 | 648 | 660 | 671 | 682 | | |
| .12 | \$ | 716 | 722 | 727 | 733 | 739 | 744 | 750 | 756 | 761 | 773 | 784 | 795 | | |
| .14 | \$ | 829 | 835 | 840 | 846 | 852 | 857 | 863 | 868 | 874 | 885 | 897 | 908 | BALANCE POINT 20 DEG.F. | |
| .16 | \$ | 942 | 947 | 953 | 959 | 964 | 970 | 976 | 981 | 987 | 998 | 1010 | 1021 | | |
| 35,000 | \$ | 270 | 310 | 344 | 383 | 423 | 462 | 502 | 541 | 581 | 620 | 694 | 773 | ---THEORETICAL HEATING COST * FURNACE ONLY | |
| .05 | \$ | 361 | 372 | 383 | 394 | 406 | 417 | 423 | 434 | 445 | 457 | 479 | 502 | THEORETICAL HEATING COST * FURN. + HEAT PUMP \$ PER YEAR | |
| .06 | \$ | 411 | 428 | 440 | 451 | 462 | 473 | 479 | 490 | 502 | 513 | 524 | 536 | | |
| .07 | \$ | 468 | 479 | 490 | 502 | 513 | 524 | 530 | 541 | 552 | 564 | 575 | 586 | | |
| .08 | \$ | 524 | 536 | 547 | 558 | 569 | 581 | 586 | 598 | 609 | 620 | 643 | 665 | | |
| .09 | \$ | 581 | 592 | 603 | 615 | 626 | 637 | 643 | 654 | 665 | 677 | 699 | 722 | | |
| .10 | \$ | 637 | 648 | 660 | 671 | 682 | 694 | 699 | 710 | 722 | 733 | 756 | 778 | | |
| .12 | \$ | 750 | 761 | 773 | 784 | 795 | 806 | 812 | 823 | 835 | 846 | 868 | 891 | | |
| .14 | \$ | 863 | 874 | 885 | 897 | 908 | 919 | 925 | 936 | 947 | 959 | 981 | 1004 | BALANCE POINT 23 DEG.F. | |
| .16 | \$ | 976 | 987 | 998 | 1010 | 1021 | 1032 | 1038 | 1049 | 1060 | 1072 | 1094 | 1117 | | |
| 40,000 | \$ | 310 | 349 | 394 | 440 | 485 | 530 | 575 | 620 | 665 | 705 | 795 | 885 | ---THEORETICAL HEATING COST * FURNACE ONLY | |
| .05 | \$ | 383 | 406 | 423 | 440 | 462 | 479 | 496 | 519 | 536 | 552 | 592 | 631 | THEORETICAL HEATING COST * FURN. + HEAT PUMP \$ PER YEAR | |
| .06 | \$ | 434 | 457 | 473 | 490 | 513 | 530 | 547 | 569 | 586 | 603 | 643 | 682 | | |
| .07 | \$ | 485 | 507 | 524 | 541 | 564 | 581 | 598 | 620 | 637 | 654 | 694 | 733 | | |
| .08 | \$ | 530 | 552 | 569 | 586 | 609 | 626 | 643 | 665 | 682 | 699 | 739 | 778 | | |
| .09 | \$ | 581 | 603 | 620 | 637 | 660 | 677 | 694 | 716 | 733 | 750 | 789 | 829 | | |
| .10 | \$ | 631 | 654 | 671 | 688 | 710 | 727 | 744 | 767 | 784 | 801 | 840 | 880 | | |
| .12 | \$ | 733 | 756 | 773 | 789 | 812 | 829 | 846 | 868 | 885 | 902 | 942 | 981 | | |
| .14 | \$ | 835 | 857 | 874 | 891 | 914 | 931 | 947 | 970 | 987 | 1004 | 1043 | 1083 | BALANCE POINT 27 DEG.F. | |
| .16 | \$ | 936 | 959 | 976 | 993 | 1015 | 1032 | 1049 | 1072 | 1089 | 1105 | 1145 | 1184 | | |
| 50,000 | \$ | 383 | 440 | 496 | 552 | 609 | 665 | 716 | 773 | 829 | 885 | 998 | 1105 | ---THEORETICAL HEATING COST * FURNACE ONLY | |
| .05 | \$ | 440 | 473 | 507 | 541 | 575 | 603 | 637 | 671 | 705 | 739 | 806 | 868 | THEORETICAL HEATING COST * FURN. + HEAT PUMP \$ PER YEAR | |
| .06 | \$ | 485 | 519 | 552 | 586 | 620 | 648 | 682 | 716 | 750 | 784 | 852 | 914 | | |
| .07 | \$ | 534 | 569 | 592 | 626 | 660 | 688 | 722 | 756 | 789 | 823 | 891 | 953 | | |
| .08 | \$ | 589 | 603 | 637 | 671 | 705 | 733 | 767 | 801 | 835 | 868 | 936 | 998 | | |
| .09 | \$ | 609 | 643 | 677 | 710 | 744 | 773 | 806 | 840 | 874 | 908 | 976 | 1038 | | |
| .10 | \$ | 634 | 688 | 722 | 756 | 789 | 818 | 852 | 885 | 919 | 953 | 1021 | 1083 | | |
| .12 | \$ | 739 | 773 | 806 | 840 | 874 | 902 | 936 | 970 | 1004 | 1038 | 1105 | 1168 | | |
| .14 | \$ | 823 | 857 | 891 | 925 | 959 | 987 | 1021 | 1055 | 1089 | 1122 | 1190 | 1252 | BALANCE POINT 32 DEG.F. | |
| .16 | \$ | 908 | 942 | 976 | 1010 | 1043 | 1072 | 1105 | 1139 | 1173 | 1207 | 1275 | 1337 | | |
| 60,000 | \$ | 462 | 520 | 598 | 665 | 727 | 795 | 863 | 931 | 998 | 1060 | 1196 | 1331 | ---THEORETICAL HEATING COST * FURNACE ONLY | |
| .05 | \$ | 524 | 564 | 603 | 643 | 688 | 727 | 767 | 806 | 846 | 885 | 964 | 1043 | THEORETICAL HEATING COST * FURN. + HEAT PUMP \$ PER YEAR | |
| .06 | \$ | 529 | 609 | 648 | 688 | 733 | 773 | 812 | 852 | 891 | 931 | 1010 | 1089 | | |
| .07 | \$ | 620 | 660 | 699 | 739 | 784 | 823 | 863 | 902 | 942 | 981 | 1060 | 1139 | | |
| .08 | \$ | 671 | 710 | 750 | 789 | 835 | 874 | 914 | 953 | 993 | 1032 | 1111 | 1190 | | |
| .09 | \$ | 722 | 761 | 801 | 840 | 885 | 925 | 964 | 1004 | 1043 | 1083 | 1162 | 1241 | | |
| .10 | \$ | 767 | 806 | 846 | 885 | 931 | 970 | 1010 | 1049 | 1089 | 1128 | 1207 | 1286 | | |
| .12 | \$ | 868 | 908 | 947 | 987 | 1032 | 1072 | 1111 | 1151 | 1190 | 1230 | 1309 | 1388 | | |
| .14 | \$ | 964 | 1004 | 1043 | 1083 | 1128 | 1168 | 1207 | 1247 | 1286 | 1326 | 1405 | 1484 | BALANCE POINT 36 DEG.F. | |
| .16 | \$ | 1066 | 1105 | 1145 | 1184 | 1230 | 1269 | 1309 | 1348 | 1388 | 1427 | 1506 | 1585 | | |

ANNUAL AIR CONDITIONING COST WHEN COOLING LOAD IS SIZED TO MATCH COOLING CAPACITY OF HEAT PUMP

| | | | | | | | | | | |
|----|-----|-----|-----|-----|-----|-----|-----|-----|-----|---|
| | .05 | .06 | .07 | .08 | .09 | .10 | .12 | .14 | .16 | |
| \$ | 122 | 147 | 171 | 196 | 220 | 245 | 294 | 343 | 392 | ---ELECTRIC RATE \$/KWH ---THEORETICAL AIR CONDITIONING COST |

THE ABOVE ANNUAL HEATING AND COOLING OPERATING COSTS ARE THEORETICAL ESTIMATES ONLY AND ARE PROVIDED FOR A COMMON BASIS OF COMPARISON BETWEEN VARIOUS TYPES OF HEATING AND COOLING SYSTEMS. ACTUAL VALUES MAY VARY DEPENDING ON ACTUAL WEATHER CONDITIONS AND INDIVIDUAL USAGE PATTERN.

BARD MANUFACTURING COMPANY

DUAL FUEL ADD-ON HEAT PUMP GUIDE TO ENERGY COST SAVINGS

REGION 4
 HEAT PUMP MODEL: OUTDOOR 30URP0R 30URP0R/A36A0-A INDOOR A36A0-A
 AIR RATED COOLING CAP.: BTUH (95) 28200 SEER 9.19
 AIR RATED HEATING CAP.: BTUH (47) 28800 COP (17) 3.00 HSPF 6.90 MIN. DER REG IV
 FURNACE TYPE FUEL OIL FURNACE EFFICIENCY 78.00 % AFUE

| HEAT LOSS BTUH | HEAT PUMP COST \$/KWH | HEATING OIL COST - \$/GALLON | | | | | | | | | | | | | |
|----------------|-----------------------|------------------------------|------|------|------|------|------|------|------|------|------|------|------|--|--|
| | | .70 | .80 | .90 | 1.00 | 1.10 | 1.20 | 1.30 | 1.40 | 1.50 | 1.60 | 1.70 | | 1.80 | |
| 30,000 | \$ | 332 | 383 | 428 | 479 | 524 | 575 | 620 | 671 | 716 | 767 | 812 | 863 | ←--THEORETICAL HEATING COST * FURNACE ONLY | |
| | .05 | 344 | 355 | 361 | 373 | 378 | 389 | 400 | 406 | 417 | 423 | 434 | 440 | THEORETICAL HEATING COST * FURN. + HEAT PUMP | |
| | .06 | 400 | 411 | 417 | 428 | 434 | 445 | 457 | 462 | 473 | 479 | 490 | 496 | \$ PER YEAR | |
| | .07 | 451 | 462 | 468 | 479 | 485 | 496 | 507 | 513 | 524 | 530 | 541 | 547 | | |
| | .08 | 501 | 512 | 518 | 529 | 536 | 547 | 558 | 564 | 575 | 581 | 592 | 598 | | |
| | .09 | 551 | 562 | 568 | 579 | 586 | 597 | 608 | 614 | 625 | 631 | 642 | 648 | | |
| | .10 | 601 | 612 | 618 | 629 | 636 | 647 | 658 | 664 | 675 | 681 | 692 | 698 | | |
| | .12 | 651 | 662 | 668 | 679 | 686 | 697 | 708 | 714 | 725 | 731 | 742 | 748 | | |
| | .14 | 701 | 712 | 718 | 729 | 736 | 747 | 758 | 764 | 775 | 781 | 792 | 798 | | |
| | .16 | 751 | 762 | 768 | 779 | 786 | 797 | 808 | 814 | 825 | 831 | 842 | 848 | BALANCE POINT 20 DEG.F. | |
| | | 959 | 970 | 976 | 987 | 993 | 1004 | 1015 | 1021 | 1032 | 1038 | 1049 | 1055 | | |
| 35,000 | \$ | 389 | 445 | 502 | 558 | 615 | 671 | 727 | 784 | 835 | 891 | 947 | 1004 | ←--THEORETICAL HEATING COST * FURNACE ONLY | |
| | .05 | 394 | 411 | 423 | 440 | 457 | 473 | 490 | 507 | 519 | 536 | 552 | 569 | THEORETICAL HEATING COST * FURN. + HEAT PUMP | |
| | .06 | 451 | 468 | 479 | 496 | 513 | 530 | 547 | 564 | 575 | 592 | 609 | 626 | \$ PER YEAR | |
| | .07 | 502 | 519 | 530 | 547 | 564 | 581 | 598 | 615 | 626 | 643 | 660 | 677 | | |
| | .08 | 552 | 569 | 586 | 603 | 620 | 637 | 654 | 671 | 683 | 699 | 716 | 733 | | |
| | .09 | 603 | 620 | 643 | 660 | 677 | 694 | 710 | 727 | 739 | 756 | 773 | 789 | | |
| | .10 | 653 | 671 | 694 | 711 | 727 | 744 | 761 | 778 | 789 | 806 | 823 | 840 | | |
| | .12 | 704 | 721 | 744 | 761 | 778 | 794 | 811 | 823 | 835 | 852 | 869 | 886 | | |
| | .14 | 754 | 771 | 794 | 811 | 827 | 844 | 861 | 873 | 885 | 902 | 919 | 936 | | |
| | .16 | 804 | 821 | 844 | 861 | 877 | 894 | 911 | 923 | 935 | 952 | 969 | 986 | BALANCE POINT 23 DEG.F. | |
| | | 1010 | 1026 | 1038 | 1055 | 1072 | 1089 | 1105 | 1122 | 1134 | 1151 | 1168 | 1184 | | |
| 40,000 | \$ | 445 | 507 | 575 | 637 | 699 | 767 | 829 | 891 | 959 | 1021 | 1083 | 1151 | ←--THEORETICAL HEATING COST * FURNACE ONLY | |
| | .05 | 445 | 468 | 496 | 524 | 552 | 581 | 603 | 631 | 660 | 688 | 716 | 739 | THEORETICAL HEATING COST * FURN. + HEAT PUMP | |
| | .06 | 502 | 519 | 530 | 547 | 564 | 581 | 603 | 620 | 637 | 654 | 671 | 688 | \$ PER YEAR | |
| | .07 | 552 | 569 | 586 | 603 | 620 | 637 | 654 | 671 | 683 | 699 | 716 | 733 | | |
| | .08 | 603 | 620 | 643 | 660 | 677 | 694 | 710 | 727 | 739 | 756 | 773 | 789 | | |
| | .09 | 653 | 671 | 694 | 711 | 727 | 744 | 761 | 778 | 789 | 806 | 823 | 840 | | |
| | .10 | 704 | 721 | 744 | 761 | 778 | 794 | 811 | 823 | 835 | 852 | 869 | 886 | | |
| | .12 | 754 | 771 | 794 | 811 | 827 | 844 | 861 | 873 | 885 | 902 | 919 | 936 | | |
| | .14 | 804 | 821 | 844 | 861 | 877 | 894 | 911 | 923 | 935 | 952 | 969 | 986 | | |
| | .16 | 854 | 871 | 894 | 911 | 927 | 944 | 961 | 973 | 985 | 1002 | 1019 | 1036 | BALANCE POINT 27 DEG.F. | |
| | | 998 | 1021 | 1049 | 1077 | 1105 | 1134 | 1156 | 1184 | 1213 | 1241 | 1269 | 1292 | | |
| 50,000 | \$ | 558 | 637 | 716 | 795 | 880 | 959 | 1038 | 1117 | 1196 | 1280 | 1359 | 1438 | ←--THEORETICAL HEATING COST * FURNACE ONLY | |
| | .05 | 541 | 592 | 637 | 688 | 733 | 784 | 829 | 880 | 925 | 970 | 1021 | 1066 | THEORETICAL HEATING COST * FURN. + HEAT PUMP | |
| | .06 | 592 | 609 | 620 | 637 | 654 | 671 | 688 | 705 | 717 | 733 | 750 | 767 | \$ PER YEAR | |
| | .07 | 643 | 660 | 671 | 688 | 705 | 721 | 738 | 750 | 767 | 789 | 818 | 840 | | |
| | .08 | 694 | 711 | 721 | 738 | 755 | 771 | 789 | 806 | 823 | 840 | 857 | 874 | | |
| | .09 | 745 | 762 | 771 | 789 | 806 | 823 | 840 | 857 | 874 | 891 | 908 | 925 | | |
| | .10 | 796 | 813 | 823 | 840 | 857 | 874 | 891 | 908 | 925 | 942 | 959 | 976 | | |
| | .12 | 847 | 864 | 874 | 891 | 908 | 925 | 942 | 959 | 976 | 993 | 1010 | 1027 | | |
| | .14 | 898 | 915 | 925 | 942 | 959 | 976 | 993 | 1010 | 1027 | 1044 | 1061 | 1078 | | |
| | .16 | 948 | 965 | 976 | 993 | 1010 | 1027 | 1044 | 1061 | 1078 | 1095 | 1112 | 1129 | BALANCE POINT 32 DEG.F. | |
| | | 1010 | 1060 | 1105 | 1156 | 1201 | 1252 | 1297 | 1348 | 1393 | 1438 | 1489 | 1534 | | |
| 60,000 | \$ | 671 | 767 | 863 | 959 | 1055 | 1151 | 1247 | 1342 | 1438 | 1534 | 1630 | 1726 | ←--THEORETICAL HEATING COST * FURNACE ONLY | |
| | .05 | 648 | 705 | 761 | 823 | 880 | 936 | 993 | 1049 | 1105 | 1168 | 1224 | 1280 | THEORETICAL HEATING COST * FURN. + HEAT PUMP | |
| | .06 | 699 | 716 | 727 | 744 | 761 | 778 | 794 | 811 | 823 | 835 | 852 | 869 | \$ PER YEAR | |
| | .07 | 750 | 767 | 771 | 789 | 806 | 823 | 840 | 857 | 874 | 891 | 908 | 925 | | |
| | .08 | 801 | 818 | 823 | 840 | 857 | 874 | 891 | 908 | 925 | 942 | 959 | 976 | | |
| | .09 | 852 | 869 | 874 | 891 | 908 | 925 | 942 | 959 | 976 | 993 | 1010 | 1027 | | |
| | .10 | 903 | 920 | 925 | 942 | 959 | 976 | 993 | 1010 | 1027 | 1044 | 1061 | 1078 | | |
| | .12 | 954 | 971 | 976 | 993 | 1010 | 1027 | 1044 | 1061 | 1078 | 1095 | 1112 | 1129 | | |
| | .14 | 1005 | 1022 | 1027 | 1044 | 1061 | 1078 | 1095 | 1112 | 1129 | 1146 | 1163 | 1180 | | |
| | .16 | 1056 | 1073 | 1078 | 1095 | 1112 | 1129 | 1146 | 1163 | 1180 | 1197 | 1214 | 1231 | BALANCE POINT 36 DEG.F. | |
| | | 1190 | 1247 | 1303 | 1365 | 1421 | 1478 | 1534 | 1591 | 1647 | 1709 | 1766 | 1822 | | |

ANNUAL AIR CONDITIONING COST WHEN COOLING LOAD IS SIZED TO MATCH COOLING CAPACITY OF HEAT PUMP

| | | | | | | | | | | | |
|----|-----|-----|-----|-----|-----|-----|-----|-----|-----|--|--------------------------------------|
| \$ | .05 | .06 | .07 | .08 | .09 | .10 | .12 | .14 | .16 | | ←--ELECTRIC RATE \$/KWH |
| | 122 | 147 | 171 | 196 | 220 | 245 | 294 | 343 | 392 | | ←--THEORETICAL AIR CONDITIONING COST |

THE ABOVE ANNUAL HEATING AND COOLING OPERATING COSTS ARE THEORETICAL ESTIMATES ONLY AND ARE PROVIDED FOR A COMMON BASIS OF COMPARISON BETWEEN VARIOUS TYPES OF HEATING AND COOLING SYSTEMS. ACTUAL VALUES MAY VARY DEPENDING ON ACTUAL WEATHER CONDITIONS AND INDIVIDUAL USAGE PATTERNS.

BARD MANUFACTURING COMPANY
DUAL FUEL ADD-ON HEAT PUMP GUIDE TO ENERGY COST SAVINGS

REGION 4
 HEAT PUMP MODEL: OUTDOOR SOURCE: 30URPQB/A36AQ-A INDOOR A36AQ-A
 RATED COOLING CAP.: BTUH (95) 28000 SEER 9.19
 RATED HEATING CAP.: BTUH (47) 28000 COP (47) 2.00 HSPF 4.90 MIN. DHR REG IV
 FURNACE TYPE: PROPANE GAS FURNACE EFFICIENCY 78.00 % AFUE

| HEAT LOSS BTUH | ELEC. COST \$/KWH | PROPANE GAS COST - \$/GALLON | | | | | | | | | | | | |
|----------------|-------------------|------------------------------|------|------|------|------|------|------|------|------|------|------|------|--|
| | | .60 | .65 | .70 | .75 | .80 | .85 | .90 | .95 | 1.00 | 1.10 | 1.20 | 1.20 | |
| 30,000 | | \$ 434 | 473 | 507 | 547 | 581 | 620 | 654 | 694 | 727 | 801 | 874 | 874 | <--THEORETICAL HEATING COST * FURNACE ONLY |
| | .05 | \$ 361 | 372 | 378 | 383 | 389 | 400 | 406 | 411 | 417 | 434 | 445 | 445 | THEORETICAL HEATING COST * FURN. + HEAT PUMP \$ PER YEAR |
| | .06 | 411 | 428 | 434 | 440 | 445 | 457 | 463 | 468 | 473 | 490 | 502 | 502 | |
| | .07 | 468 | 479 | 485 | 490 | 496 | 507 | 513 | 519 | 524 | 541 | 552 | 552 | |
| | .08 | 524 | 536 | 541 | 547 | 552 | 564 | 569 | 575 | 581 | 598 | 609 | 609 | |
| | .09 | 581 | 592 | 598 | 603 | 609 | 620 | 626 | 631 | 637 | 654 | 665 | 665 | |
| | .10 | 637 | 648 | 654 | 660 | 665 | 677 | 682 | 688 | 694 | 710 | 722 | 722 | |
| | .12 | 750 | 761 | 767 | 773 | 778 | 789 | 795 | 801 | 806 | 823 | 835 | 835 | BALANCE POINT 20 DEG.F. |
| | .14 | 863 | 874 | 880 | 886 | 891 | 902 | 908 | 914 | 919 | 936 | 947 | 947 | |
| | .16 | 976 | 987 | 993 | 998 | 1004 | 1015 | 1021 | 1026 | 1032 | 1049 | 1060 | 1060 | |
| 35,000 | | \$ 507 | 552 | 592 | 637 | 682 | 722 | 767 | 806 | 852 | 936 | 1021 | 1021 | |
| | .05 | \$ 428 | 440 | 451 | 462 | 473 | 490 | 502 | 513 | 524 | 547 | 575 | 575 | THEORETICAL HEATING COST * FURN. + HEAT PUMP \$ PER YEAR |
| | .06 | 485 | 496 | 507 | 519 | 530 | 547 | 558 | 569 | 581 | 603 | 631 | 631 | |
| | .07 | 542 | 553 | 564 | 575 | 586 | 603 | 620 | 631 | 642 | 664 | 692 | 692 | |
| | .08 | 592 | 603 | 615 | 626 | 637 | 654 | 665 | 677 | 688 | 710 | 739 | 739 | |
| | .09 | 648 | 660 | 671 | 682 | 694 | 710 | 722 | 733 | 744 | 767 | 795 | 795 | |
| | .10 | 705 | 716 | 727 | 738 | 750 | 767 | 778 | 789 | 801 | 823 | 852 | 852 | |
| | .12 | 818 | 829 | 840 | 852 | 863 | 880 | 891 | 902 | 914 | 936 | 964 | 964 | BALANCE POINT 23 DEG.F. |
| | .14 | 931 | 942 | 953 | 964 | 976 | 993 | 1004 | 1015 | 1026 | 1049 | 1077 | 1077 | |
| | .16 | 1043 | 1055 | 1066 | 1077 | 1089 | 1105 | 1117 | 1128 | 1139 | 1162 | 1190 | 1190 | |
| 40,000 | | \$ 581 | 631 | 682 | 727 | 778 | 829 | 874 | 925 | 976 | 1072 | 1168 | 1168 | |
| | .05 | \$ 502 | 524 | 541 | 564 | 586 | 603 | 626 | 648 | 665 | 705 | 750 | 750 | THEORETICAL HEATING COST * FURN. + HEAT PUMP \$ PER YEAR |
| | .06 | 553 | 575 | 592 | 615 | 637 | 654 | 677 | 699 | 716 | 756 | 801 | 801 | |
| | .07 | 603 | 626 | 643 | 665 | 688 | 705 | 727 | 750 | 767 | 806 | 852 | 852 | |
| | .08 | 648 | 671 | 688 | 710 | 733 | 750 | 773 | 795 | 812 | 852 | 897 | 897 | |
| | .09 | 698 | 722 | 739 | 761 | 784 | 801 | 823 | 846 | 863 | 903 | 947 | 947 | |
| | .10 | 750 | 773 | 789 | 812 | 835 | 852 | 874 | 897 | 914 | 953 | 998 | 998 | |
| | .12 | 852 | 874 | 891 | 914 | 936 | 953 | 976 | 998 | 1015 | 1055 | 1100 | 1100 | BALANCE POINT 27 DEG.F. |
| | .14 | 953 | 976 | 993 | 1015 | 1038 | 1055 | 1077 | 1100 | 1117 | 1156 | 1201 | 1201 | |
| | .16 | 1055 | 1077 | 1094 | 1117 | 1139 | 1156 | 1179 | 1201 | 1218 | 1258 | 1303 | 1303 | |
| 50,000 | | \$ 727 | 789 | 852 | 914 | 976 | 1032 | 1094 | 1156 | 1218 | 1337 | 1461 | 1461 | |
| | .05 | \$ 643 | 682 | 716 | 756 | 789 | 829 | 863 | 902 | 936 | 1010 | 1083 | 1083 | THEORETICAL HEATING COST * FURN. + HEAT PUMP \$ PER YEAR |
| | .06 | 688 | 727 | 761 | 801 | 835 | 874 | 908 | 947 | 981 | 1055 | 1128 | 1128 | |
| | .07 | 727 | 767 | 801 | 840 | 874 | 914 | 947 | 987 | 1021 | 1094 | 1168 | 1168 | |
| | .08 | 773 | 812 | 846 | 885 | 919 | 959 | 993 | 1032 | 1064 | 1139 | 1213 | 1213 | |
| | .09 | 812 | 852 | 885 | 925 | 959 | 998 | 1032 | 1072 | 1105 | 1179 | 1252 | 1252 | |
| | .10 | 857 | 897 | 931 | 970 | 1004 | 1043 | 1077 | 1117 | 1151 | 1224 | 1297 | 1297 | |
| | .12 | 942 | 981 | 1015 | 1055 | 1089 | 1128 | 1162 | 1201 | 1235 | 1309 | 1382 | 1382 | BALANCE POINT 32 DEG.F. |
| | .14 | 1026 | 1066 | 1100 | 1139 | 1173 | 1213 | 1247 | 1286 | 1320 | 1393 | 1467 | 1467 | |
| | .16 | 1111 | 1151 | 1184 | 1224 | 1258 | 1297 | 1331 | 1371 | 1405 | 1478 | 1551 | 1551 | |
| 60,000 | | \$ 874 | 947 | 1021 | 1094 | 1168 | 1241 | 1314 | 1388 | 1461 | 1608 | 1754 | 1754 | |
| | .05 | \$ 773 | 818 | 857 | 902 | 947 | 993 | 1032 | 1077 | 1122 | 1207 | 1297 | 1297 | THEORETICAL HEATING COST * FURN. + HEAT PUMP \$ PER YEAR |
| | .06 | 818 | 863 | 902 | 947 | 993 | 1038 | 1077 | 1122 | 1168 | 1252 | 1342 | 1342 | |
| | .07 | 868 | 914 | 953 | 998 | 1043 | 1089 | 1128 | 1173 | 1218 | 1303 | 1393 | 1393 | |
| | .08 | 919 | 964 | 1004 | 1049 | 1094 | 1139 | 1179 | 1224 | 1269 | 1354 | 1444 | 1444 | |
| | .09 | 970 | 1015 | 1055 | 1100 | 1145 | 1190 | 1230 | 1275 | 1320 | 1405 | 1495 | 1495 | |
| | .10 | 1015 | 1060 | 1100 | 1145 | 1190 | 1235 | 1275 | 1320 | 1365 | 1450 | 1540 | 1540 | |
| | .12 | 1117 | 1163 | 1201 | 1247 | 1292 | 1337 | 1376 | 1421 | 1467 | 1551 | 1642 | 1642 | BALANCE POINT 36 DEG.F. |
| | .14 | 1213 | 1258 | 1297 | 1342 | 1388 | 1433 | 1472 | 1517 | 1563 | 1647 | 1737 | 1737 | |
| | .16 | 1314 | 1359 | 1399 | 1444 | 1489 | 1534 | 1574 | 1619 | 1664 | 1749 | 1839 | 1839 | |

ANNUAL AIR CONDITIONING COST WHEN COOLING LOAD IS SIZED TO MATCH COOLING CAPACITY OF HEAT PUMP

| | .05 | .06 | .07 | .08 | .09 | .10 | .12 | .14 | .16 | |
|----|-----|-----|-----|-----|-----|-----|-----|-----|-----|--------------------------------------|
| \$ | 123 | 147 | 171 | 196 | 220 | 245 | 294 | 343 | 392 | <--ELECTRIC RATE \$/KWH |
| | | | | | | | | | | <--THEORETICAL AIR CONDITIONING COST |

THE ABOVE ANNUAL HEATING AND COOLING OPERATING COSTS ARE THEORETICAL ESTIMATES ONLY AND ARE PROVIDED FOR A COMMON BASIS OF COMPARISON BETWEEN VARIOUS TYPES OF HEATING AND COOLING SYSTEMS. ACTUAL VALUES MAY VARY DEPENDING ON ACTUAL WEATHER CONDITIONS AND INDIVIDUAL USAGE PATTERN.

BARD MANUFACTURING COMPANY
 DUAL FUEL ADD-ON HEAT PUMP GUIDE TO ENERGY COST SAVINGS

REGION 4
 HEAT PUMP MODEL: OUTDOOR 30URP0R 30URP0R/A37A0-A
 INDOOR A37A0-A
 NET RATED COOLING CAP: BTUH(95) 30000, SEER10.00
 NET RATED HEATING CAP: BTUH(47) 29000, COP(47) 3.00, HSPF 7.00 MIN.DHR REC 19
 KW(17) 17000, COP(17) 2.10
 FURNACE TYPE ELECTRIC FURNACE EFFICIENCY 100.00 % AFUE

HEAT LOSS
 BTUH
 ELEC.
 COST
 \$/KWH

30,000

--- THEORETICAL ANNUAL HEATING COST ---
 HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

| | | |
|-----|------|------|
| .05 | 355 | 756 |
| .06 | 434 | 908 |
| .07 | 502 | 1060 |
| .08 | 575 | 1213 |
| .09 | 648 | 1366 |
| .10 | 722 | 1517 |
| .11 | 797 | 1670 |
| .12 | 874 | 1823 |
| .13 | 954 | 1977 |
| .14 | 1034 | 2131 |
| .15 | 1151 | 2431 |

BALANCE POINT 18 DEG.F.

35,000

--- THEORETICAL ANNUAL HEATING COST ---
 HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

| | | |
|-----|------|------|
| .05 | 423 | 885 |
| .06 | 507 | 1060 |
| .07 | 592 | 1241 |
| .08 | 677 | 1416 |
| .09 | 756 | 1596 |
| .10 | 848 | 1771 |
| .11 | 940 | 1947 |
| .12 | 1010 | 2127 |
| .13 | 1179 | 2482 |
| .14 | 1348 | 2838 |

BALANCE POINT 22 DEG.F.

40,000

--- THEORETICAL ANNUAL HEATING COST ---
 HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

| | | |
|-----|------|------|
| .05 | 490 | 1010 |
| .06 | 586 | 1213 |
| .07 | 688 | 1416 |
| .08 | 784 | 1619 |
| .09 | 880 | 1823 |
| .10 | 976 | 2025 |
| .11 | 1179 | 2431 |
| .12 | 1371 | 2838 |
| .13 | 1568 | 3244 |

BALANCE POINT 25 DEG.F.

50,000

--- THEORETICAL ANNUAL HEATING COST ---
 HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

| | | |
|-----|------|------|
| .05 | 643 | 1263 |
| .06 | 767 | 1517 |
| .07 | 897 | 1771 |
| .08 | 1026 | 2025 |
| .09 | 1151 | 2278 |
| .10 | 1286 | 2533 |
| .11 | 1540 | 3041 |
| .12 | 1794 | 3549 |
| .13 | 2048 | 4057 |

BALANCE POINT 30 DEG.F.

60,000

--- THEORETICAL ANNUAL HEATING COST ---
 HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

| | | |
|-----|------|------|
| .05 | 818 | 1517 |
| .06 | 976 | 1822 |
| .07 | 1139 | 2127 |
| .08 | 1303 | 2431 |
| .09 | 1467 | 2736 |
| .10 | 1630 | 3041 |
| .11 | 1857 | 3650 |
| .12 | 2285 | 4260 |
| .13 | 2618 | 4869 |

BALANCE POINT 34 DEG.F.

ANNUAL AIR CONDITIONING COST WHEN COOLING LOAD IS SIZED TO MATCH COOLING CAPACITY OF HEAT PUMP

| | | | | | | | | | |
|----|-----|-----|-----|-----|-----|-----|-----|-----|-----|
| \$ | .05 | .06 | .07 | .08 | .09 | .10 | .12 | .14 | .16 |
| | 120 | 144 | 168 | 192 | 216 | 240 | 288 | 336 | 384 |

<--ELECTRIC RATE \$/KWH
 <--THEORETICAL AIR CONDITIONING COST

THE ABOVE ANNUAL HEATING AND COOLING OPERATING COSTS ARE THEORETICAL ESTIMATES ONLY AND ARE PROVIDED FOR A COMMON BASIS OF COMPARISON BETWEEN VARIOUS TYPES OF HEATING AND COOLING SYSTEMS. ACTUAL VALUES MAY VARY DEPENDING ON ACTUAL WEATHER CONDITIONS AND INDIVIDUAL USAGE PATTERN.

BARD MANUFACTURING COMPANY

DUAL FUEL ADD-ON HEAT PUMP GUIDE TO ENERGY COST SAVINGS

REGION 4
 HEAT PUMP MODEL: OUTDOOR SOURCE 30URP08/A37A0-A INDOOR A37A0-A
 ARI RATED COOLING CAP: BTUH (95) 30000 SEER 10.00
 ARI RATED HEATING CAP: BTUH (47) 29000 COP (17) 3.00, HSPF 7.00 MIN. DR. DEG IV
 BTUH (17) 17000 COP (17) 2.10
 FURNACE TYPE NATURAL GAS FURNACE EFFICIENCY 78.00 % AFUE

| HEAT LOSS BTUH | ELECT. COST \$/KWH | NATURAL GAS COST - \$/THERM | | | | | | | | | | | | |
|----------------|--------------------|-----------------------------|------|------|------|------|------|------|------|------|------|------|------|--|
| | | .35 | .40 | .45 | .50 | .55 | .60 | .65 | .70 | .75 | .80 | .90 | 1.00 | |
| 30,000 | \$ | 231 | 265 | 299 | 332 | 361 | 394 | 428 | 462 | 496 | 530 | 598 | 665 | <--THEORETICAL HEATING COST * FURNACE ONLY |
| | .05 | 310 | 315 | 321 | 327 | 332 | 338 | 344 | 349 | 355 | 366 | 378 | 389 | THEORETICAL HEATING COST * FURN. + HEAT PUMP \$ PER YEAR |
| | .06 | 366 | 372 | 378 | 383 | 389 | 394 | 400 | 406 | 411 | 423 | 434 | 445 | |
| | .07 | 417 | 423 | 428 | 434 | 440 | 445 | 451 | 457 | 462 | 473 | 485 | 496 | |
| | .08 | 473 | 479 | 485 | 490 | 496 | 502 | 507 | 513 | 519 | 530 | 541 | 552 | |
| | .09 | 524 | 530 | 536 | 541 | 547 | 552 | 558 | 564 | 571 | 581 | 592 | 603 | |
| | .10 | 574 | 586 | 592 | 598 | 603 | 609 | 615 | 620 | 626 | 637 | 648 | 660 | |
| | .12 | 682 | 688 | 694 | 699 | 705 | 710 | 716 | 722 | 727 | 739 | 750 | 761 | |
| | .14 | 789 | 795 | 801 | 806 | 812 | 818 | 823 | 829 | 835 | 846 | 857 | 868 | BALANCE POINT 18 DEG.F. |
| | .16 | 897 | 902 | 908 | 914 | 919 | 925 | 931 | 936 | 942 | 953 | 964 | 976 | |
| 35,000 | \$ | 270 | 310 | 344 | 383 | 423 | 462 | 502 | 541 | 581 | 620 | 694 | 773 | <--THEORETICAL HEATING COST * FURNACE ONLY |
| | .05 | 344 | 355 | 366 | 378 | 389 | 400 | 406 | 417 | 428 | 440 | 462 | 485 | THEORETICAL HEATING COST * FURN. + HEAT PUMP \$ PER YEAR |
| | .06 | 400 | 411 | 423 | 434 | 445 | 457 | 462 | 473 | 485 | 496 | 519 | 541 | |
| | .07 | 451 | 462 | 473 | 485 | 496 | 507 | 513 | 524 | 536 | 547 | 569 | 592 | |
| | .08 | 502 | 513 | 524 | 536 | 547 | 558 | 564 | 575 | 586 | 598 | 620 | 643 | |
| | .09 | 558 | 569 | 581 | 592 | 603 | 615 | 620 | 631 | 643 | 654 | 677 | 699 | |
| | .10 | 609 | 620 | 631 | 643 | 654 | 665 | 677 | 688 | 694 | 705 | 727 | 750 | |
| | .12 | 716 | 727 | 739 | 750 | 761 | 773 | 778 | 789 | 801 | 812 | 835 | 857 | |
| | .14 | 823 | 835 | 846 | 857 | 868 | 880 | 885 | 897 | 908 | 919 | 942 | 964 | BALANCE POINT 22 DEG.F. |
| | .16 | 931 | 942 | 953 | 964 | 976 | 987 | 993 | 1004 | 1015 | 1026 | 1049 | 1072 | |
| 40,000 | \$ | 310 | 349 | 394 | 440 | 485 | 530 | 575 | 620 | 665 | 705 | 795 | 885 | <--THEORETICAL HEATING COST * FURNACE ONLY |
| | .05 | 389 | 400 | 411 | 423 | 440 | 451 | 462 | 473 | 485 | 502 | 524 | 552 | THEORETICAL HEATING COST * FURN. + HEAT PUMP \$ PER YEAR |
| | .06 | 445 | 457 | 468 | 479 | 490 | 501 | 513 | 524 | 536 | 547 | 569 | 592 | |
| | .07 | 507 | 519 | 530 | 541 | 552 | 569 | 581 | 592 | 609 | 620 | 643 | 671 | |
| | .08 | 564 | 575 | 586 | 598 | 615 | 626 | 637 | 648 | 665 | 677 | 699 | 727 | |
| | .09 | 626 | 637 | 648 | 660 | 677 | 688 | 699 | 710 | 727 | 739 | 761 | 789 | |
| | .10 | 682 | 694 | 705 | 716 | 733 | 744 | 756 | 767 | 784 | 795 | 818 | 846 | |
| | .12 | 806 | 818 | 829 | 840 | 857 | 868 | 880 | 891 | 908 | 919 | 942 | 970 | |
| | .14 | 925 | 936 | 947 | 959 | 976 | 987 | 998 | 1010 | 1026 | 1038 | 1060 | 1089 | BALANCE POINT 25 DEG.F. |
| | .16 | 1043 | 1055 | 1066 | 1077 | 1094 | 1105 | 1117 | 1128 | 1145 | 1156 | 1179 | 1207 | |
| 50,000 | \$ | 383 | 440 | 496 | 552 | 609 | 665 | 716 | 773 | 829 | 885 | 998 | 1105 | <--THEORETICAL HEATING COST * FURNACE ONLY |
| | .05 | 451 | 473 | 496 | 524 | 547 | 569 | 592 | 615 | 637 | 665 | 710 | 756 | THEORETICAL HEATING COST * FURN. + HEAT PUMP \$ PER YEAR |
| | .06 | 507 | 530 | 552 | 581 | 603 | 626 | 648 | 671 | 694 | 727 | 767 | 812 | |
| | .07 | 569 | 592 | 615 | 643 | 665 | 688 | 710 | 733 | 756 | 784 | 829 | 874 | |
| | .08 | 626 | 648 | 671 | 699 | 727 | 744 | 767 | 789 | 812 | 840 | 885 | 931 | |
| | .09 | 682 | 705 | 727 | 756 | 778 | 801 | 823 | 846 | 868 | 891 | 942 | 987 | |
| | .10 | 739 | 761 | 784 | 812 | 835 | 857 | 880 | 902 | 925 | 953 | 998 | 1043 | |
| | .12 | 857 | 880 | 902 | 931 | 953 | 976 | 998 | 1021 | 1043 | 1072 | 1117 | 1162 | |
| | .14 | 970 | 993 | 1015 | 1043 | 1066 | 1089 | 1111 | 1134 | 1156 | 1184 | 1230 | 1275 | BALANCE POINT 30 DEG.F. |
| | .16 | 1089 | 1111 | 1134 | 1162 | 1184 | 1207 | 1230 | 1252 | 1275 | 1303 | 1348 | 1393 | |
| 60,000 | \$ | 462 | 530 | 598 | 665 | 727 | 795 | 863 | 931 | 998 | 1060 | 1196 | 1331 | <--THEORETICAL HEATING COST * FURNACE ONLY |
| | .05 | 513 | 551 | 592 | 631 | 677 | 716 | 756 | 795 | 835 | 874 | 953 | 1032 | THEORETICAL HEATING COST * FURN. + HEAT PUMP \$ PER YEAR |
| | .06 | 558 | 598 | 637 | 677 | 722 | 761 | 801 | 840 | 880 | 919 | 998 | 1077 | |
| | .07 | 603 | 643 | 682 | 722 | 761 | 806 | 846 | 885 | 925 | 964 | 1043 | 1122 | |
| | .08 | 654 | 694 | 733 | 773 | 818 | 857 | 897 | 936 | 976 | 1015 | 1094 | 1173 | |
| | .09 | 709 | 739 | 778 | 818 | 863 | 902 | 942 | 981 | 1021 | 1060 | 1139 | 1218 | |
| | .10 | 744 | 784 | 823 | 863 | 908 | 947 | 987 | 1026 | 1066 | 1105 | 1184 | 1263 | |
| | .12 | 840 | 880 | 919 | 959 | 1004 | 1043 | 1083 | 1122 | 1162 | 1201 | 1280 | 1359 | |
| | .14 | 936 | 976 | 1015 | 1055 | 1100 | 1139 | 1179 | 1218 | 1258 | 1297 | 1376 | 1455 | BALANCE POINT 34 DEG.F. |
| | .16 | 1026 | 1066 | 1105 | 1145 | 1190 | 1230 | 1269 | 1309 | 1348 | 1388 | 1467 | 1546 | |

ANNUAL AIR CONDITIONING COST WHEN COOLING LOAD IS SIZED TO MATCH COOLING CAPACITY OF HEAT PUMP

| | .05 | .06 | .07 | .08 | .09 | .10 | .12 | .14 | .16 | |
|----|-----|-----|-----|-----|-----|-----|-----|-----|-----|--------------------------------------|
| \$ | 120 | 144 | 168 | 192 | 216 | 240 | 288 | 336 | 384 | <--ELECTRIC RATE \$/KWH |
| | | | | | | | | | | <--THEORETICAL AIR CONDITIONING COST |

THE ABOVE ANNUAL HEATING AND COOLING OPERATING COSTS ARE THEORETICAL ESTIMATES ONLY AND ARE PROVIDED FOR A COMMON BASIS OF COMPARISON BETWEEN VARIOUS TYPES OF HEATING AND COOLING SYSTEMS. ACTUAL VALUES MAY VARY DEPENDING ON ACTUAL WEATHER CONDITIONS AND INDIVIDUAL USAGE PATTERN.

BARD MANUFACTURING COMPANY
DUAL FUEL ADD-ON HEAT PUMP GUIDE TO ENERGY COST SAVINGS

REGION 4
 HEAT PUMP MODEL: OUTDOOR SOURCE
 RATED COOLING CAP.: BTUH (95) 30,000, SEER10.00
 RATED HEATING CAP.: BTUH (47) 20,000, COP(47) 3.00, HSPF 7.00 MIN. DR. REG IV
 FURNACE TYPE: FUEL OIL FURNACE EFFICIENCY 78.00 % AFUE

| HEAT LOSS BTUH | ELEC. COST \$/KWH | HEATING OIL COST - \$/GALLON | | | | | | | | | | | | | |
|----------------|-------------------|------------------------------|------|------|------|------|------|------|------|------|------|------|------|--|--|
| | | .70 | .80 | .90 | 1.00 | 1.10 | 1.20 | 1.30 | 1.40 | 1.50 | 1.60 | 1.70 | 1.80 | | |
| 30,000 | \$ | 332 | 383 | 428 | 479 | 524 | 575 | 620 | 671 | 716 | 767 | 812 | 863 | ---THEORETICAL HEATING COST * FURNACE ONLY | |
| .05 | \$ | 327 | 338 | 344 | 355 | 361 | 372 | 383 | 389 | 400 | 406 | 417 | 423 | THEORETICAL HEATING COST * FURN. + HEAT PUMP | |
| .06 | \$ | 383 | 394 | 400 | 411 | 417 | 428 | 440 | 445 | 457 | 462 | 473 | 479 | \$ PER YEAR | |
| .07 | \$ | 434 | 445 | 451 | 462 | 468 | 479 | 490 | 496 | 507 | 513 | 524 | 530 | | |
| .08 | \$ | 490 | 501 | 507 | 518 | 524 | 535 | 546 | 552 | 564 | 569 | 581 | 586 | | |
| .09 | \$ | 541 | 552 | 558 | 569 | 575 | 586 | 598 | 603 | 615 | 620 | 631 | 637 | | |
| .10 | \$ | 598 | 609 | 615 | 626 | 631 | 643 | 654 | 660 | 671 | 677 | 688 | 694 | | |
| .11 | \$ | 659 | 670 | 676 | 687 | 693 | 704 | 715 | 721 | 733 | 738 | 749 | 755 | | |
| .12 | \$ | 696 | 707 | 713 | 724 | 730 | 741 | 752 | 758 | 770 | 775 | 786 | 792 | BALANCE POINT 18 DEG.F. | |
| .14 | \$ | 806 | 817 | 823 | 834 | 840 | 851 | 862 | 868 | 880 | 885 | 896 | 902 | | |
| .16 | \$ | 914 | 925 | 931 | 942 | 947 | 959 | 970 | 976 | 987 | 993 | 1004 | 1010 | | |
| 35,000 | \$ | 389 | 445 | 502 | 558 | 615 | 671 | 727 | 784 | 835 | 891 | 947 | 1004 | ---THEORETICAL HEATING COST * FURNACE ONLY | |
| .05 | \$ | 378 | 394 | 406 | 423 | 440 | 457 | 473 | 490 | 502 | 519 | 536 | 552 | THEORETICAL HEATING COST * FURN. + HEAT PUMP | |
| .06 | \$ | 434 | 451 | 462 | 479 | 496 | 513 | 530 | 547 | 558 | 575 | 592 | 609 | \$ PER YEAR | |
| .07 | \$ | 485 | 502 | 513 | 530 | 547 | 564 | 581 | 598 | 609 | 626 | 643 | 660 | | |
| .08 | \$ | 536 | 552 | 564 | 581 | 598 | 615 | 631 | 648 | 660 | 677 | 694 | 710 | | |
| .09 | \$ | 592 | 609 | 620 | 637 | 654 | 671 | 688 | 705 | 716 | 733 | 750 | 767 | | |
| .10 | \$ | 643 | 660 | 671 | 688 | 705 | 722 | 739 | 756 | 767 | 784 | 801 | 818 | | |
| .12 | \$ | 750 | 767 | 773 | 795 | 812 | 829 | 846 | 863 | 874 | 891 | 908 | 925 | | |
| .14 | \$ | 857 | 874 | 885 | 902 | 919 | 936 | 953 | 970 | 981 | 998 | 1015 | 1032 | BALANCE POINT 22 DEG.F. | |
| .16 | \$ | 964 | 981 | 993 | 1010 | 1026 | 1043 | 1060 | 1077 | 1089 | 1106 | 1122 | 1139 | | |
| 40,000 | \$ | 445 | 507 | 575 | 637 | 699 | 767 | 829 | 891 | 959 | 1021 | 1083 | 1151 | ---THEORETICAL HEATING COST * FURNACE ONLY | |
| .05 | \$ | 428 | 445 | 462 | 479 | 502 | 519 | 536 | 552 | 569 | 592 | 609 | 626 | THEORETICAL HEATING COST * FURN. + HEAT PUMP | |
| .06 | \$ | 485 | 502 | 513 | 530 | 547 | 564 | 581 | 598 | 609 | 626 | 643 | 660 | \$ PER YEAR | |
| .07 | \$ | 547 | 564 | 575 | 592 | 609 | 626 | 643 | 660 | 671 | 688 | 705 | 722 | | |
| .08 | \$ | 603 | 620 | 631 | 648 | 665 | 681 | 700 | 717 | 728 | 744 | 761 | 778 | | |
| .09 | \$ | 655 | 672 | 683 | 699 | 716 | 733 | 750 | 767 | 779 | 806 | 823 | 840 | | |
| .10 | \$ | 722 | 739 | 756 | 773 | 795 | 812 | 829 | 846 | 863 | 885 | 902 | 919 | | |
| .12 | \$ | 846 | 863 | 880 | 897 | 919 | 936 | 953 | 970 | 981 | 1010 | 1026 | 1043 | | |
| .14 | \$ | 964 | 981 | 998 | 1015 | 1038 | 1055 | 1072 | 1089 | 1105 | 1128 | 1145 | 1162 | BALANCE POINT 25 DEG.F. | |
| .16 | \$ | 1083 | 1100 | 1117 | 1134 | 1156 | 1173 | 1190 | 1207 | 1224 | 1247 | 1263 | 1280 | | |
| 50,000 | \$ | 558 | 637 | 716 | 795 | 880 | 959 | 1038 | 1117 | 1196 | 1280 | 1359 | 1438 | ---THEORETICAL HEATING COST * FURNACE ONLY | |
| .05 | \$ | 524 | 558 | 592 | 626 | 660 | 694 | 727 | 761 | 795 | 829 | 863 | 897 | THEORETICAL HEATING COST * FURN. + HEAT PUMP | |
| .06 | \$ | 581 | 615 | 648 | 682 | 716 | 750 | 784 | 818 | 852 | 885 | 919 | 953 | \$ PER YEAR | |
| .07 | \$ | 643 | 677 | 710 | 744 | 778 | 812 | 846 | 880 | 914 | 947 | 981 | 1015 | | |
| .08 | \$ | 699 | 733 | 767 | 801 | 835 | 868 | 902 | 936 | 970 | 1004 | 1038 | 1072 | | |
| .09 | \$ | 756 | 789 | 823 | 857 | 891 | 925 | 959 | 993 | 1026 | 1060 | 1094 | 1128 | | |
| .10 | \$ | 812 | 846 | 880 | 914 | 947 | 981 | 1015 | 1049 | 1083 | 1117 | 1151 | 1184 | | |
| .12 | \$ | 931 | 964 | 998 | 1032 | 1066 | 1100 | 1134 | 1168 | 1201 | 1235 | 1269 | 1303 | | |
| .14 | \$ | 1043 | 1077 | 1111 | 1145 | 1179 | 1213 | 1247 | 1280 | 1314 | 1348 | 1382 | 1416 | BALANCE POINT 30 DEG.F. | |
| .16 | \$ | 1162 | 1196 | 1230 | 1263 | 1297 | 1331 | 1365 | 1399 | 1433 | 1467 | 1500 | 1534 | | |
| 60,000 | \$ | 671 | 767 | 863 | 959 | 1055 | 1151 | 1247 | 1342 | 1438 | 1534 | 1630 | 1726 | ---THEORETICAL HEATING COST * FURNACE ONLY | |
| .05 | \$ | 637 | 694 | 750 | 812 | 868 | 925 | 981 | 1038 | 1094 | 1156 | 1213 | 1269 | THEORETICAL HEATING COST * FURN. + HEAT PUMP | |
| .06 | \$ | 682 | 739 | 795 | 857 | 914 | 970 | 1026 | 1083 | 1139 | 1201 | 1258 | 1314 | \$ PER YEAR | |
| .07 | \$ | 747 | 784 | 840 | 902 | 959 | 1015 | 1072 | 1128 | 1184 | 1247 | 1303 | 1359 | | |
| .08 | \$ | 778 | 835 | 891 | 953 | 1010 | 1066 | 1122 | 1179 | 1235 | 1297 | 1354 | 1410 | | |
| .09 | \$ | 823 | 880 | 936 | 998 | 1055 | 1111 | 1168 | 1224 | 1280 | 1342 | 1399 | 1455 | | |
| .10 | \$ | 868 | 925 | 981 | 1043 | 1100 | 1156 | 1213 | 1269 | 1326 | 1388 | 1444 | 1500 | | |
| .12 | \$ | 964 | 1021 | 1077 | 1139 | 1196 | 1252 | 1309 | 1365 | 1421 | 1484 | 1540 | 1596 | | |
| .14 | \$ | 1060 | 1117 | 1173 | 1235 | 1292 | 1348 | 1405 | 1461 | 1517 | 1579 | 1636 | 1692 | BALANCE POINT 34 DEG.F. | |
| .16 | \$ | 1151 | 1207 | 1263 | 1326 | 1382 | 1438 | 1495 | 1551 | 1608 | 1670 | 1726 | 1783 | | |

ANNUAL AIR CONDITIONING COST WHEN COOLING LOAD IS SIZED TO MATCH COOLING CAPACITY OF HEAT PUMP

| | | | | | | | | | | |
|----|-----|-----|-----|-----|-----|-----|-----|-----|-----|---|
| | .05 | .06 | .07 | .08 | .09 | .10 | .12 | .14 | .16 | |
| \$ | 120 | 144 | 168 | 192 | 216 | 240 | 288 | 336 | 384 | ---ELECTRIC RATE \$/KWH ---THEORETICAL AIR CONDITIONING COST |

THE ABOVE ANNUAL HEATING AND COOLING OPERATING COSTS ARE THEORETICAL ESTIMATES ONLY AND ARE PROVIDED FOR A COMMON BASIS OF COMPARISON BETWEEN VARIOUS TYPES OF HEATING AND COOLING SYSTEMS. ACTUAL VALUES MAY VARY DEPENDING ON ACTUAL WEATHER CONDITIONS AND INDIVIDUAL USAGE PATTERN.

BAIRD MANUFACTURING COMPANY
DUAL FUEL ADD-ON HEAT PUMP GUIDE TO ENERGY COST SAVINGS

REGION 4
 HEAT PUMP MODEL: OUTDOOR CONDENSER
 SOUTHPOB/A37AD-A INDOOR A37AD-A
 RATED COOLING CAP.: BTUH (95) 30000 SEER10.00
 RATED HEATING CAP.: BTUH (47) 20000 COP(47) 3.00, RSPF 7.00 N.W. DIB REG IV
 BTUH (17) 17000 COP(17) 3.10
 FURNACE TYPE PROPANE GAS FURNACE EFFICIENCY 78.00 % AEU6

| HEAT LOSS BTUH | ELEC. COST \$/KWH | PROPANE GAS COST - \$/GALLON | | | | | | | | | | | | | |
|----------------|-------------------|------------------------------|------|------|------|------|------|------|------|------|------|------|------|---|--|
| | | .60 | .65 | .70 | .75 | .80 | .85 | .90 | .95 | 1.00 | 1.10 | 1.20 | 1.20 | | |
| 30,000 | \$ | 434 | 473 | 507 | 547 | 581 | 620 | 654 | 694 | 727 | 801 | 874 | 974 | ---THEORETICAL HEATING COST * FURNACE ONLY | |
| .05 | \$ | 344 | 355 | 361 | 366 | 372 | 383 | 389 | 394 | 400 | 417 | 428 | 428 | THEORETICAL HEATING COST * FURN.+ HEAT PUMP \$ PER YEAR | |
| .06 | \$ | 400 | 411 | 417 | 423 | 428 | 440 | 445 | 451 | 457 | 473 | 485 | 485 | | |
| .07 | \$ | 457 | 462 | 468 | 473 | 479 | 490 | 496 | 502 | 507 | 524 | 536 | 536 | | |
| .08 | \$ | 507 | 519 | 524 | 530 | 536 | 547 | 552 | 558 | 564 | 581 | 592 | 592 | | |
| .09 | \$ | 558 | 569 | 575 | 581 | 586 | 598 | 603 | 609 | 615 | 631 | 643 | 643 | | |
| .10 | \$ | 616 | 626 | 633 | 637 | 643 | 654 | 660 | 665 | 671 | 688 | 699 | 699 | | |
| .12 | \$ | 716 | 727 | 733 | 739 | 744 | 756 | 761 | 767 | 773 | 789 | 801 | 801 | | |
| .14 | \$ | 823 | 835 | 840 | 846 | 852 | 863 | 868 | 874 | 880 | 897 | 908 | 908 | | |
| .16 | \$ | 931 | 942 | 947 | 953 | 959 | 970 | 976 | 981 | 987 | 1004 | 1015 | 1015 | | BALANCE POINT 18 DEG.F. |
| 35,000 | \$ | 507 | 552 | 592 | 637 | 682 | 722 | 767 | 806 | 852 | 936 | 1021 | 1021 | | ---THEORETICAL HEATING COST * FURNACE ONLY |
| .05 | \$ | 411 | 423 | 434 | 445 | 457 | 473 | 485 | 496 | 507 | 530 | 558 | 558 | THEORETICAL HEATING COST * FURN.+ HEAT PUMP \$ PER YEAR | |
| .06 | \$ | 468 | 479 | 490 | 502 | 513 | 530 | 541 | 552 | 564 | 586 | 615 | 615 | | |
| .07 | \$ | 519 | 530 | 541 | 552 | 564 | 581 | 592 | 603 | 615 | 637 | 665 | 665 | | |
| .08 | \$ | 569 | 581 | 592 | 603 | 615 | 631 | 643 | 654 | 665 | 688 | 716 | 716 | | |
| .09 | \$ | 626 | 637 | 648 | 660 | 671 | 688 | 699 | 710 | 721 | 744 | 773 | 773 | | |
| .10 | \$ | 677 | 688 | 699 | 710 | 721 | 739 | 750 | 761 | 773 | 795 | 823 | 823 | | |
| .12 | \$ | 784 | 795 | 806 | 818 | 829 | 846 | 857 | 868 | 880 | 902 | 931 | 931 | | |
| .14 | \$ | 891 | 902 | 914 | 925 | 936 | 953 | 964 | 976 | 987 | 1010 | 1038 | 1038 | | |
| .16 | \$ | 998 | 1010 | 1021 | 1032 | 1043 | 1060 | 1072 | 1083 | 1094 | 1117 | 1145 | 1145 | | BALANCE POINT 22 DEG.F. |
| 40,000 | \$ | 581 | 631 | 682 | 727 | 778 | 829 | 874 | 925 | 976 | 1072 | 1168 | 1168 | | ---THEORETICAL HEATING COST * FURNACE ONLY |
| .05 | \$ | 468 | 479 | 490 | 507 | 519 | 536 | 547 | 564 | 575 | 603 | 631 | 631 | THEORETICAL HEATING COST * FURN.+ HEAT PUMP \$ PER YEAR | |
| .06 | \$ | 524 | 535 | 546 | 557 | 568 | 586 | 597 | 615 | 626 | 660 | 688 | 688 | | |
| .07 | \$ | 586 | 598 | 609 | 626 | 637 | 654 | 665 | 682 | 694 | 722 | 750 | 750 | | |
| .08 | \$ | 643 | 654 | 665 | 682 | 694 | 710 | 721 | 739 | 750 | 778 | 806 | 806 | | |
| .09 | \$ | 705 | 716 | 727 | 744 | 756 | 773 | 784 | 801 | 812 | 840 | 868 | 868 | | |
| .10 | \$ | 761 | 773 | 784 | 801 | 812 | 829 | 840 | 857 | 868 | 897 | 925 | 925 | | |
| .12 | \$ | 885 | 897 | 908 | 925 | 936 | 953 | 964 | 981 | 993 | 1021 | 1049 | 1049 | | |
| .14 | \$ | 1004 | 1015 | 1026 | 1043 | 1055 | 1072 | 1083 | 1100 | 1111 | 1139 | 1168 | 1168 | | |
| .16 | \$ | 1122 | 1134 | 1145 | 1162 | 1173 | 1190 | 1201 | 1218 | 1230 | 1258 | 1286 | 1286 | | BALANCE POINT 25 DEG.F. |
| 50,000 | \$ | 727 | 789 | 852 | 914 | 976 | 1032 | 1094 | 1156 | 1218 | 1337 | 1461 | 1461 | | ---THEORETICAL HEATING COST * FURNACE ONLY |
| .05 | \$ | 598 | 620 | 648 | 677 | 699 | 727 | 750 | 778 | 801 | 857 | 908 | 908 | THEORETICAL HEATING COST * FURN.+ HEAT PUMP \$ PER YEAR | |
| .06 | \$ | 654 | 677 | 705 | 733 | 756 | 784 | 806 | 835 | 857 | 914 | 964 | 964 | | |
| .07 | \$ | 716 | 739 | 767 | 795 | 818 | 846 | 868 | 897 | 919 | 976 | 1026 | 1026 | | |
| .08 | \$ | 773 | 795 | 823 | 852 | 874 | 902 | 925 | 953 | 976 | 1032 | 1083 | 1083 | | |
| .09 | \$ | 829 | 852 | 880 | 908 | 931 | 959 | 981 | 1010 | 1032 | 1089 | 1139 | 1139 | | |
| .10 | \$ | 885 | 908 | 936 | 964 | 987 | 1015 | 1038 | 1066 | 1089 | 1145 | 1196 | 1196 | | |
| .12 | \$ | 1004 | 1026 | 1055 | 1083 | 1105 | 1134 | 1156 | 1184 | 1207 | 1263 | 1314 | 1314 | | |
| .14 | \$ | 1117 | 1139 | 1168 | 1196 | 1218 | 1247 | 1269 | 1297 | 1320 | 1376 | 1427 | 1427 | | |
| .16 | \$ | 1235 | 1258 | 1286 | 1314 | 1337 | 1365 | 1388 | 1416 | 1438 | 1495 | 1546 | 1546 | | BALANCE POINT 30 DEG.F. |
| 60,000 | \$ | 874 | 947 | 1021 | 1094 | 1168 | 1241 | 1314 | 1388 | 1461 | 1608 | 1754 | 1754 | | ---THEORETICAL HEATING COST * FURNACE ONLY |
| .05 | \$ | 761 | 806 | 846 | 891 | 936 | 981 | 1021 | 1066 | 1111 | 1196 | 1286 | 1286 | THEORETICAL HEATING COST * FURN.+ HEAT PUMP \$ PER YEAR | |
| .06 | \$ | 806 | 852 | 891 | 936 | 981 | 1026 | 1066 | 1111 | 1156 | 1241 | 1331 | 1331 | | |
| .07 | \$ | 852 | 897 | 936 | 981 | 1026 | 1072 | 1111 | 1156 | 1201 | 1286 | 1376 | 1376 | | |
| .08 | \$ | 902 | 947 | 987 | 1032 | 1077 | 1122 | 1162 | 1207 | 1252 | 1337 | 1427 | 1427 | | |
| .09 | \$ | 947 | 993 | 1032 | 1077 | 1122 | 1168 | 1207 | 1252 | 1297 | 1382 | 1472 | 1472 | | |
| .10 | \$ | 993 | 1038 | 1077 | 1122 | 1168 | 1213 | 1252 | 1297 | 1342 | 1427 | 1517 | 1517 | | |
| .12 | \$ | 1089 | 1134 | 1173 | 1218 | 1263 | 1309 | 1348 | 1393 | 1438 | 1523 | 1613 | 1613 | | |
| .14 | \$ | 1184 | 1230 | 1269 | 1314 | 1359 | 1405 | 1444 | 1489 | 1534 | 1619 | 1709 | 1709 | | |
| .16 | \$ | 1275 | 1320 | 1359 | 1405 | 1450 | 1495 | 1534 | 1579 | 1625 | 1709 | 1799 | 1799 | | BALANCE POINT 34 DEG.F. |

ANNUAL AIR CONDITIONING COST WHEN COOLING LOAD IS SIZED TO MATCH COOLING CAPACITY OF HEAT PUMP

| | | | | | | | | | | |
|----|-----|-----|-----|-----|-----|-----|-----|-----|-----|--------------------------------------|
| \$ | .05 | .06 | .07 | .08 | .09 | .10 | .12 | .14 | .16 | ---ELECTRIC RATE \$/KWH |
| | 120 | 144 | 168 | 192 | 216 | 240 | 288 | 336 | 384 | ---THEORETICAL AIR CONDITIONING COST |

THE ABOVE ANNUAL HEATING AND COOLING OPERATING COSTS ARE THEORETICAL ESTIMATES ONLY AND ARE PROVIDED FOR A COMMON BASIS OF COMPARISON BETWEEN VARIOUS TYPES OF HEATING AND COOLING SYSTEMS. ACTUAL VALUES MAY VARY DEPENDING ON ACTUAL WEATHER CONDITIONS AND INDIVIDUAL USAGE PATTERN.

BARD MANUFACTURING COMPANY

DOAL FURE, ADD-ON HEAT PUMP GUIDE TO ENERGY COST SAVINGS

REGION 4
 HEAT PUMP MODEL: OUTDOOR 36UNP08 36UNP08/A36AQ-A INDOOR A36AQ-A
 ARI RATED COOLING CAP.: BTUH (95) 33000 SEER 8.69
 ARI RATED HEATING CAP.: BTUH (47) 33600 COP (47) 2.90, HSPF 6.30 MIN. DER REG 19
 FURNACE TYPE ELECTRIC FURNACE EFFICIENCY 100.00 % A20E

HEAT PUMP COST \$/KW
 BTUH

35,000 --- THEORETICAL ANNUAL HEATING COST ---
 HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

| | | | |
|-----|----|------|------|
| .05 | \$ | 434 | 885 |
| .06 | | 524 | 1060 |
| .07 | | 603 | 1241 |
| .08 | | 694 | 1416 |
| .09 | | 784 | 1596 |
| .10 | | 868 | 1771 |
| .12 | | 1043 | 2127 |
| .14 | | 1218 | 2482 |
| .16 | | 1388 | 2838 |

BALANCE POINT 19 DEG.F.

40,000 --- THEORETICAL ANNUAL HEATING COST ---
 HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

| | | | |
|-----|----|------|------|
| .05 | \$ | 502 | 1010 |
| .06 | | 603 | 1213 |
| .07 | | 699 | 1416 |
| .08 | | 801 | 1619 |
| .09 | | 897 | 1822 |
| .10 | | 998 | 2025 |
| .12 | | 1201 | 2431 |
| .14 | | 1399 | 2838 |
| .16 | | 1596 | 3244 |

BALANCE POINT 22 DEG.F.

50,000 --- THEORETICAL ANNUAL HEATING COST ---
 HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

| | | | |
|-----|----|------|------|
| .05 | \$ | 648 | 1263 |
| .06 | | 773 | 1517 |
| .07 | | 908 | 1771 |
| .08 | | 1032 | 2025 |
| .09 | | 1182 | 2279 |
| .10 | | 1297 | 2533 |
| .12 | | 1557 | 3041 |
| .14 | | 1811 | 3549 |
| .16 | | 2070 | 4057 |

BALANCE POINT 28 DEG.F.

60,000 --- THEORETICAL ANNUAL HEATING COST ---
 HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

| | | | |
|-----|----|------|------|
| .05 | \$ | 812 | 1517 |
| .06 | | 976 | 1822 |
| .07 | | 1145 | 2127 |
| .08 | | 1309 | 2431 |
| .09 | | 1467 | 2736 |
| .10 | | 1630 | 3041 |
| .12 | | 1957 | 3650 |
| .14 | | 2285 | 4260 |
| .16 | | 2606 | 4869 |

BALANCE POINT 33 DEG.F.

70,000 --- THEORETICAL ANNUAL HEATING COST ---
 HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

| | | | |
|-----|----|------|------|
| .05 | \$ | 1004 | 1771 |
| .06 | | 1201 | 2127 |
| .07 | | 1399 | 2482 |
| .08 | | 1608 | 2838 |
| .09 | | 1805 | 3193 |
| .10 | | 2003 | 3549 |
| .12 | | 2403 | 4260 |
| .14 | | 2810 | 4971 |
| .16 | | 3210 | 5682 |

BALANCE POINT 36 DEG.F.

ANNUAL AIR CONDITIONING COST WHEN COOLING LOAD IS SIZED TO MATCH COOLING CAPACITY OF HEAT PUMP

| | | | | | | | | | | |
|----|-----|-----|-----|-----|-----|-----|-----|-----|-----|---------------------------------------|
| | .05 | .06 | .07 | .08 | .09 | .10 | .12 | .14 | .16 | |
| \$ | 151 | 182 | 212 | 243 | 273 | 303 | 364 | 425 | 486 | <-- ELECTRIC RATE \$/KWH |
| | | | | | | | | | | <-- THEORETICAL AIR CONDITIONING COST |

THE ABOVE ANNUAL HEATING AND COOLING OPERATING COSTS ARE THEORETICAL ESTIMATES ONLY AND ARE PROVIDED FOR A COMMON BASIS OF COMPARISON BETWEEN VARIOUS TYPES OF HEATING AND COOLING SYSTEMS. ACTUAL VALUES MAY VARY DEPENDING ON ACTUAL WEATHER CONDITIONS AND INDIVIDUAL USAGE PATTERN.

BAIRD MANUFACTURING COMPANY

DUAL FUEL ADD-ON HEAT PUMP GUIDE TO ENERGY COST SAVINGS

REGION 4
 HEAT PUMP MODEL: OUTDOOR 36URP03 36URP03/A36AO-A INDOOR A36AO-A
 RATED COOLING CAP.: BTUH (95) 33000 SEER 8.69
 RATED HEATING CAP.: BTUH (47) 33800 COP (47) 2.90 HSPF 6.90 MIN. DHR REG IV
 FURNACE TYPE NATURAL GAS FURNACE EFFICIENCY 78.00 % AFUE

| HEAT LOADS BTUH | HEAT PUMP COST \$/KWH | NATURAL GAS COST - \$/THERM | | | | | | | | | | | | | |
|-----------------|-----------------------|-----------------------------|------|------|------|------|------|------|------|------|------|------|------|--|--|
| | | .35 | .40 | .45 | .50 | .55 | .60 | .65 | .70 | .75 | .80 | | .90 | 1.00 | |
| 35,000 | \$ | 270 | 310 | 344 | 383 | 423 | 462 | 502 | 541 | 581 | 620 | 694 | 773 | ←--THEORETICAL HEATING COST * FURNACE ONLY | |
| .05 | \$ | 383 | 389 | 400 | 406 | 411 | 417 | 428 | 434 | 440 | 445 | 462 | 479 | THEORETICAL HEATING COST * FURN. + HEAT PUMP | |
| .06 | \$ | 445 | 451 | 462 | 468 | 473 | 479 | 490 | 496 | 502 | 507 | 524 | 541 | \$ PER YEAR | |
| .07 | \$ | 513 | 519 | 530 | 536 | 541 | 547 | 558 | 564 | 569 | 575 | 592 | 609 | | |
| .08 | \$ | 581 | 586 | 598 | 603 | 609 | 615 | 625 | 631 | 637 | 643 | 660 | 677 | | |
| .09 | \$ | 648 | 654 | 665 | 671 | 677 | 682 | 694 | 699 | 705 | 710 | 727 | 744 | | |
| .10 | \$ | 710 | 716 | 727 | 733 | 739 | 744 | 755 | 761 | 767 | 773 | 789 | 806 | | |
| .12 | \$ | 846 | 852 | 863 | 868 | 874 | 880 | 891 | 897 | 902 | 908 | 924 | 941 | | |
| .14 | \$ | 976 | 981 | 993 | 998 | 1004 | 1010 | 1021 | 1026 | 1032 | 1038 | 1055 | 1072 | BALANCE POINT 19 DEG.F. | |
| .16 | \$ | 1111 | 1117 | 1128 | 1134 | 1139 | 1145 | 1156 | 1162 | 1168 | 1173 | 1190 | 1207 | | |
| 40,000 | \$ | 310 | 349 | 394 | 440 | 485 | 530 | 575 | 620 | 665 | 705 | 795 | 885 | ←--THEORETICAL HEATING COST * FURNACE ONLY | |
| .05 | \$ | 417 | 428 | 440 | 451 | 468 | 479 | 490 | 502 | 519 | 530 | 552 | 581 | THEORETICAL HEATING COST * FURN. + HEAT PUMP | |
| .06 | \$ | 479 | 490 | 502 | 513 | 530 | 541 | 552 | 564 | 581 | 592 | 615 | 643 | \$ PER YEAR | |
| .07 | \$ | 547 | 558 | 569 | 581 | 598 | 609 | 620 | 631 | 648 | 660 | 682 | 710 | | |
| .08 | \$ | 615 | 626 | 637 | 648 | 665 | 677 | 688 | 699 | 716 | 727 | 750 | 778 | | |
| .09 | \$ | 677 | 688 | 699 | 710 | 727 | 739 | 750 | 761 | 778 | 789 | 812 | 840 | | |
| .10 | \$ | 744 | 755 | 767 | 778 | 794 | 806 | 818 | 829 | 846 | 857 | 880 | 908 | | |
| .12 | \$ | 874 | 885 | 897 | 908 | 925 | 936 | 947 | 959 | 976 | 987 | 1010 | 1038 | BALANCE POINT 22 DEG.F. | |
| .14 | \$ | 1004 | 1015 | 1026 | 1038 | 1055 | 1066 | 1077 | 1089 | 1105 | 1117 | 1139 | 1168 | | |
| .16 | \$ | 1134 | 1145 | 1156 | 1168 | 1184 | 1196 | 1207 | 1218 | 1235 | 1247 | 1269 | 1297 | | |
| 50,000 | \$ | 383 | 440 | 496 | 552 | 609 | 665 | 716 | 773 | 829 | 885 | 998 | 1105 | ←--THEORETICAL HEATING COST * FURNACE ONLY | |
| .05 | \$ | 485 | 507 | 530 | 558 | 581 | 603 | 626 | 648 | 671 | 699 | 744 | 789 | THEORETICAL HEATING COST * FURN. + HEAT PUMP | |
| .06 | \$ | 547 | 569 | 592 | 620 | 643 | 665 | 688 | 710 | 733 | 761 | 806 | 852 | \$ PER YEAR | |
| .07 | \$ | 609 | 631 | 654 | 682 | 705 | 727 | 750 | 773 | 796 | 823 | 868 | 914 | | |
| .08 | \$ | 671 | 694 | 716 | 744 | 767 | 789 | 812 | 835 | 857 | 885 | 931 | 976 | | |
| .09 | \$ | 733 | 761 | 784 | 812 | 835 | 857 | 880 | 902 | 925 | 953 | 998 | 1043 | | |
| .10 | \$ | 801 | 823 | 846 | 874 | 897 | 919 | 942 | 964 | 987 | 1015 | 1060 | 1105 | | |
| .12 | \$ | 931 | 953 | 976 | 1004 | 1026 | 1049 | 1072 | 1094 | 1117 | 1145 | 1190 | 1235 | BALANCE POINT 28 DEG.F. | |
| .14 | \$ | 1055 | 1077 | 1100 | 1128 | 1151 | 1173 | 1196 | 1218 | 1241 | 1269 | 1314 | 1359 | | |
| .16 | \$ | 1184 | 1207 | 1230 | 1258 | 1280 | 1303 | 1326 | 1348 | 1371 | 1399 | 1444 | 1489 | | |
| 60,000 | \$ | 462 | 530 | 598 | 665 | 727 | 795 | 863 | 931 | 998 | 1060 | 1196 | 1331 | ←--THEORETICAL HEATING COST * FURNACE ONLY | |
| .05 | \$ | 536 | 575 | 615 | 654 | 699 | 739 | 778 | 818 | 857 | 897 | 976 | 1055 | THEORETICAL HEATING COST * FURN. + HEAT PUMP | |
| .06 | \$ | 598 | 626 | 665 | 705 | 750 | 789 | 829 | 868 | 908 | 947 | 1026 | 1105 | \$ PER YEAR | |
| .07 | \$ | 663 | 689 | 722 | 761 | 806 | 846 | 885 | 925 | 964 | 1004 | 1083 | 1162 | | |
| .08 | \$ | 694 | 733 | 773 | 812 | 857 | 897 | 936 | 976 | 1015 | 1055 | 1134 | 1213 | | |
| .09 | \$ | 744 | 784 | 823 | 863 | 908 | 947 | 987 | 1026 | 1066 | 1105 | 1184 | 1263 | | |
| .10 | \$ | 795 | 835 | 874 | 914 | 959 | 998 | 1038 | 1077 | 1117 | 1156 | 1235 | 1314 | | |
| .12 | \$ | 902 | 944 | 981 | 1021 | 1066 | 1105 | 1145 | 1184 | 1224 | 1263 | 1342 | 1421 | | |
| .14 | \$ | 1004 | 1043 | 1083 | 1122 | 1168 | 1207 | 1247 | 1286 | 1326 | 1365 | 1444 | 1523 | BALANCE POINT 33 DEG.F. | |
| .16 | \$ | 1111 | 1151 | 1190 | 1230 | 1275 | 1314 | 1354 | 1393 | 1433 | 1472 | 1551 | 1630 | | |
| 70,000 | \$ | 541 | 620 | 694 | 773 | 852 | 931 | 1010 | 1083 | 1162 | 1241 | 1393 | 1551 | ←--THEORETICAL HEATING COST * FURNACE ONLY | |
| .05 | \$ | 626 | 671 | 716 | 761 | 806 | 857 | 902 | 947 | 993 | 1043 | 1134 | 1224 | THEORETICAL HEATING COST * FURN. + HEAT PUMP | |
| .06 | \$ | 682 | 717 | 773 | 818 | 863 | 914 | 959 | 1004 | 1049 | 1100 | 1190 | 1280 | \$ PER YEAR | |
| .07 | \$ | 744 | 789 | 835 | 880 | 925 | 976 | 1021 | 1066 | 1111 | 1162 | 1252 | 1342 | | |
| .08 | \$ | 801 | 846 | 891 | 936 | 981 | 1032 | 1077 | 1122 | 1168 | 1218 | 1309 | 1399 | | |
| .09 | \$ | 863 | 908 | 953 | 998 | 1043 | 1094 | 1139 | 1184 | 1230 | 1280 | 1371 | 1461 | | |
| .10 | \$ | 919 | 964 | 1010 | 1055 | 1100 | 1151 | 1196 | 1241 | 1286 | 1337 | 1427 | 1517 | | |
| .12 | \$ | 1038 | 1083 | 1128 | 1173 | 1218 | 1269 | 1314 | 1359 | 1405 | 1455 | 1546 | 1636 | | |
| .14 | \$ | 1156 | 1201 | 1247 | 1292 | 1337 | 1388 | 1433 | 1478 | 1523 | 1574 | 1664 | 1754 | BALANCE POINT 36 DEG.F. | |
| .16 | \$ | 1275 | 1320 | 1365 | 1410 | 1455 | 1506 | 1551 | 1596 | 1642 | 1692 | 1783 | 1873 | | |

ANNUAL AIR CONDITIONING COST WHEN COOLING LOAD IS SIZED TO MATCH COOLING CAPACITY OF HEAT PUMP

| | .05 | .06 | .07 | .08 | .09 | .10 | .12 | .14 | .16 | |
|----|-----|-----|-----|-----|-----|-----|-----|-----|-----|--------------------------------------|
| \$ | 151 | 182 | 212 | 243 | 273 | 303 | 364 | 425 | 486 | ←--ELECTRIC RATE \$/KWH |
| | | | | | | | | | | ←--THEORETICAL AIR CONDITIONING COST |

THE ABOVE ANNUAL HEATING AND COOLING OPERATING COSTS ARE THEORETICAL ESTIMATES ONLY AND ARE PROVIDED FOR A COMMON BASIS OF COMPARISON BETWEEN VARIOUS TYPES OF HEATING AND COOLING SYSTEMS. ACTUAL VALUES MAY VARY DEPENDING ON ACTUAL WEATHER CONDITIONS AND INDIVIDUAL USAGE PATTERN.

BAIRD MANUFACTURING COMPANY

DUAL FUEL ADD-ON HEAT PUMP GUIDE TO ENERGY COST SAVINGS

REGION 4
 HEAT PUMP MODEL: OUTDOOR 36UNP08 36UNP08/A36AO-A INDOOR A36AO-A
 RATED COOLING CAP.: BTUH(95) 33000 SEER 8.49
 RATED HEATING CAP.: BTUH(47) 33000 COP(47) 2.50 HSPF 8.90 MIN.DHR REG IV
 BTUH(17) 20000 COP(17) 2.20
 FURNACE TYPE FUEL OIL FURNACE EFFICIENCY 78.00 % AFUE

| HEAT LOSS BTUH | ELEC. COST \$/KWH | HEATING OIL COST - \$/GALLON | | | | | | | | | | | | | |
|----------------|-------------------|------------------------------|------|------|------|------|------|------|------|------|------|------|------|---|--|
| | | .70 | .80 | .90 | 1.00 | 1.10 | 1.20 | 1.30 | 1.40 | 1.50 | 1.60 | 1.70 | 1.80 | | |
| 35,000 | \$ | 389 | 445 | 502 | 558 | 615 | 671 | 727 | 784 | 835 | 891 | 947 | 1004 | ←--THEORETICAL HEATING COST * FURNACE ONLY | |
| .05 | \$ | 406 | 417 | 428 | 434 | 445 | 457 | 468 | 479 | 490 | 502 | 507 | 519 | THEORETICAL HEATING COST * FURN.+ HEAT PUMP | |
| .06 | \$ | 468 | 479 | 490 | 496 | 507 | 519 | 530 | 541 | 552 | 564 | 569 | 581 | \$ PER YEAR | |
| .07 | \$ | 530 | 541 | 552 | 558 | 570 | 581 | 592 | 603 | 615 | 626 | 631 | 643 | | |
| .08 | \$ | 603 | 615 | 626 | 631 | 643 | 654 | 665 | 677 | 688 | 699 | 705 | 716 | | |
| .09 | \$ | 671 | 682 | 694 | 699 | 710 | 722 | 733 | 744 | 756 | 767 | 773 | 784 | | |
| .10 | \$ | 733 | 744 | 756 | 761 | 773 | 784 | 795 | 806 | 818 | 829 | 835 | 846 | | |
| .12 | \$ | 868 | 880 | 891 | 897 | 908 | 919 | 931 | 942 | 953 | 964 | 970 | 981 | | |
| .14 | \$ | 998 | 1010 | 1021 | 1026 | 1038 | 1049 | 1060 | 1072 | 1083 | 1094 | 1100 | 1111 | BALANCE POINT 19 DEG.F. | |
| .16 | \$ | 1134 | 1145 | 1156 | 1162 | 1173 | 1184 | 1196 | 1207 | 1218 | 1230 | 1235 | 1247 | | |
| 40,000 | \$ | 445 | 507 | 575 | 637 | 699 | 767 | 829 | 891 | 959 | 1021 | 1083 | 1151 | ←--THEORETICAL HEATING COST * FURNACE ONLY | |
| .05 | \$ | 457 | 473 | 490 | 501 | 530 | 547 | 564 | 581 | 598 | 620 | 637 | 654 | THEORETICAL HEATING COST * FURN.+ HEAT PUMP | |
| .06 | \$ | 519 | 536 | 552 | 569 | 592 | 609 | 626 | 643 | 660 | 682 | 699 | 716 | \$ PER YEAR | |
| .07 | \$ | 586 | 603 | 620 | 637 | 660 | 677 | 694 | 710 | 727 | 750 | 767 | 784 | | |
| .08 | \$ | 654 | 671 | 688 | 705 | 727 | 744 | 761 | 778 | 795 | 818 | 835 | 852 | | |
| .09 | \$ | 716 | 733 | 750 | 767 | 789 | 806 | 823 | 840 | 857 | 880 | 897 | 914 | | |
| .10 | \$ | 784 | 801 | 818 | 835 | 857 | 874 | 891 | 908 | 925 | 947 | 964 | 981 | | |
| .12 | \$ | 911 | 931 | 947 | 964 | 987 | 1004 | 1021 | 1038 | 1055 | 1071 | 1094 | 1111 | | |
| .14 | \$ | 1043 | 1080 | 1077 | 1094 | 1117 | 1134 | 1151 | 1168 | 1184 | 1207 | 1224 | 1241 | BALANCE POINT 22 DEG.F. | |
| .16 | \$ | 1173 | 1190 | 1207 | 1224 | 1247 | 1263 | 1280 | 1297 | 1314 | 1337 | 1354 | 1371 | | |
| 50,000 | \$ | 558 | 637 | 716 | 795 | 880 | 959 | 1038 | 1117 | 1196 | 1280 | 1359 | 1438 | ←--THEORETICAL HEATING COST * FURNACE ONLY | |
| .05 | \$ | 558 | 592 | 626 | 660 | 694 | 727 | 761 | 795 | 829 | 863 | 897 | 931 | THEORETICAL HEATING COST * FURN.+ HEAT PUMP | |
| .06 | \$ | 620 | 654 | 688 | 722 | 756 | 789 | 823 | 857 | 891 | 925 | 959 | 993 | \$ PER YEAR | |
| .07 | \$ | 682 | 716 | 750 | 784 | 818 | 852 | 885 | 919 | 953 | 987 | 1021 | 1055 | | |
| .08 | \$ | 744 | 778 | 812 | 846 | 880 | 914 | 947 | 981 | 1015 | 1049 | 1083 | 1117 | | |
| .09 | \$ | 812 | 846 | 880 | 914 | 947 | 981 | 1015 | 1049 | 1083 | 1117 | 1151 | 1184 | | |
| .10 | \$ | 874 | 908 | 942 | 976 | 1010 | 1043 | 1077 | 1111 | 1145 | 1179 | 1213 | 1247 | | |
| .12 | \$ | 1004 | 1038 | 1072 | 1106 | 1139 | 1173 | 1207 | 1241 | 1275 | 1309 | 1342 | 1376 | | |
| .14 | \$ | 1128 | 1162 | 1196 | 1230 | 1263 | 1297 | 1331 | 1365 | 1399 | 1433 | 1467 | 1500 | BALANCE POINT 28 DEG.F. | |
| .16 | \$ | 1258 | 1292 | 1326 | 1359 | 1393 | 1427 | 1461 | 1495 | 1529 | 1563 | 1596 | 1630 | | |
| 60,000 | \$ | 671 | 767 | 863 | 959 | 1055 | 1151 | 1247 | 1342 | 1438 | 1534 | 1630 | 1726 | ←--THEORETICAL HEATING COST * FURNACE ONLY | |
| .05 | \$ | 680 | 716 | 773 | 835 | 891 | 947 | 1004 | 1060 | 1117 | 1179 | 1235 | 1292 | THEORETICAL HEATING COST * FURN.+ HEAT PUMP | |
| .06 | \$ | 710 | 767 | 823 | 885 | 942 | 998 | 1055 | 1111 | 1168 | 1224 | 1286 | 1342 | \$ PER YEAR | |
| .07 | \$ | 767 | 823 | 880 | 942 | 998 | 1055 | 1111 | 1168 | 1224 | 1286 | 1342 | 1399 | | |
| .08 | \$ | 818 | 874 | 931 | 991 | 1049 | 1105 | 1162 | 1218 | 1275 | 1337 | 1393 | 1450 | | |
| .09 | \$ | 868 | 925 | 981 | 1043 | 1100 | 1156 | 1213 | 1269 | 1326 | 1388 | 1444 | 1500 | | |
| .10 | \$ | 919 | 976 | 1032 | 1094 | 1151 | 1207 | 1263 | 1320 | 1376 | 1438 | 1495 | 1551 | | |
| .12 | \$ | 1026 | 1083 | 1139 | 1201 | 1258 | 1314 | 1371 | 1427 | 1484 | 1546 | 1602 | 1658 | | |
| .14 | \$ | 1128 | 1184 | 1241 | 1303 | 1359 | 1416 | 1472 | 1529 | 1585 | 1647 | 1704 | 1760 | BALANCE POINT 33 DEG.F. | |
| .16 | \$ | 1235 | 1292 | 1348 | 1410 | 1467 | 1523 | 1579 | 1636 | 1692 | 1754 | 1811 | 1867 | | |
| 70,000 | \$ | 784 | 891 | 1004 | 1117 | 1230 | 1342 | 1455 | 1568 | 1675 | 1788 | 1901 | 2014 | ←--THEORETICAL HEATING COST * FURNACE ONLY | |
| .05 | \$ | 767 | 835 | 902 | 970 | 1032 | 1100 | 1168 | 1235 | 1303 | 1371 | 1438 | 1500 | THEORETICAL HEATING COST * FURN.+ HEAT PUMP | |
| .06 | \$ | 823 | 891 | 959 | 1026 | 1089 | 1156 | 1224 | 1292 | 1359 | 1427 | 1495 | 1557 | \$ PER YEAR | |
| .07 | \$ | 885 | 953 | 1021 | 1089 | 1151 | 1218 | 1286 | 1354 | 1421 | 1489 | 1557 | 1619 | | |
| .08 | \$ | 942 | 1010 | 1077 | 1145 | 1207 | 1275 | 1342 | 1410 | 1478 | 1546 | 1613 | 1675 | | |
| .09 | \$ | 1004 | 1072 | 1139 | 1207 | 1269 | 1337 | 1405 | 1472 | 1540 | 1608 | 1675 | 1737 | | |
| .10 | \$ | 1060 | 1128 | 1196 | 1263 | 1326 | 1393 | 1461 | 1529 | 1596 | 1664 | 1732 | 1794 | | |
| .12 | \$ | 1179 | 1247 | 1314 | 1382 | 1444 | 1512 | 1579 | 1647 | 1715 | 1783 | 1850 | 1912 | | |
| .14 | \$ | 1297 | 1365 | 1433 | 1500 | 1563 | 1630 | 1698 | 1766 | 1833 | 1901 | 1969 | 2031 | BALANCE POINT 36 DEG.F. | |
| .16 | \$ | 1416 | 1484 | 1551 | 1619 | 1681 | 1749 | 1816 | 1884 | 1952 | 2020 | 2087 | 2149 | | |

ANNUAL AIR CONDITIONING COST WHEN COOLING LOAD IS SIZED TO MATCH COOLING CAPACITY OF HEAT PUMP

| | .05 | .06 | .07 | .08 | .09 | .10 | .12 | .14 | .16 | ←--ELECTRIC RATE \$/KWH |
|----|-----|-----|-----|-----|-----|-----|-----|-----|-----|--------------------------------------|
| \$ | 151 | 182 | 212 | 243 | 273 | 303 | 364 | 425 | 486 | ←--THEORETICAL AIR CONDITIONING COST |

THE ABOVE ANNUAL HEATING AND COOLING OPERATING COSTS ARE THEORETICAL ESTIMATES ONLY AND ARE PROVIDED FOR A COMMON BASIS OF COMPARISON BETWEEN VARIOUS TYPES OF HEATING AND COOLING SYSTEMS. ACTUAL VALUES MAY VARY DEPENDING ON ACTUAL WEATHER CONDITIONS AND INDIVIDUAL USAGE PATTERN.

BARD MANUFACTURING COMPANY
DUAL FUEL ADD-ON HEAT PUMP GUIDE TO ENERGY COST SAVINGS

REGION 4
 HEAT PUMP MODEL: OUTDOOR 36URPQB 36URPQB/A36AQ-A INDOOR A36AQ-A
 AIR RATED COOLING CAP.: BTUH (95) 30000 SHR 8.02
 AIR RATED HEATING CAP.: BTUH (47) 30000 COP (17) 2.90 HSPF 6.90 MIN. OHR DEG IV
 FURNACE TYPE PROPANE GAS FURNACE EFFICIENCY 78.00 % AFUE

| HEAT PUMP BTUH | HEAT COST \$/KWH | PROPANE GAS COST - \$/GALLON | | | | | | | | | | | | | |
|----------------|------------------|------------------------------|------|------|------|------|------|------|------|------|------|------|------|--|--|
| | | .60 | .65 | .70 | .75 | .80 | .85 | .90 | .95 | 1.00 | 1.10 | 1.20 | | 1.20 | |
| 35,000 | \$ | 507 | 552 | 592 | 637 | 682 | 722 | 767 | 806 | 852 | 906 | 1021 | 1021 | ←--THEORETICAL HEATING COST * FURNACE ONLY | |
| .05 | \$ | 438 | 434 | 445 | 451 | 462 | 468 | 473 | 485 | 490 | 507 | 524 | 524 | THEORETICAL HEATING COST * FURN. + HEAT PUMP \$ PER YEAR | |
| .06 | \$ | 490 | 496 | 507 | 513 | 524 | 530 | 536 | 547 | 552 | 569 | 586 | 586 | | |
| .07 | \$ | 542 | 548 | 559 | 565 | 576 | 582 | 588 | 600 | 605 | 622 | 639 | 639 | | |
| .08 | \$ | 594 | 600 | 611 | 617 | 628 | 634 | 640 | 652 | 657 | 674 | 691 | 691 | | |
| .09 | \$ | 646 | 652 | 663 | 669 | 680 | 686 | 692 | 704 | 709 | 726 | 743 | 743 | | |
| .10 | \$ | 698 | 704 | 715 | 721 | 732 | 738 | 744 | 756 | 761 | 778 | 795 | 795 | | |
| .12 | \$ | 756 | 762 | 773 | 779 | 790 | 796 | 802 | 814 | 819 | 836 | 853 | 853 | | |
| .14 | \$ | 814 | 820 | 831 | 837 | 848 | 854 | 860 | 872 | 877 | 894 | 911 | 911 | | |
| .16 | \$ | 1021 | 1027 | 1038 | 1044 | 1055 | 1061 | 1067 | 1079 | 1084 | 1101 | 1118 | 1118 | BALANCE POINT 19 DEG.F. | |
| | \$ | 1156 | 1162 | 1173 | 1179 | 1190 | 1196 | 1201 | 1213 | 1218 | 1235 | 1252 | 1252 | | |
| 40,000 | \$ | 581 | 631 | 682 | 727 | 778 | 829 | 874 | 925 | 976 | 1072 | 1168 | 1168 | ←--THEORETICAL HEATING COST * FURNACE ONLY | |
| .05 | \$ | 496 | 507 | 519 | 526 | 537 | 544 | 550 | 562 | 567 | 584 | 601 | 601 | THEORETICAL HEATING COST * FURN. + HEAT PUMP \$ PER YEAR | |
| .06 | \$ | 558 | 569 | 581 | 587 | 598 | 604 | 610 | 622 | 627 | 644 | 661 | 661 | | |
| .07 | \$ | 620 | 631 | 643 | 649 | 660 | 666 | 672 | 684 | 689 | 706 | 723 | 723 | | |
| .08 | \$ | 682 | 693 | 705 | 711 | 722 | 728 | 734 | 746 | 751 | 768 | 785 | 785 | | |
| .09 | \$ | 744 | 755 | 767 | 773 | 784 | 790 | 796 | 808 | 813 | 830 | 847 | 847 | | |
| .10 | \$ | 806 | 817 | 829 | 835 | 846 | 852 | 858 | 870 | 875 | 892 | 909 | 909 | | |
| .12 | \$ | 868 | 879 | 891 | 897 | 908 | 914 | 920 | 932 | 937 | 954 | 971 | 971 | | |
| .14 | \$ | 930 | 941 | 953 | 959 | 970 | 976 | 982 | 994 | 999 | 1016 | 1033 | 1033 | | |
| .16 | \$ | 1213 | 1219 | 1230 | 1236 | 1247 | 1253 | 1259 | 1271 | 1276 | 1293 | 1310 | 1310 | BALANCE POINT 22 DEG.F. | |
| | \$ | 1376 | 1382 | 1393 | 1399 | 1410 | 1416 | 1422 | 1434 | 1439 | 1456 | 1473 | 1473 | | |
| 50,000 | \$ | 727 | 789 | 852 | 914 | 976 | 1032 | 1094 | 1156 | 1218 | 1337 | 1461 | 1461 | ←--THEORETICAL HEATING COST * FURNACE ONLY | |
| .05 | \$ | 631 | 654 | 682 | 710 | 733 | 761 | 784 | 812 | 835 | 891 | 942 | 942 | THEORETICAL HEATING COST * FURN. + HEAT PUMP \$ PER YEAR | |
| .06 | \$ | 694 | 717 | 744 | 773 | 796 | 824 | 847 | 874 | 897 | 953 | 1004 | 1004 | | |
| .07 | \$ | 756 | 779 | 806 | 835 | 858 | 886 | 909 | 936 | 959 | 1015 | 1066 | 1066 | | |
| .08 | \$ | 818 | 841 | 868 | 897 | 920 | 947 | 970 | 998 | 1021 | 1077 | 1128 | 1128 | | |
| .09 | \$ | 880 | 903 | 930 | 959 | 982 | 1009 | 1032 | 1060 | 1083 | 1139 | 1190 | 1190 | | |
| .10 | \$ | 942 | 965 | 992 | 1021 | 1044 | 1071 | 1100 | 1123 | 1151 | 1207 | 1258 | 1258 | | |
| .12 | \$ | 1004 | 1027 | 1054 | 1083 | 1106 | 1133 | 1160 | 1183 | 1211 | 1267 | 1318 | 1318 | | |
| .14 | \$ | 1066 | 1089 | 1116 | 1145 | 1168 | 1195 | 1222 | 1245 | 1273 | 1329 | 1380 | 1380 | | |
| .16 | \$ | 1331 | 1354 | 1382 | 1410 | 1433 | 1461 | 1484 | 1512 | 1534 | 1591 | 1642 | 1642 | BALANCE POINT 28 DEG.F. | |
| | \$ | 1594 | 1617 | 1645 | 1673 | 1696 | 1724 | 1747 | 1775 | 1803 | 1860 | 1911 | 1911 | | |
| 60,000 | \$ | 874 | 947 | 1021 | 1094 | 1168 | 1241 | 1314 | 1388 | 1461 | 1608 | 1754 | 1754 | ←--THEORETICAL HEATING COST * FURNACE ONLY | |
| .05 | \$ | 784 | 829 | 868 | 914 | 959 | 1004 | 1043 | 1089 | 1134 | 1218 | 1309 | 1309 | THEORETICAL HEATING COST * FURN. + HEAT PUMP \$ PER YEAR | |
| .06 | \$ | 835 | 880 | 919 | 964 | 1010 | 1055 | 1094 | 1139 | 1184 | 1269 | 1359 | 1359 | | |
| .07 | \$ | 891 | 936 | 976 | 1021 | 1066 | 1111 | 1157 | 1202 | 1247 | 1332 | 1423 | 1423 | | |
| .08 | \$ | 942 | 987 | 1026 | 1071 | 1117 | 1162 | 1207 | 1252 | 1297 | 1382 | 1473 | 1473 | | |
| .09 | \$ | 993 | 1038 | 1077 | 1122 | 1168 | 1213 | 1258 | 1297 | 1342 | 1427 | 1517 | 1517 | | |
| .10 | \$ | 1043 | 1089 | 1128 | 1173 | 1219 | 1263 | 1303 | 1348 | 1388 | 1473 | 1563 | 1563 | | |
| .12 | \$ | 1105 | 1151 | 1190 | 1235 | 1280 | 1326 | 1371 | 1410 | 1455 | 1540 | 1630 | 1630 | | |
| .14 | \$ | 1252 | 1297 | 1337 | 1382 | 1427 | 1472 | 1512 | 1557 | 1602 | 1687 | 1777 | 1777 | | |
| .16 | \$ | 1359 | 1405 | 1444 | 1489 | 1534 | 1579 | 1619 | 1664 | 1709 | 1794 | 1884 | 1884 | BALANCE POINT 33 DEG.F. | |
| | \$ | 1884 | 1929 | 1968 | 2013 | 2058 | 2103 | 2143 | 2188 | 2233 | 2318 | 2408 | 2408 | | |
| 70,000 | \$ | 1021 | 1105 | 1190 | 1280 | 1365 | 1450 | 1534 | 1619 | 1704 | 1878 | 2048 | 2048 | ←--THEORETICAL HEATING COST * FURNACE ONLY | |
| .05 | \$ | 908 | 959 | 1010 | 1066 | 1117 | 1168 | 1218 | 1269 | 1320 | 1421 | 1523 | 1523 | THEORETICAL HEATING COST * FURN. + HEAT PUMP \$ PER YEAR | |
| .06 | \$ | 964 | 1015 | 1066 | 1122 | 1173 | 1224 | 1275 | 1326 | 1377 | 1478 | 1580 | 1580 | | |
| .07 | \$ | 1026 | 1077 | 1128 | 1184 | 1235 | 1286 | 1337 | 1388 | 1439 | 1540 | 1642 | 1642 | | |
| .08 | \$ | 1083 | 1134 | 1184 | 1241 | 1292 | 1342 | 1393 | 1444 | 1495 | 1596 | 1698 | 1698 | | |
| .09 | \$ | 1145 | 1196 | 1247 | 1303 | 1354 | 1405 | 1455 | 1506 | 1557 | 1658 | 1760 | 1760 | | |
| .10 | \$ | 1201 | 1252 | 1303 | 1359 | 1410 | 1461 | 1512 | 1563 | 1614 | 1715 | 1816 | 1816 | | |
| .12 | \$ | 1320 | 1371 | 1421 | 1478 | 1529 | 1579 | 1630 | 1681 | 1732 | 1833 | 1935 | 1935 | | |
| .14 | \$ | 1438 | 1489 | 1540 | 1591 | 1642 | 1693 | 1744 | 1795 | 1846 | 1947 | 2048 | 2048 | | |
| .16 | \$ | 1557 | 1608 | 1658 | 1715 | 1766 | 1816 | 1867 | 1918 | 1969 | 2070 | 2172 | 2172 | BALANCE POINT 36 DEG.F. | |
| | \$ | 2172 | 2223 | 2274 | 2325 | 2376 | 2427 | 2478 | 2529 | 2580 | 2681 | 2783 | 2783 | | |

ANNUAL AIR CONDITIONING COST WHEN COOLING LOAD IS SIZED TO MATCH COOLING CAPACITY OF HEAT PUMP
 \$ 05 06 07 08 09 10 12 14 16
 ←--ELECTRIC RATE \$/KWH
 ←--THEORETICAL AIR CONDITIONING COST

THE ABOVE ANNUAL HEATING AND COOLING OPERATING COSTS ARE THEORETICAL ESTIMATES ONLY AND ARE PROVIDED FOR A COMMON BASIS OF COMPARISON BETWEEN VARIOUS TYPES OF HEATING AND COOLING SYSTEMS. ACTUAL VALUES MAY VARY DEPENDING ON ACTUAL WEATHER CONDITIONS AND INDIVIDUAL USAGE PATTERN.

BAIRD MANUFACTURING COMPANY

DUAL FUEL AID-ON HEAT PUMP GUIDE TO ENERGY COST SAVINGS

REGION 4
 HEAT PUMP MODEL: OUTDOOR 36URP08 36URP08/A37A0-A INDOOR A37A0-A
 ARI RATED COOLING CAP.: BTUH (95) 36000 SEER10.00
 ARI RATED HEATING CAP.: BTUH (47) 36000 COP(47) 3.10, HSPF 7.20 N.W.D.H.R. REG IV
 BTUH (17) 21000 COP(17) 2.20
 FURNACE TYPE ELECTRIC FURNACE EFFICIENCY 100.00 % A.E.U.B.

HEAT LOSS \$/YR
 BTUH

ELEC. COST \$/KWH

35,000

--- THEORETICAL ANNUAL HEATING COST ---
 HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

| | | |
|-----|------|------|
| .05 | 394 | 885 |
| .06 | 473 | 1060 |
| .07 | 552 | 1241 |
| .08 | 631 | 1416 |
| .09 | 710 | 1596 |
| .10 | 789 | 1771 |
| .11 | 868 | 1947 |
| .12 | 947 | 2127 |
| .13 | 1026 | 2302 |
| .14 | 1105 | 2482 |
| .15 | 1184 | 2658 |
| .16 | 1263 | 2838 |

BALANCE POINT 17 DEG.F.

40,000

--- THEORETICAL ANNUAL HEATING COST ---
 HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

| | | |
|-----|------|------|
| .05 | 451 | 1010 |
| .06 | 547 | 1213 |
| .07 | 637 | 1416 |
| .08 | 727 | 1619 |
| .09 | 821 | 1822 |
| .10 | 914 | 2025 |
| .11 | 1004 | 2231 |
| .12 | 1094 | 2431 |
| .13 | 1175 | 2639 |
| .14 | 1275 | 2839 |
| .15 | 1361 | 3044 |
| .16 | 1461 | 3244 |

BALANCE POINT 21 DEG.F.

50,000

--- THEORETICAL ANNUAL HEATING COST ---
 HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

| | | |
|-----|------|------|
| .05 | 591 | 1263 |
| .06 | 702 | 1477 |
| .07 | 813 | 1691 |
| .08 | 924 | 1905 |
| .09 | 1035 | 2119 |
| .10 | 1146 | 2333 |
| .11 | 1179 | 2533 |
| .12 | 1216 | 2741 |
| .13 | 1253 | 2949 |
| .14 | 1290 | 3157 |
| .15 | 1327 | 3365 |
| .16 | 1364 | 3573 |

BALANCE POINT 27 DEG.F.

60,000

--- THEORETICAL ANNUAL HEATING COST ---
 HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

| | | |
|-----|------|------|
| .05 | 744 | 1517 |
| .06 | 891 | 1827 |
| .07 | 1038 | 2127 |
| .08 | 1190 | 2427 |
| .09 | 1341 | 2727 |
| .10 | 1494 | 3027 |
| .11 | 1647 | 3327 |
| .12 | 1777 | 3650 |
| .13 | 2082 | 4000 |
| .14 | 2282 | 4350 |
| .15 | 2482 | 4700 |
| .16 | 2682 | 5050 |

BALANCE POINT 31 DEG.F.

70,000

--- THEORETICAL ANNUAL HEATING COST ---
 HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

| | | |
|-----|------|------|
| .05 | 925 | 1771 |
| .06 | 1105 | 2127 |
| .07 | 1292 | 2482 |
| .08 | 1484 | 2838 |
| .09 | 1670 | 3193 |
| .10 | 1850 | 3549 |
| .11 | 2023 | 3900 |
| .12 | 2223 | 4260 |
| .13 | 2569 | 4771 |
| .14 | 2862 | 5282 |
| .15 | 3155 | 5793 |
| .16 | 3448 | 6304 |

BALANCE POINT 35 DEG.F.

ANNUAL AIR CONDITIONING COST WHEN COOLING LOAD IS SIZED TO MATCH COOLING CAPACITY OF HEAT PUMP

| | | | | | | | | |
|-----|-----|-----|-----|-----|-----|-----|-----|-----|
| .05 | .06 | .07 | .08 | .09 | .10 | .12 | .14 | .16 |
| 144 | 172 | 201 | 230 | 259 | 288 | 348 | 403 | 460 |

←-- ELECTRIC RATE \$/KWH
 ←-- THEORETICAL AIR CONDITIONING COST

THE ABOVE ANNUAL HEATING AND COOLING OPERATING COSTS ARE THEORETICAL ESTIMATES ONLY AND ARE PROVIDED FOR A COMMON BASIS OF COMPARISON BETWEEN VARIOUS TYPES OF HEATING AND COOLING SYSTEMS. ACTUAL VALUES MAY VARY DEPENDING ON ACTUAL WEATHER CONDITIONS AND INDIVIDUAL USAGE PATTERN.

BAIRD MANUFACTURING COMPANY

DUAL FUEL ADD-OR HEAT PUMP GUIDE TO ENERGY COST SAVINGS

REGION 4
 HEAT PUMP MODEL: OUTDOOR 36URP08 36URP08/A37AG-A INDOOR A37AG-A
 RATED COOLING CAP.: BTUH (95) 36000 SEER10.00
 RATED HEATING CAP.: BTUH (47) 36000 COP(47) 3.10, HSPF 7.20 MIN. DBR DEG IV
 FURNACE TYPE NATURAL GAS FURNACE EFFICIENCY 78.00 % AFUE

| HEAT LOSS BTUH | ELEC. COST \$/KWH | NATURAL GAS COST - \$/THERM | | | | | | | | | | | | |
|----------------|-------------------|-----------------------------|------|------|------|------|------|------|------|------|------|------|------|---|
| | | .35 | .40 | .45 | .50 | .55 | .60 | .65 | .70 | .75 | .80 | .90 | | 1.00 |
| 35,000 | | \$ 270 | 310 | 344 | 383 | 423 | 462 | 502 | 541 | 581 | 620 | 694 | 773 | <--THEORETICAL HEATING COST * FURNACE ONLY |
| .05 | \$ | 344 | 349 | 361 | 366 | 372 | 378 | 389 | 394 | 400 | 406 | 423 | 440 | THEORETICAL HEATING COST * FURN.+ HEAT PUMP \$ PER YEAR |
| .06 | \$ | 406 | 411 | 423 | 428 | 434 | 440 | 451 | 457 | 462 | 468 | 485 | 502 | |
| .07 | \$ | 468 | 473 | 485 | 490 | 496 | 502 | 513 | 519 | 524 | 529 | 541 | 558 | |
| .08 | \$ | 529 | 534 | 546 | 551 | 557 | 562 | 573 | 579 | 584 | 589 | 603 | 620 | |
| .09 | \$ | 589 | 594 | 606 | 611 | 617 | 622 | 633 | 639 | 644 | 649 | 663 | 677 | |
| .10 | \$ | 649 | 654 | 666 | 671 | 677 | 682 | 693 | 699 | 704 | 709 | 723 | 739 | |
| .12 | \$ | 767 | 772 | 784 | 789 | 795 | 800 | 811 | 817 | 822 | 827 | 841 | 857 | |
| .14 | \$ | 874 | 879 | 891 | 896 | 902 | 907 | 918 | 924 | 929 | 934 | 948 | 963 | BALANCE POINT 17 DEG.F. |
| .16 | \$ | 993 | 998 | 1010 | 1015 | 1021 | 1026 | 1036 | 1042 | 1047 | 1052 | 1072 | 1089 | |
| 40,000 | | \$ 310 | 349 | 394 | 440 | 485 | 530 | 575 | 620 | 665 | 705 | 795 | 885 | <--THEORETICAL HEATING COST * FURNACE ONLY |
| .05 | \$ | 389 | 400 | 406 | 417 | 423 | 434 | 440 | 445 | 457 | 462 | 479 | 496 | THEORETICAL HEATING COST * FURN.+ HEAT PUMP \$ PER YEAR |
| .06 | \$ | 451 | 456 | 468 | 473 | 479 | 485 | 496 | 502 | 507 | 513 | 524 | 541 | |
| .07 | \$ | 513 | 518 | 530 | 535 | 541 | 546 | 557 | 563 | 568 | 573 | 589 | 606 | |
| .08 | \$ | 573 | 578 | 590 | 595 | 601 | 606 | 617 | 623 | 628 | 633 | 649 | 666 | |
| .09 | \$ | 633 | 638 | 650 | 655 | 661 | 666 | 677 | 683 | 688 | 693 | 709 | 726 | |
| .10 | \$ | 693 | 698 | 710 | 715 | 721 | 726 | 737 | 743 | 748 | 753 | 769 | 786 | |
| .12 | \$ | 811 | 816 | 828 | 833 | 839 | 844 | 855 | 861 | 866 | 871 | 887 | 904 | |
| .14 | \$ | 924 | 929 | 941 | 946 | 952 | 957 | 968 | 974 | 979 | 984 | 1000 | 1017 | BALANCE POINT 21 DEG.F. |
| .16 | \$ | 1117 | 1122 | 1134 | 1139 | 1145 | 1151 | 1162 | 1168 | 1173 | 1178 | 1207 | 1224 | |
| 50,000 | | \$ 383 | 440 | 496 | 552 | 609 | 665 | 716 | 773 | 829 | 885 | 998 | 1105 | <--THEORETICAL HEATING COST * FURNACE ONLY |
| .05 | \$ | 440 | 452 | 468 | 485 | 502 | 519 | 536 | 552 | 569 | 586 | 609 | 644 | THEORETICAL HEATING COST * FURN.+ HEAT PUMP \$ PER YEAR |
| .06 | \$ | 496 | 501 | 513 | 518 | 524 | 530 | 541 | 546 | 557 | 563 | 579 | 596 | |
| .07 | \$ | 557 | 562 | 574 | 579 | 585 | 590 | 601 | 607 | 612 | 617 | 633 | 650 | |
| .08 | \$ | 617 | 622 | 634 | 639 | 645 | 650 | 661 | 667 | 672 | 677 | 693 | 710 | |
| .09 | \$ | 677 | 682 | 694 | 699 | 705 | 710 | 721 | 727 | 732 | 737 | 753 | 770 | |
| .10 | \$ | 737 | 742 | 754 | 759 | 765 | 770 | 781 | 787 | 792 | 797 | 813 | 830 | |
| .12 | \$ | 855 | 860 | 872 | 877 | 883 | 888 | 900 | 905 | 910 | 915 | 931 | 948 | |
| .14 | \$ | 974 | 979 | 991 | 996 | 1002 | 1007 | 1018 | 1024 | 1029 | 1034 | 1050 | 1067 | BALANCE POINT 27 DEG.F. |
| .16 | \$ | 1055 | 1060 | 1072 | 1077 | 1083 | 1088 | 1100 | 1105 | 1110 | 1115 | 1144 | 1161 | |
| 60,000 | | \$ 462 | 530 | 598 | 665 | 727 | 795 | 863 | 931 | 998 | 1060 | 1196 | 1331 | <--THEORETICAL HEATING COST * FURNACE ONLY |
| .05 | \$ | 524 | 552 | 581 | 609 | 637 | 665 | 694 | 722 | 750 | 778 | 835 | 891 | THEORETICAL HEATING COST * FURN.+ HEAT PUMP \$ PER YEAR |
| .06 | \$ | 586 | 591 | 603 | 608 | 614 | 620 | 631 | 636 | 641 | 646 | 662 | 679 | |
| .07 | \$ | 646 | 651 | 663 | 668 | 674 | 680 | 691 | 696 | 701 | 706 | 722 | 739 | |
| .08 | \$ | 706 | 711 | 723 | 728 | 734 | 740 | 751 | 756 | 761 | 766 | 782 | 800 | |
| .09 | \$ | 766 | 771 | 783 | 788 | 794 | 799 | 810 | 815 | 820 | 825 | 841 | 859 | |
| .10 | \$ | 826 | 831 | 843 | 848 | 854 | 859 | 870 | 875 | 880 | 885 | 901 | 919 | |
| .12 | \$ | 944 | 949 | 961 | 966 | 972 | 977 | 988 | 993 | 998 | 1003 | 1019 | 1037 | |
| .14 | \$ | 1065 | 1070 | 1082 | 1087 | 1093 | 1098 | 1109 | 1114 | 1119 | 1124 | 1140 | 1158 | BALANCE POINT 31 DEG.F. |
| .16 | \$ | 1235 | 1240 | 1252 | 1257 | 1263 | 1268 | 1280 | 1285 | 1290 | 1295 | 1324 | 1341 | |
| 70,000 | | \$ 541 | 620 | 694 | 773 | 852 | 931 | 1010 | 1083 | 1162 | 1241 | 1393 | 1551 | <--THEORETICAL HEATING COST * FURNACE ONLY |
| .05 | \$ | 586 | 631 | 677 | 722 | 767 | 818 | 863 | 908 | 953 | 1004 | 1094 | 1184 | THEORETICAL HEATING COST * FURN.+ HEAT PUMP \$ PER YEAR |
| .06 | \$ | 647 | 652 | 664 | 669 | 675 | 681 | 692 | 697 | 702 | 718 | 735 | 752 | |
| .07 | \$ | 707 | 712 | 724 | 729 | 735 | 741 | 752 | 757 | 762 | 767 | 783 | 800 | |
| .08 | \$ | 767 | 772 | 784 | 789 | 795 | 801 | 812 | 817 | 822 | 827 | 843 | 860 | |
| .09 | \$ | 827 | 832 | 844 | 849 | 855 | 860 | 871 | 876 | 881 | 886 | 902 | 919 | |
| .10 | \$ | 887 | 892 | 904 | 909 | 915 | 920 | 931 | 936 | 941 | 946 | 962 | 979 | |
| .12 | \$ | 1005 | 1010 | 1022 | 1027 | 1033 | 1038 | 1049 | 1054 | 1059 | 1064 | 1080 | 1097 | |
| .14 | \$ | 1065 | 1070 | 1082 | 1087 | 1093 | 1098 | 1109 | 1114 | 1119 | 1124 | 1140 | 1158 | BALANCE POINT 35 DEG.F. |
| .16 | \$ | 1158 | 1163 | 1175 | 1180 | 1186 | 1191 | 1203 | 1208 | 1213 | 1218 | 1247 | 1264 | |

ANNUAL AIR CONDITIONING COST WHEN COOLING LOAD IS SIZED TO MATCH COOLING CAPACITY OF HEAT PUMP

| | | | | | | | | | | |
|----|-----|-----|-----|-----|-----|-----|-----|-----|-----|--------------------------------------|
| \$ | .05 | .06 | .07 | .08 | .09 | .10 | .12 | .14 | .16 | <--ELECTRIC RATE \$/KWH |
| \$ | 144 | 172 | 201 | 230 | 259 | 288 | 345 | 403 | 460 | <--THEORETICAL AIR CONDITIONING COST |

THE ABOVE ANNUAL HEATING AND COOLING OPERATING COSTS ARE THEORETICAL ESTIMATES ONLY AND ARE PROVIDED FOR A COMMON BASIS OF COMPARISON BETWEEN VARIOUS TYPES OF HEATING AND COOLING SYSTEMS. ACTUAL VALUES MAY VARY DEPENDING ON ACTUAL WEATHER CONDITIONS AND INDIVIDUAL USAGE PATTERN.

BARD MANUFACTURING COMPANY

DUAL FUEL ADD-ON HEAT PUMP GUIDE TO ENERGY COST SAVINGS

REGION 4
 HEAT PUMP MODEL: OUTDOOR 36URP08 36URP08/A37AO-A INDOOR A37AO-A
 ARI RATED COOLING CAP.: BTUH(95) 32000, SEER10.00
 ARI RATED HEATING CAP.: BTUH(47) 32000, COP(47) 3.10, HSPF 1.20 MIN. DHR REG IV
 BTUH(17) 21000, COP(17) 2.20
 FURNACE TYPE FUEL OIL FURNACE EFFICIENCY 78.00 % AFUE

| HEAT LOSS BTUH | HEAT PUMP COST \$/KWH | HEATING OIL COST - \$/GALLON | | | | | | | | | | | | | |
|----------------|-----------------------|------------------------------|------|------|------|------|------|------|------|------|------|------|------|--|--|
| | | .70 | .80 | .90 | 1.00 | 1.10 | 1.20 | 1.30 | 1.40 | 1.50 | 1.60 | 1.70 | 1.80 | | |
| 35,000 | | \$ 389 | 445 | 502 | 558 | 615 | 671 | 727 | 784 | 835 | 891 | 947 | 1004 | ---THEORETICAL HEATING COST * FURNACE ONLY | |
| | .05 | \$ 366 | 378 | 389 | 394 | 406 | 417 | 428 | 440 | 451 | 462 | 468 | 479 | THEORETICAL HEATING COST * FURN. + HEAT PUMP \$ PER YEAR | |
| | .06 | 429 | 440 | 451 | 457 | 468 | 479 | 490 | 502 | 513 | 524 | 530 | 541 | | |
| | .07 | 485 | 496 | 507 | 513 | 524 | 536 | 547 | 558 | 569 | 581 | 586 | 598 | | |
| | .08 | 541 | 552 | 563 | 575 | 586 | 598 | 609 | 620 | 631 | 643 | 648 | 660 | | |
| | .09 | 600 | 611 | 622 | 631 | 643 | 654 | 665 | 677 | 688 | 699 | 705 | 716 | | |
| | .10 | 655 | 677 | 688 | 694 | 705 | 716 | 727 | 738 | 750 | 761 | 767 | 778 | | |
| | .12 | 784 | 795 | 806 | 812 | 823 | 835 | 846 | 857 | 868 | 880 | 885 | 897 | | |
| | .14 | 897 | 908 | 919 | 925 | 936 | 947 | 959 | 970 | 981 | 993 | 998 | 1010 | BALANCE POINT 17 DEG.F. | |
| | .16 | \$ 1015 | 1026 | 1038 | 1043 | 1055 | 1066 | 1077 | 1089 | 1100 | 1111 | 1117 | 1128 | | |
| 40,000 | | \$ 445 | 501 | 575 | 637 | 699 | 767 | 829 | 891 | 959 | 1021 | 1083 | 1151 | ---THEORETICAL HEATING COST * FURNACE ONLY | |
| | .05 | \$ 417 | 438 | 440 | 451 | 462 | 473 | 485 | 503 | 513 | 524 | 536 | 547 | THEORETICAL HEATING COST * FURN. + HEAT PUMP \$ PER YEAR | |
| | .06 | 479 | 490 | 502 | 513 | 524 | 536 | 547 | 564 | 575 | 586 | 598 | 609 | | |
| | .07 | 547 | 558 | 569 | 581 | 592 | 603 | 615 | 631 | 643 | 654 | 665 | 677 | | |
| | .08 | 615 | 626 | 637 | 648 | 660 | 671 | 682 | 699 | 710 | 722 | 733 | 744 | | |
| | .09 | 677 | 688 | 699 | 710 | 722 | 733 | 744 | 761 | 773 | 784 | 795 | 806 | | |
| | .10 | 744 | 755 | 767 | 778 | 789 | 801 | 812 | 829 | 840 | 852 | 863 | 874 | | |
| | .12 | 880 | 891 | 902 | 914 | 925 | 936 | 947 | 964 | 976 | 987 | 998 | 1010 | | |
| | .14 | 1010 | 1021 | 1032 | 1043 | 1055 | 1066 | 1077 | 1094 | 1105 | 1117 | 1128 | 1139 | BALANCE POINT 21 DEG.F. | |
| | .16 | \$ 1145 | 1156 | 1168 | 1179 | 1190 | 1201 | 1213 | 1230 | 1241 | 1252 | 1263 | 1275 | | |
| 50,000 | | \$ 558 | 637 | 716 | 795 | 880 | 959 | 1038 | 1117 | 1196 | 1280 | 1359 | 1438 | ---THEORETICAL HEATING COST * FURNACE ONLY | |
| | .05 | \$ 513 | 547 | 581 | 615 | 648 | 682 | 716 | 750 | 784 | 818 | 852 | 885 | THEORETICAL HEATING COST * FURN. + HEAT PUMP \$ PER YEAR | |
| | .06 | 549 | 603 | 637 | 671 | 705 | 739 | 773 | 806 | 840 | 874 | 908 | 942 | | |
| | .07 | 626 | 660 | 694 | 727 | 761 | 795 | 829 | 863 | 897 | 931 | 964 | 998 | | |
| | .08 | 682 | 716 | 750 | 784 | 818 | 852 | 885 | 919 | 953 | 987 | 1021 | 1055 | | |
| | .09 | 739 | 773 | 806 | 840 | 874 | 908 | 942 | 976 | 1010 | 1043 | 1077 | 1111 | | |
| | .10 | 795 | 829 | 863 | 897 | 931 | 964 | 998 | 1032 | 1066 | 1100 | 1134 | 1168 | | |
| | .12 | 908 | 942 | 976 | 1010 | 1043 | 1077 | 1111 | 1145 | 1179 | 1213 | 1247 | 1280 | | |
| | .14 | 1015 | 1049 | 1083 | 1117 | 1151 | 1184 | 1218 | 1252 | 1286 | 1320 | 1354 | 1388 | BALANCE POINT 27 DEG.F. | |
| | .16 | \$ 1128 | 1162 | 1196 | 1230 | 1263 | 1297 | 1331 | 1365 | 1399 | 1433 | 1467 | 1500 | | |
| 60,000 | | \$ 671 | 767 | 863 | 959 | 1055 | 1151 | 1247 | 1342 | 1438 | 1534 | 1630 | 1726 | ---THEORETICAL HEATING COST * FURNACE ONLY | |
| | .05 | \$ 609 | 654 | 694 | 733 | 773 | 812 | 857 | 897 | 936 | 976 | 1015 | 1060 | THEORETICAL HEATING COST * FURN. + HEAT PUMP \$ PER YEAR | |
| | .06 | 611 | 716 | 756 | 795 | 835 | 874 | 919 | 959 | 998 | 1038 | 1077 | 1122 | | |
| | .07 | 739 | 784 | 823 | 863 | 902 | 942 | 987 | 1026 | 1066 | 1105 | 1145 | 1190 | | |
| | .08 | 801 | 846 | 885 | 925 | 964 | 1004 | 1049 | 1089 | 1128 | 1168 | 1207 | 1252 | | |
| | .09 | 868 | 914 | 953 | 993 | 1032 | 1072 | 1117 | 1156 | 1196 | 1235 | 1275 | 1320 | | |
| | .10 | 931 | 976 | 1015 | 1055 | 1094 | 1134 | 1179 | 1218 | 1258 | 1297 | 1337 | 1382 | | |
| | .12 | 1060 | 1105 | 1145 | 1184 | 1224 | 1263 | 1309 | 1348 | 1388 | 1427 | 1467 | 1512 | | |
| | .14 | 1190 | 1235 | 1275 | 1314 | 1354 | 1393 | 1438 | 1478 | 1517 | 1557 | 1596 | 1642 | BALANCE POINT 31 DEG.F. | |
| | .16 | \$ 1320 | 1365 | 1405 | 1444 | 1484 | 1523 | 1568 | 1608 | 1647 | 1687 | 1726 | 1771 | | |
| 70,000 | | \$ 784 | 891 | 1004 | 1117 | 1230 | 1342 | 1455 | 1568 | 1675 | 1788 | 1901 | 2014 | ---THEORETICAL HEATING COST * FURNACE ONLY | |
| | .05 | \$ 727 | 795 | 863 | 931 | 993 | 1060 | 1128 | 1196 | 1263 | 1331 | 1399 | 1461 | THEORETICAL HEATING COST * FURN. + HEAT PUMP \$ PER YEAR | |
| | .06 | 778 | 846 | 914 | 981 | 1043 | 1111 | 1179 | 1247 | 1314 | 1382 | 1450 | 1513 | | |
| | .07 | 849 | 897 | 944 | 1032 | 1094 | 1162 | 1230 | 1297 | 1365 | 1433 | 1500 | 1563 | | |
| | .08 | 885 | 953 | 1021 | 1089 | 1151 | 1218 | 1286 | 1354 | 1421 | 1489 | 1557 | 1619 | | |
| | .09 | 936 | 1004 | 1072 | 1139 | 1201 | 1269 | 1337 | 1405 | 1474 | 1540 | 1608 | 1670 | | |
| | .10 | 987 | 1055 | 1123 | 1190 | 1254 | 1320 | 1388 | 1455 | 1523 | 1591 | 1659 | 1721 | | |
| | .12 | 1089 | 1156 | 1224 | 1292 | 1354 | 1421 | 1489 | 1557 | 1625 | 1692 | 1760 | 1822 | | |
| | .14 | 1196 | 1263 | 1331 | 1399 | 1461 | 1529 | 1596 | 1664 | 1732 | 1799 | 1867 | 1929 | BALANCE POINT 35 DEG.F. | |
| | .16 | \$ 1297 | 1365 | 1433 | 1500 | 1563 | 1630 | 1698 | 1766 | 1833 | 1901 | 1969 | 2031 | | |

ANNUAL AIR CONDITIONING COST WHEN COOLING LOAD IS SIZED TO MATCH COOLING CAPACITY OF HEAT PUMP

| | | | | | | | | | | |
|----|-----|-----|-----|-----|-----|-----|-----|-----|-----|---|
| | .05 | .06 | .07 | .08 | .09 | .10 | .12 | .14 | .16 | |
| \$ | 144 | 172 | 201 | 230 | 259 | 288 | 345 | 400 | 460 | ---ELECTRIC RATE \$/KWH ---THEORETICAL AIR CONDITIONING COST |

THE ABOVE ANNUAL HEATING AND COOLING OPERATING COSTS ARE THEORETICAL ESTIMATES ONLY AND ARE PROVIDED FOR A COMMON BASIS OF COMPARISON BETWEEN VARIOUS TYPES OF HEATING AND COOLING SYSTEMS. ACTUAL VALUES MAY VARY DEPENDING ON ACTUAL WEATHER CONDITIONS AND INDIVIDUAL USAGE PATTERN.

BARD MANUFACTURING COMPANY

DUAL FUEL, A/C OR HEAT PUMP GUIDE TO ENERGY COST SAVINGS

SECTION 4
 HEAT PUMP MODEL: OUTDOOR 36URP08 36URP08/A37A0-A INDOOR A37A0-A
 AIR RATED COOLING CAP.: BTUH (95) 36000 SBER10 CO
 AIR RATED HEATING CAP.: BTUH (47) 36000 COP(17) 3.10, BSPP 7.20 MIN. DEN RSG IV
 FURNACE TYPE PROPANE GAS FURNACE EFFICIENCY 78.00 % A/B/E

| HEAT LOSS BTUH | ELEC. COST \$/KWH | PROPANE GAS COST - \$/GALLON | | | | | | | | | | | | | |
|----------------|-------------------|------------------------------|------|------|------|------|------|------|------|------|------|------|------|--|--|
| | | .60 | .65 | .70 | .75 | .80 | .85 | .90 | .95 | 1.00 | 1.10 | 1.20 | 1.20 | | |
| 35,000 | \$ | 507 | 552 | 592 | 637 | 682 | 722 | 767 | 806 | 852 | 906 | 1021 | 1021 | ←--THEORETICAL HEATING COST * FURNACE ONLY | |
| | \$ | 389 | 394 | 406 | 411 | 423 | 428 | 434 | 445 | 451 | 468 | 485 | 485 | THEORETICAL HEATING COST * FURN. + HEAT PUMP \$ PER YEAR | |
| | \$ | 451 | 451 | 458 | 473 | 482 | 490 | 496 | 507 | 513 | 530 | 547 | 547 | | |
| | \$ | 507 | 513 | 524 | 530 | 541 | 547 | 557 | 564 | 573 | 586 | 603 | 603 | | |
| | \$ | 569 | 575 | 586 | 592 | 603 | 609 | 615 | 626 | 631 | 648 | 665 | 665 | | |
| | \$ | 626 | 631 | 643 | 648 | 660 | 665 | 671 | 682 | 688 | 705 | 722 | 722 | | |
| | \$ | 688 | 694 | 705 | 710 | 722 | 727 | 733 | 744 | 744 | 767 | 784 | 784 | | |
| | \$ | 806 | 812 | 823 | 829 | 840 | 846 | 852 | 863 | 868 | 885 | 902 | 902 | | |
| | \$ | 919 | 925 | 936 | 942 | 953 | 959 | 964 | 976 | 981 | 998 | 1015 | 1015 | BALANCE POINT 17 DEG.F. | |
| | \$ | 1038 | 1043 | 1055 | 1060 | 1072 | 1077 | 1083 | 1094 | 1100 | 1117 | 1134 | 1134 | | |
| 40,000 | \$ | 581 | 631 | 682 | 727 | 778 | 829 | 874 | 925 | 976 | 1072 | 1168 | 1168 | ←--THEORETICAL HEATING COST * FURNACE ONLY | |
| | \$ | 440 | 451 | 462 | 468 | 479 | 485 | 496 | 507 | 513 | 530 | 552 | 552 | THEORETICAL HEATING COST * FURN. + HEAT PUMP \$ PER YEAR | |
| | \$ | 507 | 513 | 524 | 530 | 541 | 547 | 557 | 564 | 573 | 586 | 603 | 603 | | |
| | \$ | 569 | 575 | 586 | 592 | 603 | 609 | 615 | 626 | 631 | 648 | 665 | 665 | | |
| | \$ | 626 | 631 | 643 | 648 | 660 | 665 | 671 | 682 | 688 | 705 | 722 | 722 | | |
| | \$ | 688 | 694 | 705 | 710 | 722 | 727 | 733 | 744 | 744 | 767 | 784 | 784 | | |
| | \$ | 806 | 812 | 823 | 829 | 840 | 846 | 852 | 863 | 868 | 885 | 902 | 902 | | |
| | \$ | 919 | 925 | 936 | 942 | 953 | 959 | 964 | 976 | 981 | 998 | 1015 | 1015 | BALANCE POINT 21 DEG.F. | |
| | \$ | 1032 | 1043 | 1055 | 1060 | 1072 | 1077 | 1083 | 1100 | 1106 | 1122 | 1145 | 1145 | | |
| | \$ | 1168 | 1179 | 1190 | 1196 | 1207 | 1213 | 1224 | 1235 | 1241 | 1258 | 1280 | 1280 | | |
| 50,000 | \$ | 727 | 789 | 852 | 914 | 976 | 1032 | 1094 | 1156 | 1218 | 1337 | 1461 | 1461 | ←--THEORETICAL HEATING COST * FURNACE ONLY | |
| | \$ | 586 | 609 | 637 | 668 | 716 | 739 | 767 | 789 | 846 | 892 | 892 | 892 | THEORETICAL HEATING COST * FURN. + HEAT PUMP \$ PER YEAR | |
| | \$ | 653 | 665 | 694 | 722 | 778 | 796 | 823 | 846 | 902 | 959 | 1010 | 1010 | | |
| | \$ | 727 | 738 | 750 | 758 | 778 | 785 | 802 | 810 | 823 | 846 | 863 | 863 | | |
| | \$ | 812 | 818 | 829 | 835 | 851 | 858 | 869 | 876 | 892 | 915 | 932 | 932 | | |
| | \$ | 868 | 875 | 886 | 891 | 914 | 921 | 934 | 942 | 953 | 976 | 1002 | 1002 | | |
| | \$ | 981 | 987 | 999 | 1004 | 1021 | 1021 | 1049 | 1049 | 1072 | 1128 | 1179 | 1179 | | |
| | \$ | 1089 | 1111 | 1139 | 1168 | 1190 | 1218 | 1241 | 1269 | 1292 | 1348 | 1399 | 1399 | BALANCE POINT 27 DEG.F. | |
| | \$ | 1201 | 1224 | 1252 | 1280 | 1303 | 1331 | 1354 | 1382 | 1405 | 1461 | 1512 | 1512 | | |
| 60,000 | \$ | 874 | 947 | 1021 | 1094 | 1168 | 1241 | 1314 | 1388 | 1461 | 1608 | 1754 | 1754 | ←--THEORETICAL HEATING COST * FURNACE ONLY | |
| | \$ | 699 | 727 | 761 | 789 | 823 | 852 | 885 | 914 | 947 | 1010 | 1072 | 1072 | THEORETICAL HEATING COST * FURN. + HEAT PUMP \$ PER YEAR | |
| | \$ | 761 | 789 | 823 | 852 | 885 | 914 | 947 | 976 | 1010 | 1072 | 1134 | 1134 | | |
| | \$ | 829 | 857 | 891 | 919 | 953 | 981 | 1015 | 1043 | 1077 | 1139 | 1201 | 1201 | | |
| | \$ | 891 | 919 | 953 | 981 | 1015 | 1043 | 1077 | 1105 | 1139 | 1201 | 1263 | 1263 | | |
| | \$ | 959 | 987 | 1021 | 1049 | 1083 | 1111 | 1145 | 1173 | 1207 | 1269 | 1331 | 1331 | | |
| | \$ | 1021 | 1049 | 1083 | 1111 | 1145 | 1173 | 1207 | 1235 | 1269 | 1331 | 1393 | 1393 | | |
| | \$ | 1151 | 1179 | 1213 | 1241 | 1275 | 1303 | 1337 | 1365 | 1399 | 1461 | 1523 | 1523 | BALANCE POINT 31 DEG.F. | |
| | \$ | 1280 | 1309 | 1342 | 1371 | 1405 | 1433 | 1467 | 1495 | 1529 | 1591 | 1653 | 1653 | | |
| | \$ | 1410 | 1438 | 1472 | 1500 | 1534 | 1563 | 1596 | 1625 | 1658 | 1721 | 1783 | 1783 | | |
| 70,000 | \$ | 1021 | 1105 | 1190 | 1280 | 1365 | 1450 | 1534 | 1619 | 1704 | 1878 | 2048 | 2048 | ←--THEORETICAL HEATING COST * FURNACE ONLY | |
| | \$ | 868 | 919 | 970 | 1026 | 1077 | 1128 | 1179 | 1230 | 1280 | 1382 | 1484 | 1484 | THEORETICAL HEATING COST * FURN. + HEAT PUMP \$ PER YEAR | |
| | \$ | 919 | 970 | 1021 | 1077 | 1128 | 1179 | 1230 | 1280 | 1331 | 1433 | 1534 | 1534 | | |
| | \$ | 970 | 1021 | 1072 | 1128 | 1179 | 1230 | 1280 | 1331 | 1382 | 1484 | 1585 | 1585 | | |
| | \$ | 1026 | 1077 | 1128 | 1184 | 1235 | 1286 | 1337 | 1388 | 1438 | 1540 | 1642 | 1642 | | |
| | \$ | 1077 | 1128 | 1179 | 1235 | 1286 | 1337 | 1388 | 1438 | 1489 | 1591 | 1692 | 1692 | | |
| | \$ | 1128 | 1179 | 1230 | 1286 | 1337 | 1388 | 1438 | 1489 | 1540 | 1642 | 1743 | 1743 | | |
| | \$ | 1230 | 1280 | 1331 | 1388 | 1438 | 1489 | 1540 | 1591 | 1642 | 1743 | 1845 | 1845 | BALANCE POINT 35 DEG.F. | |
| | \$ | 1337 | 1388 | 1438 | 1489 | 1540 | 1591 | 1642 | 1692 | 1743 | 1845 | 1947 | 1947 | | |
| | \$ | 1438 | 1489 | 1540 | 1591 | 1642 | 1692 | 1743 | 1793 | 1850 | 1952 | 2053 | 2053 | | |

ANNUAL AIR CONDITIONING COST WHEN COOLING LOAD IS SIZED TO MATCH COOLING CAPACITY OF HEAT PUMP

| | .05 | .06 | .07 | .08 | .09 | .10 | .12 | .14 | .16 | |
|----|-----|-----|-----|-----|-----|-----|-----|-----|-----|--------------------------------------|
| \$ | 144 | 172 | 201 | 230 | 259 | 288 | 345 | 403 | 460 | ←--ELECTRIC RATE \$/KWH |
| | | | | | | | | | | ←--THEORETICAL AIR CONDITIONING COST |

THE ABOVE ANNUAL HEATING AND COOLING OPERATING COSTS ARE THEORETICAL ESTIMATES ONLY AND ARE PROVIDED FOR A COMMON BASIS OF COMPARISON BETWEEN VARIOUS TYPES OF HEATING AND COOLING SYSTEMS. ACTUAL VALUES MAY VARY DEPENDING ON ACTUAL WEATHER CONDITIONS AND INDIVIDUAL USAGE PATTERNS.

BAIRD MANUFACTURING COMPANY

DUAL FUEL ADD-ON HEAT PUMP GUIDE TO ENERGY COST SAVINGS

ENGINE 4
 HEAT PUMP MODEL: OUTDOOR 42UHPOA 42UHPOA/A6180-A INDOOR A6180-A
 NET HEATING CAP.: BTUH (95) 48000, COP(11) 3.0
 NET HEATING CAP.: BTUH (47) 41000, COP(17) 3.40, HSPF 1.60 MIN. DER REG IV
 FURNACE TYPE ELECTRIC FURNACE EFFICIENCY 100.00 % AERB

HEAT PUMP
 \$/KWH

60,000

--- THEORETICAL ANNUAL HEATING COST ---
 HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

| | | |
|-----|------|------|
| .05 | 462 | 1010 |
| .06 | 558 | 1213 |
| .07 | 648 | 1416 |
| .08 | 739 | 1619 |
| .09 | 836 | 1822 |
| .10 | 925 | 2025 |
| .12 | 1111 | 2431 |
| .14 | 1297 | 2838 |
| .16 | 1484 | 3244 |

BALANCE POINT 16 DEG.F.

50,000

--- THEORETICAL ANNUAL HEATING COST ---
 HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

| | | |
|-----|------|------|
| .05 | 581 | 1263 |
| .06 | 704 | 1517 |
| .07 | 819 | 1771 |
| .08 | 936 | 2025 |
| .09 | 1049 | 2279 |
| .10 | 1173 | 2533 |
| .12 | 1405 | 3041 |
| .14 | 1642 | 3549 |
| .16 | 1873 | 4057 |

BALANCE POINT 23 DEG.F.

60,000

--- THEORETICAL ANNUAL HEATING COST ---
 HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

| | | |
|-----|------|------|
| .05 | 727 | 1517 |
| .06 | 869 | 1822 |
| .07 | 1015 | 2127 |
| .08 | 1162 | 2431 |
| .09 | 1309 | 2736 |
| .10 | 1450 | 3041 |
| .12 | 1737 | 3650 |
| .14 | 2031 | 4260 |
| .16 | 2319 | 4869 |

BALANCE POINT 28 DEG.F.

70,000

--- THEORETICAL ANNUAL HEATING COST ---
 HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

| | | |
|-----|------|------|
| .05 | 885 | 1771 |
| .06 | 1060 | 2127 |
| .07 | 1235 | 2482 |
| .08 | 1410 | 2838 |
| .09 | 1591 | 3193 |
| .10 | 1769 | 3549 |
| .12 | 2192 | 4260 |
| .14 | 2477 | 4971 |
| .16 | 2826 | 5682 |

BALANCE POINT 32 DEG.F.

80,000

--- THEORETICAL ANNUAL HEATING COST ---
 HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

| | | |
|-----|------|------|
| .05 | 1066 | 2025 |
| .06 | 1275 | 2431 |
| .07 | 1475 | 2838 |
| .08 | 1704 | 3244 |
| .09 | 1918 | 3650 |
| .10 | 2117 | 4057 |
| .12 | 2561 | 4869 |
| .14 | 2984 | 5682 |
| .16 | 3413 | 6494 |

BALANCE POINT 35 DEG.F.

ANNUAL AIR CONDITIONING COST WHEN COOLING LOAD IS SIZED TO MATCH COOLING CAPACITY OF HEAT PUMP

| | | | | | | | | | | |
|----|-----|-----|-----|-----|-----|-----|-----|-----|-----|---------------------------------------|
| | .05 | .06 | .07 | .08 | .09 | .10 | .12 | .14 | .16 | |
| \$ | 155 | 186 | 218 | 249 | 280 | 311 | 373 | 436 | 498 | <-- ELECTRIC RATE \$/KWH |
| | | | | | | | | | | <-- THEORETICAL AIR CONDITIONING COST |

THE ABOVE ANNUAL HEATING AND COOLING OPERATING COSTS ARE THEORETICAL ESTIMATES ONLY AND ARE PROVIDED FOR A COMMON BASIS OF COMPARISON BETWEEN VARIOUS TYPES OF HEATING AND COOLING SYSTEMS. ACTUAL VALUES MAY VARY DEPENDING ON ACTUAL WEATHER CONDITIONS AND INDIVIDUAL USAGE PATTERNS.

BARD MANUFACTURING COMPANY
DUAL FUEL ADD-ON HEAT PUMP GUIDE TO ENERGY COST SAVINGS

REGION 4
 HEAT PUMP MODEL: OUTDOOR 42HEPDA 42HEPDA/AS140-A INDOOR AS140-A
 RATIO COOLING CAP.: BTUH(95) 48000 SEER11.30
 RATIO HEATING CAP.: BTUH (47) 11000 COP(47) 3.40 BSFP 7.60 MIN. DHR REG IV
 FURNACE TYPE NATURAL GAS FURNACE EFFICIENCY 78.00 % AFUE

| HEAT LOSS BTUH | HEAT PUMP COST \$/KWH | NATURAL GAS COST - \$/THERM | | | | | | | | | | | | | |
|-------------------|--------------------------------|-----------------------------|------|------|------|------|------|------|------|------|------|------|------|---|--|
| | | .35 | .40 | .45 | .50 | .55 | .60 | .65 | .70 | .75 | .80 | | .90 | 1.00 | |
| 40,000 | \$ | 310 | 349 | 394 | 440 | 485 | 530 | 575 | 620 | 665 | 705 | 795 | 885 | ←--THEORETICAL HEATING COST * FURNACE ONLY | |
| | .05 | 417 | 423 | 428 | 434 | 440 | 445 | 451 | 457 | 457 | 462 | 473 | 485 | THEORETICAL HEATING COST * FURN.+ HEAT PUMP | |
| | .06 | 490 | 496 | 502 | 507 | 513 | 519 | 524 | 530 | 530 | 536 | 547 | 558 | \$ PER YEAR | |
| | .07 | 569 | 575 | 581 | 586 | 592 | 598 | 603 | 609 | 609 | 615 | 626 | 637 | | |
| | .08 | 648 | 654 | 660 | 665 | 671 | 677 | 682 | 688 | 688 | 694 | 705 | 716 | | |
| | .09 | 722 | 727 | 733 | 739 | 744 | 750 | 756 | 761 | 761 | 767 | 778 | 789 | | |
| | .10 | 801 | 806 | 812 | 818 | 823 | 829 | 835 | 840 | 840 | 846 | 857 | 868 | | |
| | .12 | 953 | 959 | 964 | 970 | 976 | 981 | 987 | 993 | 993 | 998 | 1010 | 1021 | BALANCE POINT 16 DEG.F. | |
| | .14 | 1105 | 1111 | 1117 | 1122 | 1128 | 1134 | 1139 | 1145 | 1145 | 1151 | 1162 | 1173 | | |
| | .16 | 1258 | 1263 | 1269 | 1275 | 1280 | 1286 | 1292 | 1297 | 1297 | 1303 | 1314 | 1326 | | |
| 50,000 | \$ | 383 | 440 | 496 | 552 | 609 | 665 | 716 | 773 | 829 | 885 | 998 | 1105 | ←--THEORETICAL HEATING COST * FURNACE ONLY | |
| | .05 | 479 | 490 | 507 | 524 | 541 | 558 | 569 | 586 | 603 | 620 | 648 | 682 | THEORETICAL HEATING COST * FURN.+ HEAT PUMP | |
| | .06 | 572 | 564 | 581 | 598 | 615 | 631 | 643 | 660 | 677 | 694 | 722 | 756 | \$ PER YEAR | |
| | .07 | 626 | 637 | 654 | 671 | 688 | 705 | 716 | 733 | 750 | 767 | 795 | 829 | | |
| | .08 | 705 | 716 | 733 | 750 | 767 | 784 | 795 | 812 | 829 | 846 | 874 | 908 | | |
| | .09 | 778 | 789 | 806 | 823 | 840 | 857 | 868 | 885 | 902 | 919 | 947 | 981 | | |
| | .10 | 852 | 863 | 880 | 897 | 914 | 931 | 942 | 959 | 976 | 993 | 1021 | 1055 | | |
| | .12 | 998 | 1010 | 1026 | 1043 | 1060 | 1077 | 1089 | 1105 | 1122 | 1139 | 1168 | 1201 | BALANCE POINT 23 DEG.F. | |
| | .14 | 1145 | 1156 | 1173 | 1190 | 1207 | 1224 | 1235 | 1252 | 1269 | 1286 | 1314 | 1348 | | |
| | .16 | 1297 | 1303 | 1320 | 1337 | 1354 | 1371 | 1382 | 1399 | 1416 | 1433 | 1461 | 1495 | | |
| 60,000 | \$ | 462 | 530 | 598 | 665 | 727 | 795 | 863 | 931 | 998 | 1060 | 1196 | 1331 | ←--THEORETICAL HEATING COST * FURNACE ONLY | |
| | .05 | 541 | 569 | 598 | 626 | 654 | 682 | 710 | 739 | 767 | 795 | 852 | 908 | THEORETICAL HEATING COST * FURN.+ HEAT PUMP | |
| | .06 | 609 | 637 | 665 | 694 | 722 | 750 | 778 | 806 | 835 | 863 | 919 | 976 | \$ PER YEAR | |
| | .07 | 677 | 705 | 733 | 761 | 789 | 818 | 846 | 874 | 902 | 931 | 987 | 1043 | | |
| | .08 | 744 | 773 | 801 | 829 | 857 | 885 | 914 | 942 | 970 | 998 | 1055 | 1111 | | |
| | .09 | 817 | 846 | 874 | 902 | 930 | 958 | 986 | 1010 | 1038 | 1066 | 1122 | 1179 | | |
| | .10 | 885 | 914 | 942 | 970 | 998 | 1026 | 1055 | 1083 | 1111 | 1139 | 1196 | 1252 | | |
| | .12 | 1021 | 1049 | 1077 | 1105 | 1134 | 1162 | 1190 | 1218 | 1247 | 1275 | 1331 | 1388 | BALANCE POINT 28 DEG.F. | |
| | .14 | 1156 | 1184 | 1213 | 1241 | 1269 | 1297 | 1326 | 1354 | 1382 | 1410 | 1467 | 1523 | | |
| | .16 | 1297 | 1326 | 1354 | 1382 | 1410 | 1438 | 1467 | 1495 | 1523 | 1551 | 1608 | 1664 | | |
| 70,000 | \$ | 541 | 620 | 694 | 773 | 852 | 931 | 1010 | 1083 | 1162 | 1241 | 1393 | 1551 | ←--THEORETICAL HEATING COST * FURNACE ONLY | |
| | .05 | 598 | 643 | 688 | 733 | 778 | 823 | 874 | 919 | 964 | 1015 | 1105 | 1196 | THEORETICAL HEATING COST * FURN.+ HEAT PUMP | |
| | .06 | 648 | 694 | 739 | 784 | 829 | 880 | 925 | 970 | 1015 | 1066 | 1156 | 1247 | \$ PER YEAR | |
| | .07 | 705 | 750 | 795 | 840 | 885 | 936 | 981 | 1026 | 1072 | 1122 | 1213 | 1303 | | |
| | .08 | 756 | 801 | 846 | 891 | 936 | 987 | 1032 | 1077 | 1124 | 1173 | 1263 | 1354 | | |
| | .09 | 812 | 857 | 902 | 947 | 993 | 1043 | 1089 | 1134 | 1179 | 1230 | 1320 | 1410 | | |
| | .10 | 863 | 908 | 953 | 998 | 1043 | 1094 | 1139 | 1184 | 1230 | 1280 | 1371 | 1461 | | |
| | .12 | 970 | 1015 | 1060 | 1105 | 1151 | 1201 | 1247 | 1292 | 1337 | 1388 | 1478 | 1568 | | |
| | .14 | 1077 | 1122 | 1168 | 1213 | 1258 | 1309 | 1354 | 1399 | 1444 | 1495 | 1585 | 1675 | BALANCE POINT 32 DEG.F. | |
| | .16 | 1184 | 1230 | 1275 | 1320 | 1365 | 1416 | 1461 | 1506 | 1551 | 1602 | 1692 | 1783 | | |
| 80,000 | \$ | 620 | 705 | 795 | 885 | 976 | 1060 | 1151 | 1241 | 1331 | 1416 | 1596 | 1771 | ←--THEORETICAL HEATING COST * FURNACE ONLY | |
| | .05 | 671 | 722 | 778 | 829 | 880 | 936 | 987 | 1043 | 1094 | 1145 | 1252 | 1359 | THEORETICAL HEATING COST * FURN.+ HEAT PUMP | |
| | .06 | 723 | 784 | 840 | 891 | 942 | 998 | 1049 | 1105 | 1156 | 1207 | 1314 | 1421 | \$ PER YEAR | |
| | .07 | 789 | 840 | 897 | 947 | 998 | 1055 | 1105 | 1162 | 1213 | 1263 | 1371 | 1478 | | |
| | .08 | 852 | 902 | 959 | 1010 | 1060 | 1117 | 1168 | 1224 | 1275 | 1326 | 1433 | 1540 | | |
| | .09 | 917 | 967 | 1024 | 1072 | 1123 | 1179 | 1230 | 1286 | 1344 | 1398 | 1495 | 1601 | | |
| | .10 | 970 | 1021 | 1071 | 1124 | 1178 | 1235 | 1286 | 1344 | 1398 | 1444 | 1551 | 1658 | | |
| | .12 | 1094 | 1145 | 1201 | 1252 | 1303 | 1359 | 1410 | 1461 | 1517 | 1568 | 1675 | 1783 | | |
| | .14 | 1213 | 1263 | 1320 | 1371 | 1421 | 1478 | 1529 | 1585 | 1636 | 1687 | 1794 | 1901 | BALANCE POINT 35 DEG.F. | |
| | .16 | 1331 | 1382 | 1438 | 1489 | 1540 | 1596 | 1647 | 1704 | 1754 | 1805 | 1912 | 2020 | | |

ANNUAL AIR CONDITIONING COST WHEN COOLING LOAD IS SIZED TO MATCH COOLING CAPACITY OF HEAT PUMP

| | .05 | .06 | .07 | .08 | .09 | .10 | .12 | .14 | .16 | |
|----|-----|-----|-----|-----|-----|-----|-----|-----|-----|--------------------------------------|
| \$ | 155 | 186 | 218 | 249 | 280 | 311 | 373 | 436 | 498 | ←--ELECTRIC RATE \$/KWH |
| | | | | | | | | | | ←--THEORETICAL AIR CONDITIONING COST |

THE ABOVE ANNUAL HEATING AND COOLING OPERATING COSTS ARE THEORETICAL ESTIMATES ONLY AND ARE PROVIDED FOR A COMMON BASIS OF COMPARISON BETWEEN VARIOUS TYPES OF HEATING AND COOLING SYSTEMS. ACTUAL VALUES MAY VARY DEPENDING ON ACTUAL WEATHER CONDITIONS AND INDIVIDUAL USAGE PATTERN.

BARD MANUFACTURING COMPANY

DUAL FUEL ADD-ON HEAT PUMP GUIDE TO ENERGY COST SAVINGS

REGION 4
 HEAT PUMP WINDS: OUTDOOR 42RHPOA 42RHPOA/AS1AQ-A INDOOR AS1AQ-A
 RATED COOLING CAP.: BTUH (95) 44000 SEER(1) 30
 RATED HEATING CAP.: BTUH (47) 21000 COP(47) 3.40 HSPF 7.60 MIN.DBR REG IV
 BTUH (17) 25000 COP(17) 2.20
 FURNACE TYPE FUEL OIL FURNACE EFFICIENCY 78.00 % AFUE

| HEAT LOSS BTUH | ELEC. COST \$/KWH | HEATING OIL COST - \$/GALLON | | | | | | | | | | | | |
|----------------|-------------------|------------------------------|------|------|------|------|------|------|------|------|------|------|------|---|
| | | .70 | .80 | .90 | 1.00 | 1.10 | 1.20 | 1.30 | 1.40 | 1.50 | 1.60 | 1.70 | 1.80 | |
| 40,000 | | \$ 445 | 507 | 575 | 637 | 699 | 767 | 829 | 891 | 959 | 1021 | 1083 | 1151 | <--THEORETICAL HEATING COST * FURNACE ONLY |
| | .05 | \$ 434 | 440 | 451 | 457 | 463 | 468 | 479 | 485 | 490 | 502 | 507 | 513 | THEORETICAL HEATING COST * FURN.+ HEAT PUMP \$ PER YEAR |
| | .10 | 507 | 513 | 524 | 530 | 536 | 541 | 552 | 558 | 564 | 575 | 581 | 586 | |
| | .15 | 586 | 592 | 603 | 609 | 617 | 620 | 631 | 637 | 643 | 654 | 660 | 665 | |
| | .20 | 665 | 671 | 682 | 688 | 694 | 699 | 710 | 716 | 728 | 733 | 739 | 744 | |
| | .25 | 739 | 744 | 756 | 761 | 767 | 773 | 784 | 789 | 795 | 806 | 812 | 818 | |
| | .30 | 818 | 823 | 835 | 840 | 846 | 853 | 864 | 869 | 874 | 885 | 891 | 897 | |
| | .35 | 910 | 916 | 927 | 933 | 938 | 944 | 954 | 959 | 964 | 974 | 980 | 986 | |
| | .40 | 1122 | 1128 | 1139 | 1145 | 1151 | 1156 | 1168 | 1173 | 1179 | 1190 | 1196 | 1201 | |
| | .45 | 1275 | 1280 | 1292 | 1297 | 1303 | 1309 | 1320 | 1326 | 1331 | 1342 | 1348 | 1354 | |
| | .16 | | | | | | | | | | | | | |
| 50,000 | | \$ 558 | 637 | 716 | 795 | 880 | 959 | 1038 | 1117 | 1196 | 1280 | 1359 | 1438 | <--THEORETICAL HEATING COST * FURNACE ONLY |
| | .05 | \$ 524 | 547 | 569 | 592 | 615 | 637 | 665 | 688 | 710 | 733 | 756 | 778 | THEORETICAL HEATING COST * FURN.+ HEAT PUMP \$ PER YEAR |
| | .10 | 594 | 630 | 643 | 665 | 688 | 710 | 739 | 761 | 784 | 806 | 829 | 852 | |
| | .15 | 671 | 694 | 716 | 739 | 761 | 784 | 812 | 835 | 857 | 880 | 902 | 925 | |
| | .20 | 750 | 773 | 795 | 818 | 840 | 863 | 891 | 914 | 936 | 959 | 981 | 1004 | |
| | .25 | 823 | 846 | 868 | 891 | 914 | 936 | 964 | 987 | 1010 | 1032 | 1055 | 1077 | |
| | .30 | 897 | 919 | 942 | 964 | 987 | 1010 | 1038 | 1060 | 1083 | 1105 | 1128 | 1151 | |
| | .35 | 1043 | 1066 | 1089 | 1111 | 1134 | 1156 | 1184 | 1207 | 1230 | 1252 | 1275 | 1297 | |
| | .40 | 1190 | 1213 | 1235 | 1258 | 1280 | 1303 | 1331 | 1354 | 1376 | 1399 | 1421 | 1444 | |
| | .45 | 1337 | 1359 | 1382 | 1405 | 1427 | 1450 | 1478 | 1500 | 1523 | 1546 | 1568 | 1591 | |
| | .16 | | | | | | | | | | | | | |
| 60,000 | | \$ 671 | 767 | 863 | 959 | 1055 | 1151 | 1247 | 1342 | 1438 | 1534 | 1630 | 1726 | <--THEORETICAL HEATING COST * FURNACE ONLY |
| | .05 | \$ 626 | 671 | 710 | 750 | 789 | 829 | 874 | 914 | 953 | 993 | 1032 | 1077 | THEORETICAL HEATING COST * FURN.+ HEAT PUMP \$ PER YEAR |
| | .10 | 694 | 739 | 778 | 818 | 857 | 897 | 942 | 981 | 1021 | 1060 | 1100 | 1145 | |
| | .15 | 761 | 806 | 846 | 885 | 925 | 964 | 1010 | 1049 | 1089 | 1128 | 1168 | 1213 | |
| | .20 | 829 | 874 | 914 | 953 | 993 | 1032 | 1077 | 1117 | 1157 | 1196 | 1235 | 1280 | |
| | .25 | 897 | 942 | 981 | 1021 | 1060 | 1100 | 1145 | 1184 | 1224 | 1263 | 1303 | 1348 | |
| | .30 | 970 | 1015 | 1055 | 1094 | 1134 | 1173 | 1218 | 1258 | 1297 | 1337 | 1376 | 1421 | |
| | .35 | 1105 | 1151 | 1190 | 1230 | 1269 | 1309 | 1349 | 1389 | 1429 | 1468 | 1508 | 1557 | |
| | .40 | 1241 | 1286 | 1326 | 1365 | 1405 | 1444 | 1489 | 1529 | 1568 | 1608 | 1647 | 1692 | |
| | .45 | 1382 | 1427 | 1467 | 1506 | 1546 | 1585 | 1630 | 1670 | 1709 | 1749 | 1788 | 1833 | |
| | .16 | | | | | | | | | | | | | |
| 70,000 | | \$ 784 | 891 | 1004 | 1117 | 1230 | 1342 | 1455 | 1568 | 1675 | 1788 | 1901 | 2014 | <--THEORETICAL HEATING COST * FURNACE ONLY |
| | .05 | \$ 739 | 806 | 874 | 942 | 1004 | 1072 | 1139 | 1207 | 1275 | 1342 | 1410 | 1474 | THEORETICAL HEATING COST * FURN.+ HEAT PUMP \$ PER YEAR |
| | .10 | 789 | 857 | 925 | 993 | 1055 | 1122 | 1190 | 1258 | 1326 | 1393 | 1461 | 1523 | |
| | .15 | 846 | 914 | 981 | 1049 | 1111 | 1179 | 1247 | 1314 | 1382 | 1450 | 1517 | 1579 | |
| | .20 | 897 | 964 | 1032 | 1100 | 1162 | 1230 | 1291 | 1356 | 1421 | 1489 | 1556 | 1620 | |
| | .25 | 953 | 1021 | 1089 | 1156 | 1218 | 1286 | 1354 | 1421 | 1489 | 1557 | 1625 | 1687 | |
| | .30 | 1004 | 1072 | 1139 | 1207 | 1269 | 1337 | 1405 | 1472 | 1540 | 1608 | 1675 | 1737 | |
| | .35 | 1111 | 1179 | 1247 | 1314 | 1376 | 1444 | 1512 | 1579 | 1647 | 1715 | 1783 | 1845 | |
| | .40 | 1218 | 1286 | 1354 | 1421 | 1484 | 1551 | 1619 | 1687 | 1754 | 1822 | 1890 | 1952 | |
| | .45 | 1326 | 1393 | 1461 | 1529 | 1591 | 1658 | 1726 | 1794 | 1862 | 1929 | 1997 | 2059 | |
| | .16 | | | | | | | | | | | | | |
| 80,000 | | \$ 891 | 1021 | 1151 | 1280 | 1405 | 1534 | 1664 | 1788 | 1918 | 2048 | 2172 | 2302 | <--THEORETICAL HEATING COST * FURNACE ONLY |
| | .05 | \$ 835 | 908 | 987 | 1060 | 1139 | 1218 | 1292 | 1371 | 1444 | 1521 | 1596 | 1675 | THEORETICAL HEATING COST * FURN.+ HEAT PUMP \$ PER YEAR |
| | .10 | 897 | 970 | 1049 | 1122 | 1201 | 1280 | 1354 | 1433 | 1506 | 1585 | 1658 | 1737 | |
| | .15 | 953 | 1026 | 1105 | 1179 | 1258 | 1337 | 1410 | 1489 | 1563 | 1642 | 1715 | 1794 | |
| | .20 | 1015 | 1089 | 1168 | 1241 | 1320 | 1399 | 1472 | 1551 | 1625 | 1704 | 1777 | 1856 | |
| | .25 | 1077 | 1151 | 1230 | 1303 | 1382 | 1461 | 1534 | 1613 | 1687 | 1766 | 1839 | 1918 | |
| | .30 | 1134 | 1207 | 1286 | 1359 | 1438 | 1517 | 1591 | 1670 | 1743 | 1822 | 1895 | 1974 | |
| | .35 | 1254 | 1331 | 1410 | 1484 | 1563 | 1642 | 1715 | 1794 | 1867 | 1945 | 2020 | 2099 | |
| | .40 | 1376 | 1450 | 1529 | 1602 | 1681 | 1760 | 1833 | 1912 | 1986 | 2065 | 2138 | 2217 | |
| | .45 | 1495 | 1568 | 1647 | 1721 | 1799 | 1878 | 1952 | 2031 | 2104 | 2183 | 2257 | 2336 | |
| | .16 | | | | | | | | | | | | | |

ANNUAL AIR CONDITIONING COST WHEN COOLING LOAD IS SIZED TO MATCH COOLING CAPACITY OF HEAT PUMP

| | .05 | .06 | .07 | .08 | .09 | .10 | .12 | .14 | .16 | |
|----|-----|-----|-----|-----|-----|-----|-----|-----|-----|--------------------------------------|
| \$ | 155 | 186 | 218 | 249 | 280 | 311 | 373 | 436 | 498 | <--ELECTRIC RATE \$/KWH |
| | | | | | | | | | | <--THEORETICAL AIR CONDITIONING COST |

THE ABOVE ANNUAL HEATING AND COOLING OPERATING COSTS ARE THEORETICAL ESTIMATES ONLY AND ARE PROVIDED FOR A COMMON BASIS OF COMPARISON BETWEEN VARIOUS TYPES OF HEATING AND COOLING SYSTEMS. ACTUAL VALUES MAY VARY DEPENDING ON ACTUAL WEATHER CONDITIONS AND INDIVIDUAL USAGE PATTERN.

BARD MANUFACTURING COMPANY

DUAL FUEL ADD-ON HEAT PUMP GUIDE TO ENERGY COST SAVINGS

ZONE 4
 HEAT PUMP MODEL: OUTDOOR 42URPOA 42URPQA/A61AC-B INDOOR A61AC-A
 AIR RATED COOLING CAP.: BTUH (95) 40000 SEER 11.30
 AIR RATED HEATING CAP.: BTUH (47) 40000 COP (47) 3.40, BSFP 7.60 MIN. OMR RSG IV
 FURNACE TYPE PROGRAM GAS FURNACE EFFICIENCY 78.00 % AFUE

| HEAT LOSS BTUH | ELEC. COST \$/KWH | PROPANE GAS COST - \$/GALLON | | | | | | | | | | | | |
|----------------|-------------------|------------------------------|------|------|------|------|------|------|------|------|------|------|------|---|
| | | .60 | .65 | .70 | .75 | .80 | .85 | .90 | .95 | 1.00 | 1.10 | 1.20 | 1.20 | |
| 40,000 | | \$ 581 | 631 | 682 | 727 | 778 | 829 | 874 | 925 | 976 | 1072 | 1168 | 1168 | <--THEORETICAL HEATING COST * FURNACE ONLY |
| | .05 | \$ 451 | 457 | 462 | 468 | 473 | 479 | 485 | 490 | 496 | 507 | 519 | 519 | THEORETICAL HEATING COST * FURN.+ HEAT PUMP \$ PER YEAR |
| | .06 | \$ 474 | 480 | 485 | 491 | 497 | 503 | 509 | 514 | 520 | 532 | 545 | 545 | |
| | .07 | \$ 497 | 503 | 509 | 515 | 521 | 527 | 533 | 539 | 545 | 558 | 571 | 571 | |
| | .08 | \$ 520 | 526 | 532 | 538 | 544 | 550 | 556 | 562 | 568 | 581 | 594 | 594 | |
| | .09 | \$ 543 | 549 | 555 | 561 | 567 | 573 | 579 | 585 | 591 | 604 | 617 | 617 | |
| | .10 | \$ 566 | 572 | 578 | 584 | 590 | 596 | 602 | 608 | 614 | 627 | 640 | 640 | |
| | .12 | \$ 612 | 618 | 624 | 630 | 636 | 642 | 648 | 654 | 660 | 673 | 686 | 686 | |
| | .14 | \$ 658 | 664 | 670 | 676 | 682 | 688 | 694 | 700 | 706 | 719 | 732 | 732 | |
| | .16 | \$ 704 | 710 | 716 | 722 | 728 | 734 | 740 | 746 | 752 | 765 | 778 | 778 | BALANCE POINT 16 DEG.F. |
| 50,000 | | \$ 727 | 789 | 852 | 914 | 976 | 1032 | 1094 | 1156 | 1218 | 1337 | 1461 | 1461 | <--THEORETICAL HEATING COST * FURNACE ONLY |
| | .05 | \$ 575 | 592 | 609 | 626 | 643 | 660 | 677 | 693 | 716 | 750 | 784 | 784 | THEORETICAL HEATING COST * FURN.+ HEAT PUMP \$ PER YEAR |
| | .06 | \$ 598 | 615 | 632 | 649 | 666 | 683 | 700 | 717 | 740 | 774 | 808 | 808 | |
| | .07 | \$ 621 | 638 | 655 | 672 | 689 | 706 | 723 | 740 | 763 | 797 | 831 | 831 | |
| | .08 | \$ 644 | 661 | 678 | 695 | 712 | 729 | 746 | 763 | 786 | 820 | 854 | 854 | |
| | .09 | \$ 667 | 684 | 701 | 718 | 735 | 752 | 769 | 786 | 809 | 843 | 877 | 877 | |
| | .10 | \$ 690 | 707 | 724 | 741 | 758 | 775 | 792 | 809 | 832 | 866 | 900 | 900 | |
| | .12 | \$ 736 | 753 | 770 | 787 | 804 | 821 | 838 | 855 | 878 | 912 | 946 | 946 | |
| | .14 | \$ 782 | 799 | 816 | 833 | 850 | 867 | 884 | 901 | 924 | 958 | 992 | 992 | |
| | .16 | \$ 828 | 845 | 862 | 879 | 896 | 913 | 930 | 947 | 970 | 1004 | 1038 | 1038 | BALANCE POINT 23 DEG.F. |
| 60,000 | | \$ 874 | 947 | 1021 | 1094 | 1168 | 1241 | 1314 | 1388 | 1461 | 1608 | 1754 | 1754 | <--THEORETICAL HEATING COST * FURNACE ONLY |
| | .05 | \$ 716 | 744 | 778 | 806 | 840 | 868 | 902 | 931 | 964 | 1026 | 1089 | 1089 | THEORETICAL HEATING COST * FURN.+ HEAT PUMP \$ PER YEAR |
| | .06 | \$ 739 | 767 | 801 | 829 | 863 | 891 | 925 | 954 | 987 | 1049 | 1112 | 1112 | |
| | .07 | \$ 762 | 790 | 824 | 852 | 886 | 914 | 948 | 977 | 1010 | 1072 | 1135 | 1135 | |
| | .08 | \$ 785 | 813 | 847 | 875 | 909 | 937 | 971 | 1000 | 1033 | 1095 | 1158 | 1158 | |
| | .09 | \$ 808 | 836 | 870 | 898 | 932 | 960 | 994 | 1023 | 1056 | 1118 | 1181 | 1181 | |
| | .10 | \$ 831 | 859 | 893 | 921 | 955 | 983 | 1017 | 1046 | 1079 | 1141 | 1204 | 1204 | |
| | .12 | \$ 877 | 905 | 939 | 967 | 1001 | 1029 | 1063 | 1092 | 1125 | 1187 | 1250 | 1250 | |
| | .14 | \$ 923 | 951 | 985 | 1013 | 1047 | 1075 | 1109 | 1138 | 1171 | 1233 | 1296 | 1296 | |
| | .16 | \$ 969 | 997 | 1031 | 1059 | 1093 | 1121 | 1155 | 1184 | 1217 | 1279 | 1342 | 1342 | BALANCE POINT 28 DEG.F. |
| 70,000 | | \$ 1021 | 1105 | 1190 | 1280 | 1365 | 1450 | 1534 | 1619 | 1704 | 1878 | 2048 | 2048 | <--THEORETICAL HEATING COST * FURNACE ONLY |
| | .05 | \$ 880 | 931 | 981 | 1038 | 1089 | 1139 | 1190 | 1241 | 1292 | 1393 | 1495 | 1495 | THEORETICAL HEATING COST * FURN.+ HEAT PUMP \$ PER YEAR |
| | .06 | \$ 903 | 954 | 1004 | 1061 | 1112 | 1163 | 1214 | 1265 | 1316 | 1417 | 1519 | 1519 | |
| | .07 | \$ 926 | 977 | 1027 | 1084 | 1135 | 1186 | 1237 | 1288 | 1339 | 1440 | 1542 | 1542 | |
| | .08 | \$ 949 | 1000 | 1050 | 1107 | 1158 | 1209 | 1260 | 1311 | 1362 | 1463 | 1565 | 1565 | |
| | .09 | \$ 972 | 1023 | 1073 | 1130 | 1181 | 1232 | 1283 | 1334 | 1385 | 1486 | 1588 | 1588 | |
| | .10 | \$ 995 | 1046 | 1096 | 1153 | 1204 | 1255 | 1306 | 1357 | 1408 | 1509 | 1611 | 1611 | |
| | .12 | \$ 1041 | 1092 | 1142 | 1200 | 1251 | 1302 | 1353 | 1404 | 1455 | 1556 | 1658 | 1658 | |
| | .14 | \$ 1087 | 1138 | 1188 | 1245 | 1296 | 1347 | 1398 | 1449 | 1500 | 1601 | 1703 | 1703 | |
| | .16 | \$ 1133 | 1184 | 1234 | 1291 | 1342 | 1393 | 1444 | 1495 | 1546 | 1647 | 1749 | 1749 | BALANCE POINT 32 DEG.F. |
| 80,000 | | \$ 1168 | 1263 | 1365 | 1461 | 1557 | 1658 | 1754 | 1850 | 1952 | 2144 | 2341 | 2341 | <--THEORETICAL HEATING COST * FURNACE ONLY |
| | .05 | \$ 998 | 1055 | 1117 | 1173 | 1230 | 1292 | 1348 | 1405 | 1461 | 1579 | 1698 | 1698 | THEORETICAL HEATING COST * FURN.+ HEAT PUMP \$ PER YEAR |
| | .06 | \$ 1021 | 1078 | 1139 | 1195 | 1252 | 1314 | 1370 | 1427 | 1483 | 1601 | 1720 | 1720 | |
| | .07 | \$ 1044 | 1101 | 1162 | 1218 | 1275 | 1331 | 1388 | 1444 | 1500 | 1618 | 1737 | 1737 | |
| | .08 | \$ 1067 | 1124 | 1185 | 1241 | 1298 | 1354 | 1410 | 1467 | 1523 | 1641 | 1760 | 1760 | |
| | .09 | \$ 1090 | 1147 | 1208 | 1264 | 1321 | 1377 | 1434 | 1490 | 1546 | 1664 | 1783 | 1783 | |
| | .10 | \$ 1113 | 1170 | 1231 | 1287 | 1344 | 1400 | 1457 | 1513 | 1569 | 1687 | 1806 | 1806 | |
| | .12 | \$ 1159 | 1216 | 1277 | 1333 | 1390 | 1446 | 1503 | 1559 | 1615 | 1733 | 1852 | 1852 | |
| | .14 | \$ 1205 | 1262 | 1323 | 1379 | 1436 | 1492 | 1549 | 1605 | 1661 | 1779 | 1898 | 1898 | |
| | .16 | \$ 1251 | 1308 | 1369 | 1425 | 1482 | 1538 | 1594 | 1650 | 1706 | 1824 | 1943 | 1943 | BALANCE POINT 35 DEG.F. |

ANNUAL AIR CONDITIONING COST WHEN COOLING LOAD IS SIZED TO MATCH COOLING CAPACITY OF HEAT PUMP
 \$.05 .06 .07 .08 .09 .10 .12 .14 .16 <--ELECTRIC RATE \$/KWH
 <--THEORETICAL AIR CONDITIONING COST

THE ABOVE ANNUAL HEATING AND COOLING OPERATING COSTS ARE THEORETICAL ESTIMATES ONLY AND ARE PROVIDED FOR A COMMON BASIS OF COMPARISON BETWEEN VARIOUS TYPES OF HEATING AND COOLING SYSTEMS. ACTUAL VALUES MAY VARY DEPENDING ON ACTUAL WEATHER CONDITIONS AND INDIVIDUAL USAGE PATTERN.

BARD MANUFACTURING COMPANY
 DUAL FUEL ADD-ON HEAT PUMP GUIDE TO ENERGY COST SAVINGS

REGION 4
 HEAT PUMP MODEL: OUTDOOR 48H90R 48H90R/A51A0-A INDOOR A51A0-A
 AIR RATIO COOLING CAP.: BTUH(95) 50000 SEER10.50
 AIR RATIO HEATING CAP.: BTUH(47) 48000 COP(47) 3.20 HSPF 1.40 MIN. DHR DEG IV
 FURNACE TYPE ELECTRIC FURNACE EFFICIENCY 100.00 % AFUE

| HEAT LOSS BTUH | ELEC. COST \$/KWH | HEAT PUMP WITH ELECTRIC HEAT | ELECTRIC HEAT ONLY | |
|---|-------------------|------------------------------|--------------------|-------------------------|
| 60,000 | | | | |
| --- THEORETICAL ANNUAL HEATING COST --- | | | | |
| | | HEAT PUMP WITH ELECTRIC HEAT | ELECTRIC HEAT ONLY | |
| .05 | \$ | 739 | 1517 | |
| .06 | | 890 | 1822 | |
| .07 | | 1026 | 2139 | |
| .08 | | 1179 | 2431 | |
| .09 | | 1326 | 2736 | |
| .10 | | 1467 | 3031 | |
| .12 | | 1706 | 3650 | |
| .14 | | 1959 | 4260 | BALANCE POINT 24 DEG.F. |
| .16 | | 2352 | 4869 | |
| 70,000 | | | | |
| --- THEORETICAL ANNUAL HEATING COST --- | | | | |
| | | HEAT PUMP WITH ELECTRIC HEAT | ELECTRIC HEAT ONLY | |
| .05 | \$ | 890 | 1771 | |
| .06 | | 1060 | 2121 | |
| .07 | | 1235 | 2482 | |
| .08 | | 1410 | 2838 | |
| .09 | | 1585 | 3193 | |
| .10 | | 1760 | 3549 | |
| .12 | | 2115 | 4260 | BALANCE POINT 28 DEG.F. |
| .14 | | 2465 | 4971 | |
| .16 | | 2821 | 5682 | |
| 80,000 | | | | |
| --- THEORETICAL ANNUAL HEATING COST --- | | | | |
| | | HEAT PUMP WITH ELECTRIC HEAT | ELECTRIC HEAT ONLY | |
| .05 | \$ | 1043 | 2025 | |
| .06 | | 1247 | 2431 | |
| .07 | | 1461 | 2838 | |
| .08 | | 1674 | 3244 | |
| .09 | | 1873 | 3650 | |
| .10 | | 2082 | 4057 | |
| .12 | | 2502 | 4869 | BALANCE POINT 32 DEG.F. |
| .14 | | 2917 | 5682 | |
| .16 | | 3334 | 6494 | |
| 90,000 | | | | |
| --- THEORETICAL ANNUAL HEATING COST --- | | | | |
| | | HEAT PUMP WITH ELECTRIC HEAT | ELECTRIC HEAT ONLY | |
| .05 | \$ | 1230 | 2279 | |
| .06 | | 1472 | 2736 | |
| .07 | | 1714 | 3193 | |
| .08 | | 1953 | 3650 | |
| .09 | | 2211 | 4107 | |
| .10 | | 2444 | 4564 | |
| .12 | | 2945 | 5478 | BALANCE POINT 35 DEG.F. |
| .14 | | 3436 | 6390 | |
| .16 | | 3927 | 7307 | |
| 100,000 | | | | |
| --- THEORETICAL ANNUAL HEATING COST --- | | | | |
| | | HEAT PUMP WITH ELECTRIC HEAT | ELECTRIC HEAT ONLY | |
| .05 | \$ | 1416 | 2533 | |
| .06 | | 1698 | 3041 | |
| .07 | | 1986 | 3549 | |
| .08 | | 2268 | 4057 | |
| .09 | | 2552 | 4564 | |
| .10 | | 2834 | 5072 | |
| .12 | | 3407 | 6088 | BALANCE POINT 37 DEG.F. |
| .14 | | 3973 | 7104 | |
| .16 | | 4542 | 8119 | |

ANNUAL AIR CONDITIONING COST WHEN COOLING LOAD IS SIZED TO MATCH COOLING CAPACITY OF HEAT PUMP

| | | | | | | | | | | |
|----|-----|-----|-----|-----|-----|-----|-----|-----|-----|--|
| | .05 | .06 | .07 | .09 | .09 | .10 | .12 | .14 | .16 | |
| \$ | 190 | 228 | 266 | 304 | 342 | 380 | 457 | 533 | 609 | |

<-- ELECTRIC RATE \$/KWH
 <-- THEORETICAL AIR CONDITIONING COST

THE ABOVE ANNUAL HEATING AND COOLING OPERATING COSTS ARE THEORETICAL ESTIMATES ONLY AND ARE PROVIDED FOR A COMMON BASIS OF COMPARISON BETWEEN VARIOUS TYPES OF HEATING AND COOLING SYSTEMS. ACTUAL VALUES MAY VARY DEPENDING ON ACTUAL WEATHER CONDITIONS AND INDIVIDUAL USAGE PATTERN.

BARD MANUFACTURING COMPANY

DOAL FUEL ADD-ON HEAT PUMP GUIDE TO ENERGY COST SAVINGS

REGION 4
 HEAT PUMP MODE: OUTDOOR AIR/DOOR 48MBP08/AS1AQ-A
 HEAT COOLING CAP.: FURN(95) 50000 SHR10.50 INDOOR AS1AQ-A
 RATED HEATING CAP.: FURN(47) 50000 COP(47) 3.20 HSPT 7.40 MIN.DHR REQ IV
 FURNACE TYPE NATURAL GAS FURNACE EFFICIENCY 78.00 % HEUR

| HEAT PUMP COST \$/KW | HEAT PUMP \$/KW | NATURAL GAS COST - \$/THERM | | | | | | | | | | | | |
|----------------------|-----------------|-----------------------------|------|------|------|------|------|------|------|------|------|------|--|--|
| | | .35 | .40 | .45 | .50 | .55 | .60 | .65 | .70 | .75 | .80 | | .90 | 1.00 |
| | | \$ 383 | 440 | 496 | 552 | 609 | 665 | 716 | 773 | 829 | 885 | 998 | 1105 | <--THEORETICAL HEATING COST * FURNACE ONLY |
| .05 | 524 | 536 | 541 | 552 | 564 | 575 | 586 | 598 | 603 | 615 | 637 | 660 | THEORETICAL HEATING COST * FURN. + HEAT PUMP \$ PER YEAR | |
| .08 | 615 | 726 | 831 | 937 | 1044 | 1151 | 1258 | 1365 | 1472 | 1579 | 1747 | 1915 | | |
| .10 | 706 | 806 | 912 | 1018 | 1124 | 1230 | 1336 | 1442 | 1548 | 1654 | 1842 | 2030 | | |
| .12 | 797 | 897 | 997 | 1097 | 1197 | 1297 | 1397 | 1497 | 1597 | 1697 | 1915 | 2133 | | |
| .14 | 888 | 988 | 1088 | 1188 | 1288 | 1388 | 1488 | 1588 | 1688 | 1788 | 2030 | 2272 | | |
| .16 | 979 | 1079 | 1179 | 1279 | 1379 | 1479 | 1579 | 1679 | 1779 | 1879 | 2133 | 2375 | BALANCE POINT 18 DEG.F. | |
| | | \$ 462 | 530 | 598 | 665 | 727 | 795 | 863 | 931 | 998 | 1066 | 1134 | <--THEORETICAL HEATING COST * FURNACE ONLY | |
| .05 | 598 | 615 | 631 | 654 | 671 | 688 | 710 | 727 | 744 | 767 | 806 | 840 | THEORETICAL HEATING COST * FURN. + HEAT PUMP \$ PER YEAR | |
| .08 | 688 | 706 | 722 | 744 | 761 | 778 | 801 | 818 | 835 | 857 | 897 | 931 | | |
| .10 | 779 | 801 | 818 | 840 | 857 | 874 | 891 | 914 | 931 | 953 | 993 | 1026 | | |
| .12 | 870 | 891 | 908 | 931 | 947 | 964 | 981 | 1004 | 1021 | 1043 | 1083 | 1117 | | |
| .14 | 961 | 981 | 998 | 1021 | 1038 | 1055 | 1071 | 1094 | 1111 | 1134 | 1173 | 1207 | | |
| .16 | 1052 | 1071 | 1094 | 1117 | 1134 | 1151 | 1173 | 1190 | 1207 | 1230 | 1269 | 1303 | BALANCE POINT 24 DEG.F. | |
| | | \$ 541 | 620 | 694 | 773 | 852 | 931 | 1010 | 1089 | 1162 | 1241 | 1320 | 1511 | <--THEORETICAL HEATING COST * FURNACE ONLY |
| .05 | 694 | 698 | 714 | 750 | 784 | 818 | 852 | 885 | 914 | 947 | 1015 | 1083 | THEORETICAL HEATING COST * FURN. + HEAT PUMP \$ PER YEAR | |
| .08 | 784 | 801 | 818 | 835 | 852 | 869 | 891 | 908 | 925 | 947 | 1006 | 1074 | | |
| .10 | 875 | 891 | 908 | 914 | 947 | 964 | 981 | 1004 | 1021 | 1043 | 1083 | 1117 | | |
| .12 | 966 | 981 | 998 | 1021 | 1038 | 1055 | 1071 | 1094 | 1111 | 1134 | 1173 | 1207 | | |
| .14 | 1057 | 1071 | 1094 | 1117 | 1134 | 1151 | 1173 | 1190 | 1207 | 1230 | 1269 | 1303 | | |
| .16 | 1148 | 1161 | 1179 | 1197 | 1214 | 1230 | 1247 | 1264 | 1281 | 1303 | 1342 | 1376 | BALANCE POINT 28 DEG.F. | |
| | | \$ 620 | 705 | 795 | 885 | 976 | 1066 | 1151 | 1241 | 1331 | 1416 | 1596 | 1771 | <--THEORETICAL HEATING COST * FURNACE ONLY |
| .05 | 795 | 798 | 814 | 850 | 884 | 918 | 952 | 985 | 1014 | 1047 | 1115 | 1183 | THEORETICAL HEATING COST * FURN. + HEAT PUMP \$ PER YEAR | |
| .08 | 885 | 901 | 918 | 935 | 952 | 969 | 991 | 1015 | 1049 | 1077 | 1111 | 1147 | | |
| .10 | 976 | 991 | 1008 | 1025 | 1042 | 1059 | 1081 | 1104 | 1127 | 1150 | 1183 | 1217 | | |
| .12 | 1067 | 1081 | 1098 | 1115 | 1132 | 1149 | 1171 | 1194 | 1217 | 1240 | 1273 | 1307 | | |
| .14 | 1158 | 1171 | 1188 | 1205 | 1222 | 1239 | 1261 | 1284 | 1307 | 1330 | 1363 | 1397 | | |
| .16 | 1249 | 1261 | 1279 | 1296 | 1313 | 1330 | 1352 | 1375 | 1398 | 1421 | 1454 | 1488 | BALANCE POINT 31 DEG.F. | |
| | | \$ 694 | 795 | 897 | 998 | 1094 | 1196 | 1297 | 1393 | 1495 | 1596 | 1794 | 1997 | <--THEORETICAL HEATING COST * FURNACE ONLY |
| .05 | 897 | 898 | 914 | 950 | 984 | 1018 | 1052 | 1085 | 1114 | 1147 | 1215 | 1283 | THEORETICAL HEATING COST * FURN. + HEAT PUMP \$ PER YEAR | |
| .08 | 987 | 1001 | 1018 | 1035 | 1052 | 1069 | 1091 | 1114 | 1137 | 1160 | 1193 | 1227 | | |
| .10 | 1078 | 1091 | 1108 | 1125 | 1142 | 1159 | 1181 | 1204 | 1227 | 1250 | 1283 | 1317 | | |
| .12 | 1169 | 1181 | 1198 | 1215 | 1232 | 1249 | 1271 | 1294 | 1317 | 1340 | 1373 | 1407 | | |
| .14 | 1260 | 1271 | 1288 | 1305 | 1322 | 1339 | 1361 | 1384 | 1407 | 1430 | 1463 | 1497 | | |
| .16 | 1351 | 1361 | 1379 | 1396 | 1413 | 1430 | 1452 | 1475 | 1498 | 1521 | 1554 | 1588 | BALANCE POINT 35 DEG.F. | |
| | | \$ 773 | 885 | 998 | 1105 | 1218 | 1331 | 1438 | 1551 | 1664 | 1771 | 1997 | 2217 | <--THEORETICAL HEATING COST * FURNACE ONLY |
| .05 | 998 | 998 | 1014 | 1050 | 1084 | 1118 | 1152 | 1185 | 1214 | 1247 | 1315 | 1383 | THEORETICAL HEATING COST * FURN. + HEAT PUMP \$ PER YEAR | |
| .08 | 1088 | 1101 | 1118 | 1135 | 1152 | 1174 | 1197 | 1220 | 1243 | 1266 | 1309 | 1343 | | |
| .10 | 1179 | 1191 | 1208 | 1225 | 1242 | 1264 | 1287 | 1310 | 1333 | 1356 | 1389 | 1423 | | |
| .12 | 1270 | 1281 | 1298 | 1315 | 1332 | 1354 | 1377 | 1400 | 1423 | 1446 | 1479 | 1513 | | |
| .14 | 1361 | 1371 | 1388 | 1405 | 1422 | 1444 | 1467 | 1490 | 1513 | 1536 | 1569 | 1603 | | |
| .16 | 1452 | 1461 | 1479 | 1496 | 1513 | 1535 | 1558 | 1581 | 1604 | 1627 | 1660 | 1694 | BALANCE POINT 37 DEG.F. | |

ANNUAL AIR CONDITIONING COST WHEN COOLING LOAD IS SIZED TO MATCH COOLING CAPACITY OF HEAT PUMP

.05 .06 .07 .08 .09 .10 .12 .14 .16 <--ELECTRIC RATE \$/KWH

THE ABOVE ANNUAL HEATING AND COOLING OPERATING COSTS ARE THEORETICAL ESTIMATES ONLY AND ARE PROVIDED FOR A COMMON BASIS OF COMPARISON BETWEEN VARIOUS TYPES OF HEATING AND COOLING SYSTEMS. ACTUAL VALUES MAY VARY DEPENDING ON ACTUAL WEATHER CONDITIONS AND INDIVIDUAL USAGE PATTERNS.

DAVID MANUFACTURING COMPANY
DUAL FUEL ADD-ON HEAT PUMP GUIDE TO ENERGY COST SAVINGS

SECTION 4
 HEAT PUMP MODEL: OUTDOOR 48RUP08 48RUP08/A51AO-A
 INDOOR: A51AO-A
 RATED COOLING CAP.: BTUH (95) 30000 COP(10) 5.0
 RATED HEATING CAP.: BTUH (47) 30000 COP(47) 3.20 RSPY 1.40 MIN. DTR REG IV
 FURNACE TYPE FUEL OIL FURNACE EFFICIENCY 78.00 % AQUE

| HEAT PUMP BTUH | ELEC. COST \$/KWH | HEATING OIL COST - \$/GALLON | | | | | | | | | | | | | | |
|-------------------|-------------------------|------------------------------|------|------|------|------|------|------|------|------|------|------|------|---|--|--|
| | | .70 | .80 | .90 | 1.00 | 1.10 | 1.20 | 1.30 | 1.40 | 1.50 | 1.60 | 1.70 | 1.80 | | | |
| 50,000 | | \$ 558 | 637 | 716 | 795 | 880 | 959 | 1038 | 1117 | 1196 | 1280 | 1359 | 1438 | ←←-THEORETICAL HEATING COST * FURNACE ONLY | | |
| .05 | | 552 | 569 | 586 | 598 | 615 | 631 | 643 | 660 | 677 | 688 | 705 | 716 | THEORETICAL HEATING COST * FURN. + HEAT PUMP \$ PER YEAR | | |
| .06 | | 643 | 660 | 677 | 688 | 705 | 722 | 733 | 750 | 767 | 778 | 795 | 806 | | | |
| .07 | | 733 | 750 | 767 | 778 | 795 | 812 | 823 | 840 | 857 | 868 | 885 | 897 | | | |
| .08 | | 823 | 840 | 857 | 868 | 885 | 902 | 913 | 930 | 947 | 958 | 975 | 987 | | | |
| .09 | | 914 | 931 | 947 | 958 | 975 | 992 | 1004 | 1021 | 1038 | 1049 | 1066 | 1077 | | | |
| .10 | | 1010 | 1026 | 1043 | 1055 | 1072 | 1089 | 1100 | 1117 | 1134 | 1145 | 1162 | 1173 | | | |
| .12 | | 1190 | 1207 | 1224 | 1235 | 1252 | 1269 | 1280 | 1297 | 1314 | 1326 | 1343 | 1354 | | | |
| .14 | | 1371 | 1388 | 1405 | 1416 | 1433 | 1450 | 1461 | 1478 | 1495 | 1506 | 1523 | 1534 | | | |
| .16 | | 1551 | 1568 | 1585 | 1596 | 1613 | 1630 | 1642 | 1658 | 1675 | 1687 | 1704 | 1715 | BALANCE POINT 18 DEG.F. | | |
| 60,000 | | \$ 671 | 767 | 863 | 959 | 1055 | 1151 | 1247 | 1342 | 1438 | 1534 | 1630 | 1726 | ←←-THEORETICAL HEATING COST * FURNACE ONLY | | |
| .05 | | 654 | 662 | 710 | 733 | 761 | 789 | 818 | 846 | 874 | 902 | 925 | 953 | THEORETICAL HEATING COST * FURN. + HEAT PUMP \$ PER YEAR | | |
| .06 | | 744 | 773 | 801 | 823 | 851 | 880 | 908 | 936 | 964 | 993 | 1015 | 1043 | | | |
| .07 | | 840 | 868 | 897 | 919 | 947 | 976 | 1004 | 1032 | 1060 | 1089 | 1111 | 1139 | | | |
| .08 | | 931 | 959 | 987 | 1010 | 1038 | 1066 | 1094 | 1122 | 1151 | 1179 | 1201 | 1230 | | | |
| .09 | | 1021 | 1049 | 1077 | 1100 | 1128 | 1156 | 1184 | 1212 | 1241 | 1269 | 1298 | 1326 | | | |
| .10 | | 1110 | 1145 | 1173 | 1201 | 1229 | 1257 | 1285 | 1313 | 1341 | 1369 | 1398 | 1426 | | | |
| .12 | | 1303 | 1331 | 1359 | 1387 | 1415 | 1443 | 1471 | 1499 | 1527 | 1555 | 1583 | 1611 | | | |
| .14 | | 1484 | 1513 | 1540 | 1568 | 1596 | 1624 | 1652 | 1680 | 1708 | 1736 | 1764 | 1792 | | | |
| .16 | | 1670 | 1698 | 1726 | 1754 | 1782 | 1810 | 1838 | 1866 | 1894 | 1922 | 1950 | 1978 | BALANCE POINT 24 DEG.F. | | |
| 70,000 | | \$ 784 | 891 | 1004 | 1117 | 1230 | 1342 | 1455 | 1568 | 1675 | 1788 | 1901 | 2014 | ←←-THEORETICAL HEATING COST * FURNACE ONLY | | |
| .05 | | 756 | 801 | 852 | 897 | 942 | 993 | 1038 | 1089 | 1134 | 1179 | 1230 | 1275 | THEORETICAL HEATING COST * FURN. + HEAT PUMP \$ PER YEAR | | |
| .06 | | 846 | 891 | 936 | 981 | 1026 | 1077 | 1123 | 1173 | 1218 | 1263 | 1314 | 1359 | | | |
| .07 | | 919 | 964 | 1015 | 1060 | 1105 | 1156 | 1201 | 1252 | 1297 | 1342 | 1393 | 1438 | | | |
| .08 | | 1004 | 1049 | 1100 | 1145 | 1190 | 1241 | 1286 | 1332 | 1377 | 1422 | 1473 | 1518 | | | |
| .09 | | 1089 | 1134 | 1184 | 1230 | 1275 | 1326 | 1371 | 1416 | 1461 | 1506 | 1551 | 1601 | | | |
| .10 | | 1173 | 1218 | 1269 | 1314 | 1359 | 1410 | 1455 | 1506 | 1551 | 1596 | 1647 | 1692 | | | |
| .12 | | 1342 | 1387 | 1438 | 1484 | 1529 | 1574 | 1625 | 1675 | 1726 | 1771 | 1816 | 1861 | | | |
| .14 | | 1512 | 1557 | 1608 | 1653 | 1704 | 1749 | 1794 | 1845 | 1890 | 1935 | 1986 | 2031 | | | |
| .16 | | 1681 | 1726 | 1777 | 1822 | 1867 | 1918 | 1963 | 2014 | 2059 | 2104 | 2155 | 2200 | BALANCE POINT 28 DEG.F. | | |
| 80,000 | | \$ 891 | 1021 | 1151 | 1280 | 1405 | 1534 | 1664 | 1788 | 1918 | 2048 | 2172 | 2302 | ←←-THEORETICAL HEATING COST * FURNACE ONLY | | |
| .05 | | 857 | 931 | 1010 | 1083 | 1162 | 1241 | 1314 | 1393 | 1467 | 1546 | 1619 | 1698 | THEORETICAL HEATING COST * FURN. + HEAT PUMP \$ PER YEAR | | |
| .06 | | 925 | 998 | 1077 | 1151 | 1230 | 1309 | 1382 | 1461 | 1534 | 1613 | 1687 | 1766 | | | |
| .07 | | 987 | 1060 | 1139 | 1213 | 1292 | 1371 | 1444 | 1523 | 1596 | 1675 | 1749 | 1828 | | | |
| .08 | | 1055 | 1128 | 1207 | 1280 | 1359 | 1438 | 1512 | 1591 | 1664 | 1743 | 1816 | 1895 | | | |
| .09 | | 1117 | 1190 | 1269 | 1343 | 1421 | 1500 | 1574 | 1653 | 1726 | 1805 | 1878 | 1957 | | | |
| .10 | | 1184 | 1258 | 1337 | 1410 | 1489 | 1568 | 1642 | 1721 | 1794 | 1873 | 1946 | 2025 | | | |
| .12 | | 1314 | 1388 | 1467 | 1540 | 1619 | 1698 | 1771 | 1850 | 1924 | 2003 | 2076 | 2155 | | | |
| .14 | | 1444 | 1517 | 1596 | 1670 | 1749 | 1828 | 1901 | 1980 | 2053 | 2132 | 2206 | 2285 | | | |
| .16 | | 1568 | 1642 | 1721 | 1794 | 1873 | 1952 | 2025 | 2104 | 2178 | 2257 | 2330 | 2409 | BALANCE POINT 32 DEG.F. | | |
| 90,000 | | \$ 1004 | 1151 | 1292 | 1438 | 1579 | 1726 | 1873 | 2014 | 2161 | 2302 | 2448 | 2589 | ←←-THEORETICAL HEATING COST * FURNACE ONLY | | |
| .05 | | 959 | 1043 | 1128 | 1213 | 1303 | 1388 | 1472 | 1557 | 1647 | 1732 | 1816 | 1901 | THEORETICAL HEATING COST * FURN. + HEAT PUMP \$ PER YEAR | | |
| .06 | | 1027 | 1117 | 1201 | 1286 | 1375 | 1461 | 1546 | 1630 | 1712 | 1795 | 1878 | 1961 | | | |
| .07 | | 1105 | 1190 | 1275 | 1359 | 1450 | 1534 | 1618 | 1704 | 1791 | 1878 | 1963 | 2048 | | | |
| .08 | | 1173 | 1258 | 1343 | 1427 | 1517 | 1602 | 1687 | 1771 | 1852 | 1946 | 2031 | 2115 | | | |
| .09 | | 1241 | 1331 | 1416 | 1500 | 1591 | 1675 | 1760 | 1845 | 1935 | 2020 | 2104 | 2189 | | | |
| .10 | | 1310 | 1405 | 1489 | 1574 | 1664 | 1749 | 1833 | 1918 | 2008 | 2093 | 2178 | 2262 | | | |
| .12 | | 1481 | 1576 | 1660 | 1745 | 1835 | 1920 | 2005 | 2090 | 2175 | 2260 | 2345 | 2430 | | | |
| .14 | | 1608 | 1703 | 1787 | 1882 | 1972 | 2067 | 2152 | 2237 | 2322 | 2407 | 2492 | 2577 | | | |
| .16 | | 1749 | 1833 | 1918 | 2003 | 2093 | 2178 | 2262 | 2347 | 2437 | 2522 | 2606 | 2691 | BALANCE POINT 35 DEG.F. | | |
| 100,000 | | \$ 1117 | 1280 | 1438 | 1596 | 1760 | 1918 | 2076 | 2240 | 2398 | 2561 | 2719 | 2877 | ←←-THEORETICAL HEATING COST * FURNACE ONLY | | |
| .05 | | 1072 | 1184 | 1303 | 1421 | 1534 | 1653 | 1766 | 1884 | 1997 | 2115 | 2228 | 2347 | THEORETICAL HEATING COST * FURN. + HEAT PUMP \$ PER YEAR | | |
| .06 | | 1149 | 1265 | 1384 | 1503 | 1622 | 1741 | 1854 | 1972 | 2085 | 2193 | 2306 | 2425 | | | |
| .07 | | 1230 | 1346 | 1465 | 1584 | 1703 | 1822 | 1941 | 2060 | 2179 | 2298 | 2417 | 2536 | | | |
| .08 | | 1310 | 1426 | 1545 | 1664 | 1783 | 1902 | 2021 | 2140 | 2259 | 2378 | 2497 | 2616 | | | |
| .09 | | 1391 | 1507 | 1626 | 1745 | 1864 | 1983 | 2102 | 2221 | 2340 | 2459 | 2578 | 2697 | | | |
| .10 | | 1472 | 1588 | 1707 | 1826 | 1945 | 2064 | 2183 | 2302 | 2421 | 2540 | 2659 | 2778 | | | |
| .12 | | 1653 | 1769 | 1888 | 2007 | 2126 | 2245 | 2364 | 2483 | 2602 | 2721 | 2840 | 2959 | | | |
| .14 | | 1834 | 1950 | 2069 | 2188 | 2307 | 2426 | 2545 | 2664 | 2783 | 2902 | 3021 | 3140 | | | |
| .16 | | 1947 | 2066 | 2185 | 2304 | 2423 | 2542 | 2661 | 2780 | 2900 | 3019 | 3138 | 3257 | BALANCE POINT 37 DEG.F. | | |

ANNUAL AIR CONDITIONING COST WHEN COOLING LOAD IS SIZED TO MATCH COOLING CAPACITY OF HEAT PUMP
 ←←-ELECTRIC RATE \$/KWH
 .05 .06 .07 .08 .09 .10 .12 .14 .16

THE ABOVE ANNUAL HEATING AND COOLING HEATING COSTS ARE THEORETICAL ESTIMATES ONLY AND ARE PROVIDED FOR A COMMON BASIS OF COMPARISON BETWEEN VARIOUS TYPES OF HEATING AND COOLING SYSTEMS. ACTUAL VALUES MAY VARY DEPENDING ON ACTUAL WEATHER CONDITIONS AND INDIVIDUAL USAGE PATTERN.

LARD MANUFACTURING COMPANY

DUAL FUEL ADD-ON HEAT PUMP GUIDE TO ENERGY COST SAVINGS

REGION 4
 HEAT PUMP MODEL: OUTDOOR COILS
 60URP08/611AQ-A
 11000R 611AQ-A
 RATED COOLING CAP.: BTUH(95) 80000, SEER10.70
 RATED HEATING CAP.: BTUH(47) 81000, COP(47) 3.20, HSPF 7.50 MIN. OMR BEO IV
 BTUH(17) 35500, COP(17) 2.20
 FURNACE TYPE ELECTRIC FURNACE EFFICIENCY 100.00 % AFUE

HEAT LOSS
 BTUH
 ELEC.
 COST
 \$/KWH

80,000 --- THEORETICAL ANNUAL HEATING COST ---
 HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

| | | | |
|-----|------|------|-------------------------|
| .05 | 953 | 2025 | |
| .06 | 1139 | 2431 | |
| .07 | 1326 | 2838 | |
| .08 | 1511 | 3244 | |
| .09 | 1709 | 3650 | |
| .10 | 1901 | 4057 | |
| .12 | 2279 | 4869 | |
| .14 | 2663 | 5682 | BALANCE POINT 25 DEG.F. |
| .16 | 3041 | 6494 | |

90,000 --- THEORETICAL ANNUAL HEATING COST ---
 HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

| | | | |
|-----|------|------|-------------------------|
| .05 | 1094 | 2279 | |
| .06 | 1320 | 2738 | |
| .07 | 1540 | 3193 | |
| .08 | 1754 | 3650 | |
| .09 | 1974 | 4107 | |
| .10 | 2200 | 4564 | |
| .12 | 2635 | 5478 | |
| .14 | 3075 | 6393 | BALANCE POINT 28 DEG.F. |
| .16 | 3515 | 7307 | |

100,000 --- THEORETICAL ANNUAL HEATING COST ---
 HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

| | | | |
|-----|------|------|-------------------------|
| .05 | 1251 | 2533 | |
| .06 | 1500 | 3041 | |
| .07 | 1760 | 3549 | |
| .08 | 2008 | 4057 | |
| .09 | 2259 | 4564 | |
| .10 | 2510 | 5072 | |
| .12 | 3007 | 6089 | |
| .14 | 3509 | 7104 | BALANCE POINT 31 DEG.F. |
| .16 | 4011 | 8119 | |

110,000 --- THEORETICAL ANNUAL HEATING COST ---
 HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

| | | | |
|-----|------|------|-------------------------|
| .05 | 1427 | 2787 | |
| .06 | 1715 | 3346 | |
| .07 | 2003 | 3904 | |
| .08 | 2292 | 4463 | |
| .09 | 2579 | 5021 | |
| .10 | 2866 | 5580 | |
| .12 | 3436 | 6697 | |
| .14 | 4006 | 7815 | BALANCE POINT 33 DEG.F. |
| .16 | 4581 | 8932 | |

130,000 --- THEORETICAL ANNUAL HEATING COST ---
 HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

| | | | |
|-----|------|-------|-------------------------|
| .05 | 1799 | 3295 | |
| .06 | 2161 | 3955 | |
| .07 | 2523 | 4615 | |
| .08 | 2884 | 5275 | |
| .09 | 3244 | 5936 | |
| .10 | 3605 | 6596 | |
| .12 | 4322 | 7916 | |
| .14 | 5044 | 9236 | BALANCE POINT 37 DEG.F. |
| .16 | 5766 | 10557 | |

ANNUAL AIR CONDITIONING COST WHEN COOLING LOAD IS SIZED TO MATCH COOLING CAPACITY OF HEAT PUMP

| | | | | | | | | | | |
|----|-----|-----|-----|-----|-----|-----|-----|-----|-----|--------------------------------------|
| | .05 | .06 | .07 | .08 | .09 | .10 | .12 | .14 | .16 | |
| \$ | 216 | 260 | 303 | 346 | 390 | 433 | 520 | 607 | 693 | ←--ELECTRIC RATE \$/KWH |
| | | | | | | | | | | ←--THEORETICAL AIR CONDITIONING COST |

THE ABOVE ANNUAL HEATING AND COOLING OPERATING COSTS ARE THEORETICAL ESTIMATES ONLY AND ARE PROVIDED FOR A COMMON BASIS OF COMPARISON BETWEEN VARIOUS TYPES OF HEATING AND COOLING SYSTEMS. ACTUAL VALUES MAY VARY DEPENDING ON ACTUAL WEATHER CONDITIONS AND INDIVIDUAL USAGE PATTERNS.

WARD MANUFACTURING COMPANY
DUAL FUEL, AIR-ON HEAT PUMP GUIDE TO ENERGY COST SAVINGS

REGION 4 COURTESY/ASLCO-A
 HEAT PUMP MODEL: OUTDOOR CONDENSER INDOOR ASLCO-A
 RATED COOLING CAP.: BTU'S 58000 SERVO 10 TO
 RATED HEATING CAP.: BTU'S (47) 61000 COP (1) 3.20 HSPF 7.50 MIN. DWR REG IV
 PURCHASE PRICE \$ 35500 CUR (1) 2.20
 FURNACE TYPE NATURAL GAS FURNACE EFFICIENCY 78.00 % A/EUB

| HEAT LOAD BTU/H | FUELS COST \$/THERM | .25 | .40 | .45 | NATURAL GAS COST - \$/THERM | | | | | .80 | .90 | 1.00 | | |
|-----------------|---------------------|--------|------|------|-----------------------------|------|------|------|------|------|------|------|------|--|
| 60,000 | | \$ 462 | 530 | 598 | 665 | 727 | 795 | 863 | 931 | 998 | 1066 | 1134 | 1331 | <--THEORETICAL HEATING COST * FURNACE ONLY |
| | | \$ 603 | 620 | 631 | 643 | 654 | 665 | 682 | 694 | 705 | 716 | 744 | 767 | THEORETICAL HEATING COST * FURN. + HEAT PUMP |
| | | 705 | 732 | 733 | 744 | 756 | 767 | 784 | 795 | 806 | 818 | 846 | 868 | \$ PER YEAR |
| | .05 | 914 | 863 | 825 | 866 | 864 | 866 | 866 | 867 | 868 | 898 | 919 | 947 | |
| | .10 | 1015 | 932 | 873 | 953 | 906 | 866 | 827 | 788 | 749 | 710 | 671 | 632 | |
| | .12 | 1117 | 1004 | 921 | 1026 | 948 | 888 | 828 | 768 | 708 | 648 | 588 | 528 | |
| | .14 | 1220 | 1077 | 965 | 1096 | 1003 | 928 | 853 | 778 | 703 | 628 | 553 | 478 | |
| | .16 | 1323 | 1151 | 1014 | 1186 | 1077 | 989 | 901 | 813 | 725 | 637 | 549 | 461 | BALANCE POINT 18 DEG.F. |
| 70,000 | | \$ 541 | 620 | 694 | 773 | 852 | 931 | 1010 | 1083 | 1162 | 1241 | 1331 | 1551 | <--THEORETICAL HEATING COST * FURNACE ONLY |
| | | \$ 665 | 688 | 710 | 733 | 756 | 778 | 801 | 823 | 846 | 868 | 914 | 953 | THEORETICAL HEATING COST * FURN. + HEAT PUMP |
| | .05 | 873 | 819 | 781 | 840 | 863 | 885 | 908 | 931 | 953 | 976 | 1021 | 1060 | \$ PER YEAR |
| | .10 | 976 | 936 | 897 | 919 | 912 | 964 | 967 | 1010 | 1032 | 1055 | 1077 | 1122 | |
| | .12 | 1077 | 1000 | 921 | 1043 | 1066 | 1089 | 1111 | 1134 | 1156 | 1179 | 1224 | 1263 | |
| | .14 | 1184 | 1100 | 1011 | 1142 | 1168 | 1190 | 1213 | 1235 | 1258 | 1280 | 1324 | 1363 | |
| | .16 | 1288 | 1207 | 1121 | 1252 | 1278 | 1299 | 1320 | 1342 | 1362 | 1385 | 1428 | 1467 | BALANCE POINT 22 DEG.F. |
| 80,000 | | \$ 620 | 705 | 795 | 885 | 976 | 1066 | 1151 | 1241 | 1331 | 1416 | 1596 | 1771 | <--THEORETICAL HEATING COST * FURNACE ONLY |
| | | \$ 750 | 778 | 801 | 829 | 852 | 880 | 902 | 931 | 953 | 981 | 1032 | 1083 | THEORETICAL HEATING COST * FURN. + HEAT PUMP |
| | .05 | 868 | 819 | 781 | 840 | 863 | 885 | 908 | 931 | 953 | 976 | 1021 | 1060 | \$ PER YEAR |
| | .10 | 1010 | 932 | 853 | 1032 | 1060 | 1111 | 1134 | 1184 | 1213 | 1213 | 1253 | 1314 | |
| | .12 | 1111 | 1032 | 953 | 1179 | 1201 | 1230 | 1252 | 1280 | 1303 | 1331 | 1382 | 1433 | |
| | .14 | 1213 | 1121 | 1042 | 1263 | 1292 | 1314 | 1342 | 1365 | 1383 | 1416 | 1458 | 1500 | |
| | .16 | 1314 | 1207 | 1127 | 1348 | 1378 | 1408 | 1438 | 1468 | 1498 | 1528 | 1570 | 1612 | BALANCE POINT 25 DEG.F. |
| 90,000 | | \$ 694 | 795 | 897 | 998 | 1094 | 1196 | 1297 | 1393 | 1495 | 1596 | 1794 | 1997 | <--THEORETICAL HEATING COST * FURNACE ONLY |
| | | \$ 806 | 852 | 891 | 936 | 976 | 1021 | 1060 | 1105 | 1145 | 1190 | 1275 | 1359 | THEORETICAL HEATING COST * FURN. + HEAT PUMP |
| | .05 | 908 | 953 | 993 | 1038 | 1077 | 1122 | 1162 | 1207 | 1247 | 1292 | 1376 | 1461 | \$ PER YEAR |
| | .10 | 1010 | 1055 | 1094 | 1139 | 1179 | 1224 | 1263 | 1309 | 1348 | 1393 | 1478 | 1563 | |
| | .12 | 1111 | 1052 | 1082 | 1127 | 1167 | 1212 | 1252 | 1297 | 1336 | 1381 | 1466 | 1551 | |
| | .14 | 1213 | 1144 | 1164 | 1209 | 1249 | 1288 | 1327 | 1366 | 1405 | 1444 | 1483 | 1522 | |
| | .16 | 1314 | 1227 | 1247 | 1292 | 1332 | 1371 | 1410 | 1449 | 1488 | 1527 | 1566 | 1605 | BALANCE POINT 28 DEG.F. |
| 100,000 | | \$ 773 | 885 | 998 | 1105 | 1218 | 1331 | 1438 | 1551 | 1664 | 1771 | 1997 | 2217 | <--THEORETICAL HEATING COST * FURNACE ONLY |
| | | \$ 885 | 936 | 981 | 1026 | 1077 | 1122 | 1168 | 1218 | 1263 | 1309 | 1405 | 1495 | THEORETICAL HEATING COST * FURN. + HEAT PUMP |
| | .05 | 998 | 1049 | 1094 | 1139 | 1179 | 1224 | 1263 | 1309 | 1348 | 1393 | 1478 | 1563 | \$ PER YEAR |
| | .10 | 1094 | 1139 | 1179 | 1224 | 1263 | 1309 | 1348 | 1387 | 1426 | 1465 | 1504 | 1543 | |
| | .12 | 1195 | 1240 | 1279 | 1324 | 1363 | 1402 | 1441 | 1480 | 1519 | 1558 | 1597 | 1636 | |
| | .14 | 1297 | 1342 | 1381 | 1426 | 1465 | 1504 | 1543 | 1582 | 1621 | 1660 | 1699 | 1738 | |
| | .16 | 1398 | 1443 | 1482 | 1527 | 1566 | 1605 | 1644 | 1683 | 1722 | 1761 | 1800 | 1839 | BALANCE POINT 31 DEG.F. |
| 110,000 | | \$ 852 | 976 | 1094 | 1218 | 1342 | 1461 | 1585 | 1709 | 1828 | 1952 | 2194 | 2443 | <--THEORETICAL HEATING COST * FURNACE ONLY |
| | | \$ 925 | 998 | 1072 | 1145 | 1218 | 1292 | 1365 | 1438 | 1512 | 1585 | 1732 | 1873 | THEORETICAL HEATING COST * FURN. + HEAT PUMP |
| | .05 | 1010 | 1083 | 1157 | 1230 | 1303 | 1376 | 1450 | 1523 | 1596 | 1743 | 1884 | 2025 | \$ PER YEAR |
| | .10 | 1094 | 1139 | 1179 | 1224 | 1263 | 1309 | 1348 | 1387 | 1426 | 1465 | 1504 | 1543 | |
| | .12 | 1195 | 1240 | 1279 | 1324 | 1363 | 1402 | 1441 | 1480 | 1519 | 1558 | 1597 | 1636 | |
| | .14 | 1297 | 1342 | 1381 | 1426 | 1465 | 1504 | 1543 | 1582 | 1621 | 1660 | 1699 | 1738 | |
| | .16 | 1398 | 1443 | 1482 | 1527 | 1566 | 1605 | 1644 | 1683 | 1722 | 1761 | 1800 | 1839 | BALANCE POINT 33 DEG.F. |

THE ABOVE ANNUAL HEATING AND COOLING OPERATING COSTS ARE THEORETICAL ESTIMATES ONLY AND ARE PROVIDED FOR A CORNER CASE OF COMPARISON BETWEEN VARIOUS TYPES OF HEATING AND COOLING SYSTEMS. ACTUAL VALUES MAY VARY DEPENDING ON ACTUAL WEATHER CONDITIONS AND INDIVIDUAL USAGE PATTERN.

HARD MANUFACTURING COMPANY
DUAL FUEL ADD-ON HEAT PUMP GUIDE TO ENERGY COST SAVINGS

REGION 4 **SOUTHWESTALING-A**
 HEAT PUMP MODEL OUTDOOR COIL/COILS INDOOR A1A0-A
 AIR RATED COOLING CAP. BTU/Hr (95) 36000 SEER 10.70
 AIR RATED HEATING CAP. BTU/Hr (47) 51000 COP (47) 2.20 HSPF 7.50 MIN. OEB RSG 1%
 FURNACE TYPE FUEL OIL FURNACE EFFICIENCY 78.00 % A/CUE

| HEAT LOSS BTU/Hr | | HEATING OIL COST - \$/GALLON | | | | | | | | | | | | | | |
|------------------|--|--|------|------|------|------|------|------|------|------|------|------|------|--|--|--|
| | | .70 | .80 | .90 | 1.00 | 1.10 | 1.20 | 1.30 | 1.40 | 1.50 | 1.60 | 1.70 | 1.80 | | | |
| 60,000 | | \$ 671 767 863 959 1055 1151 1247 1342 1438 1534 1630 1726 <<--THEORETICAL HEATING COST * FURNACE ONLY | | | | | | | | | | | | | | |
| .05 | | 643 | 660 | 677 | 699 | 716 | 733 | 750 | 767 | 784 | 806 | 823 | 840 | THEORETICAL HEATING COST * FURN. + HEAT PUMP | | |
| .07 | | 844 | 874 | 903 | 936 | 963 | 993 | 1023 | 1053 | 1083 | 1113 | 1143 | 1173 | \$ PER YEAR | | |
| .08 | | 944 | 985 | 1025 | 1069 | 1111 | 1151 | 1191 | 1231 | 1271 | 1311 | 1351 | 1391 | | | |
| .09 | | 1044 | 1100 | 1155 | 1215 | 1271 | 1326 | 1381 | 1436 | 1491 | 1546 | 1601 | 1656 | | | |
| .10 | | 1144 | 1215 | 1281 | 1351 | 1416 | 1481 | 1546 | 1611 | 1676 | 1741 | 1806 | 1871 | | | |
| .12 | | 1344 | 1440 | 1536 | 1631 | 1726 | 1821 | 1916 | 2011 | 2106 | 2201 | 2296 | 2391 | | | |
| .14 | | 1544 | 1680 | 1816 | 1951 | 2086 | 2221 | 2356 | 2491 | 2626 | 2761 | 2896 | 3031 | BALANCE POINT 18 DEG.F. | | |
| .16 | | 1744 | 1920 | 2096 | 2271 | 2446 | 2621 | 2796 | 2971 | 3146 | 3321 | 3496 | 3671 | | | |
| 70,000 | | \$ 784 891 1004 1117 1230 1342 1455 1568 1675 1788 1901 2014 <<--THEORETICAL HEATING COST * FURNACE ONLY | | | | | | | | | | | | | | |
| .05 | | 739 | 777 | 801 | 835 | 863 | 897 | 931 | 959 | 993 | 1026 | 1055 | 1089 | THEORETICAL HEATING COST * FURN. + HEAT PUMP | | |
| .07 | | 949 | 996 | 1030 | 1074 | 1113 | 1152 | 1191 | 1230 | 1269 | 1308 | 1347 | 1386 | \$ PER YEAR | | |
| .08 | | 1049 | 1107 | 1151 | 1195 | 1234 | 1273 | 1312 | 1351 | 1390 | 1429 | 1468 | 1507 | | | |
| .09 | | 1149 | 1218 | 1267 | 1315 | 1358 | 1401 | 1444 | 1487 | 1530 | 1573 | 1616 | 1659 | | | |
| .10 | | 1249 | 1329 | 1389 | 1446 | 1503 | 1560 | 1617 | 1674 | 1731 | 1788 | 1845 | 1902 | | | |
| .12 | | 1449 | 1550 | 1621 | 1691 | 1761 | 1831 | 1901 | 1971 | 2041 | 2111 | 2181 | 2251 | | | |
| .14 | | 1649 | 1780 | 1851 | 1921 | 1991 | 2061 | 2131 | 2201 | 2271 | 2341 | 2411 | 2481 | BALANCE POINT 22 DEG.F. | | |
| .16 | | 1849 | 2000 | 2081 | 2161 | 2241 | 2321 | 2401 | 2481 | 2561 | 2641 | 2721 | 2801 | | | |
| 80,000 | | \$ 891 1021 1151 1280 1405 1534 1664 1789 1918 2048 2172 2302 <<--THEORETICAL HEATING COST * FURNACE ONLY | | | | | | | | | | | | | | |
| .05 | | 829 | 868 | 902 | 942 | 976 | 1015 | 1049 | 1089 | 1122 | 1156 | 1196 | 1230 | THEORETICAL HEATING COST * FURN. + HEAT PUMP | | |
| .07 | | 1060 | 1100 | 1134 | 1173 | 1207 | 1247 | 1280 | 1320 | 1354 | 1398 | 1437 | 1481 | \$ PER YEAR | | |
| .08 | | 1159 | 1218 | 1257 | 1296 | 1335 | 1374 | 1413 | 1452 | 1491 | 1530 | 1569 | 1608 | | | |
| .09 | | 1259 | 1329 | 1368 | 1407 | 1446 | 1485 | 1524 | 1563 | 1602 | 1641 | 1680 | 1719 | | | |
| .10 | | 1359 | 1450 | 1500 | 1549 | 1598 | 1647 | 1696 | 1745 | 1794 | 1843 | 1892 | 1941 | | | |
| .12 | | 1559 | 1680 | 1751 | 1821 | 1891 | 1961 | 2031 | 2101 | 2171 | 2241 | 2311 | 2381 | | | |
| .14 | | 1759 | 1910 | 1981 | 2051 | 2121 | 2191 | 2261 | 2331 | 2401 | 2471 | 2541 | 2611 | BALANCE POINT 25 DEG.F. | | |
| .16 | | 1959 | 2140 | 2211 | 2281 | 2351 | 2421 | 2491 | 2561 | 2631 | 2701 | 2771 | 2841 | | | |
| 90,000 | | \$ 1004 1151 1292 1438 1579 1726 1873 2014 2161 2302 2448 2589 <<--THEORETICAL HEATING COST * FURNACE ONLY | | | | | | | | | | | | | | |
| .05 | | 942 | 988 | 1030 | 1074 | 1113 | 1152 | 1191 | 1230 | 1269 | 1308 | 1347 | 1386 | THEORETICAL HEATING COST * FURN. + HEAT PUMP | | |
| .07 | | 1173 | 1220 | 1254 | 1298 | 1337 | 1376 | 1415 | 1454 | 1493 | 1532 | 1571 | 1610 | \$ PER YEAR | | |
| .08 | | 1273 | 1340 | 1374 | 1418 | 1457 | 1496 | 1535 | 1574 | 1613 | 1652 | 1691 | 1730 | | | |
| .09 | | 1373 | 1450 | 1484 | 1528 | 1567 | 1606 | 1645 | 1684 | 1723 | 1762 | 1801 | 1840 | | | |
| .10 | | 1473 | 1570 | 1604 | 1648 | 1687 | 1726 | 1765 | 1804 | 1843 | 1882 | 1921 | 1960 | | | |
| .12 | | 1673 | 1800 | 1871 | 1941 | 2011 | 2081 | 2151 | 2221 | 2291 | 2361 | 2431 | 2501 | | | |
| .14 | | 1873 | 2020 | 2091 | 2161 | 2231 | 2301 | 2371 | 2441 | 2511 | 2581 | 2651 | 2721 | BALANCE POINT 28 DEG.F. | | |
| .16 | | 2073 | 2240 | 2311 | 2381 | 2451 | 2521 | 2591 | 2661 | 2731 | 2801 | 2871 | 2941 | | | |
| 100,000 | | \$ 1117 1280 1438 1596 1760 1918 2076 2240 2398 2561 2719 2877 <<--THEORETICAL HEATING COST * FURNACE ONLY | | | | | | | | | | | | | | |
| .05 | | 1034 | 1100 | 1168 | 1235 | 1303 | 1371 | 1438 | 1506 | 1574 | 1642 | 1709 | 1777 | THEORETICAL HEATING COST * FURN. + HEAT PUMP | | |
| .07 | | 1265 | 1333 | 1391 | 1459 | 1527 | 1595 | 1663 | 1731 | 1799 | 1867 | 1935 | 2003 | \$ PER YEAR | | |
| .08 | | 1365 | 1440 | 1498 | 1566 | 1634 | 1702 | 1770 | 1838 | 1906 | 1974 | 2042 | 2110 | | | |
| .09 | | 1465 | 1550 | 1608 | 1676 | 1744 | 1812 | 1880 | 1948 | 2016 | 2084 | 2152 | 2220 | | | |
| .10 | | 1565 | 1670 | 1728 | 1796 | 1864 | 1932 | 2000 | 2068 | 2136 | 2204 | 2272 | 2340 | | | |
| .12 | | 1765 | 1900 | 1968 | 2036 | 2104 | 2172 | 2240 | 2308 | 2376 | 2444 | 2512 | 2580 | | | |
| .14 | | 1965 | 2120 | 2188 | 2256 | 2324 | 2392 | 2460 | 2528 | 2596 | 2664 | 2732 | 2800 | BALANCE POINT 31 DEG.F. | | |
| .16 | | 2165 | 2340 | 2408 | 2476 | 2544 | 2612 | 2680 | 2748 | 2816 | 2884 | 2952 | 3020 | | | |
| 110,000 | | \$ 1230 1405 1579 1760 1925 2110 2285 2465 2640 2815 2990 3165 <<--THEORETICAL HEATING COST * FURNACE ONLY | | | | | | | | | | | | | | |
| .05 | | 1151 | 1258 | 1365 | 1467 | 1574 | 1681 | 1783 | 1890 | 1991 | 2099 | 2206 | 2307 | THEORETICAL HEATING COST * FURN. + HEAT PUMP | | |
| .07 | | 1382 | 1460 | 1528 | 1596 | 1664 | 1732 | 1800 | 1868 | 1936 | 2004 | 2072 | 2140 | \$ PER YEAR | | |
| .08 | | 1482 | 1570 | 1628 | 1696 | 1764 | 1832 | 1900 | 1968 | 2036 | 2104 | 2172 | 2240 | | | |
| .09 | | 1582 | 1680 | 1738 | 1806 | 1874 | 1942 | 2010 | 2078 | 2146 | 2214 | 2282 | 2350 | | | |
| .10 | | 1682 | 1800 | 1858 | 1926 | 1994 | 2062 | 2130 | 2198 | 2266 | 2334 | 2402 | 2470 | | | |
| .12 | | 1882 | 2020 | 2088 | 2156 | 2224 | 2292 | 2360 | 2428 | 2496 | 2564 | 2632 | 2700 | | | |
| .14 | | 2082 | 2240 | 2308 | 2376 | 2444 | 2512 | 2580 | 2648 | 2716 | 2784 | 2852 | 2920 | BALANCE POINT 33 DEG.F. | | |
| .16 | | 2282 | 2460 | 2528 | 2596 | 2664 | 2732 | 2800 | 2868 | 2936 | 3004 | 3072 | 3140 | | | |

THE ABOVE ANNUAL HEATING AND COOLING OPERATING COSTS ARE THEORETICAL ESTIMATES ONLY AND ARE PROVIDED FOR A COMMON BASIS OF COMPARISON BETWEEN VARIOUS TYPES OF HEATING AND COOLING SYSTEMS. ACTUAL VALUES MAY VARY DEPENDING ON ACTUAL WEATHER CONDITIONS AND INDIVIDUAL USAGE PATTERN.

SARD MANUFACTURING COMPANY
DUAL FUEL ADD-ON HEAT PUMP GUIDE TO ENERGY COST SAVINGS

REGION 4 60000/61100-A
 HEAT PUMP MODEL: OUTDOOR ASHRAE INDEX 61100-A
 ARI RATED COOLING CAP.: BTUH (95) 30000 SEER 10.50
 ARI RATED HEATING CAP.: BTUH (47) 48000 COP (47) 3.20 HSPF 1.40 MIN. DHR REG IV
 FURNACE TYPE ELECTRIC FURNACE EFFICIENCY 100.00 % ARI

| HEAT LOSS BTUH | HEAT COST \$/KW | --- THEORETICAL ANNUAL HEATING COST --- | |
|----------------|-----------------|---|--------------------|
| | | HEAT PUMP WITH ELECTRIC HEAT | ELECTRIC HEAT ONLY |
| 60,000 | | | |
| .05 | | 739 | 1517 |
| .06 | | 885 | 1831 |
| .07 | | 1032 | 2145 |
| .08 | | 1180 | 2459 |
| .09 | | 1327 | 2773 |
| .10 | | 1475 | 3087 |
| .11 | | 1622 | 3401 |
| .12 | | 1770 | 3715 |
| .13 | | 1917 | 4029 |
| .14 | | 2065 | 4343 |
| .15 | | 2212 | 4657 |
| .16 | | 2360 | 4971 |

BALANCE POINT 24 DEG.F.

| HEAT LOSS BTUH | HEAT COST \$/KW | --- THEORETICAL ANNUAL HEATING COST --- | |
|----------------|-----------------|---|--------------------|
| | | HEAT PUMP WITH ELECTRIC HEAT | ELECTRIC HEAT ONLY |
| 70,000 | | | |
| .05 | | 885 | 1771 |
| .06 | | 1066 | 2181 |
| .07 | | 1247 | 2591 |
| .08 | | 1428 | 3001 |
| .09 | | 1609 | 3411 |
| .10 | | 1790 | 3821 |
| .11 | | 1971 | 4231 |
| .12 | | 2152 | 4641 |
| .13 | | 2333 | 5051 |
| .14 | | 2514 | 5461 |
| .15 | | 2695 | 5871 |
| .16 | | 2876 | 6281 |

BALANCE POINT 28 DEG.F.

| HEAT LOSS BTUH | HEAT COST \$/KW | --- THEORETICAL ANNUAL HEATING COST --- | |
|----------------|-----------------|---|--------------------|
| | | HEAT PUMP WITH ELECTRIC HEAT | ELECTRIC HEAT ONLY |
| 80,000 | | | |
| .05 | | 1043 | 2025 |
| .06 | | 1252 | 2431 |
| .07 | | 1461 | 2837 |
| .08 | | 1670 | 3243 |
| .09 | | 1878 | 3649 |
| .10 | | 2087 | 4055 |
| .11 | | 2295 | 4461 |
| .12 | | 2504 | 4867 |
| .13 | | 2712 | 5273 |
| .14 | | 2921 | 5679 |
| .15 | | 3129 | 6085 |
| .16 | | 3338 | 6491 |

BALANCE POINT 32 DEG.F.

| HEAT LOSS BTUH | HEAT COST \$/KW | --- THEORETICAL ANNUAL HEATING COST --- | |
|----------------|-----------------|---|--------------------|
| | | HEAT PUMP WITH ELECTRIC HEAT | ELECTRIC HEAT ONLY |
| 90,000 | | | |
| .05 | | 1230 | 2279 |
| .06 | | 1472 | 2781 |
| .07 | | 1714 | 3283 |
| .08 | | 1956 | 3785 |
| .09 | | 2198 | 4287 |
| .10 | | 2440 | 4789 |
| .11 | | 2682 | 5291 |
| .12 | | 2924 | 5793 |
| .13 | | 3166 | 6295 |
| .14 | | 3408 | 6797 |
| .15 | | 3650 | 7299 |
| .16 | | 3892 | 7801 |

BALANCE POINT 35 DEG.F.

| HEAT LOSS BTUH | HEAT COST \$/KW | --- THEORETICAL ANNUAL HEATING COST --- | |
|----------------|-----------------|---|--------------------|
| | | HEAT PUMP WITH ELECTRIC HEAT | ELECTRIC HEAT ONLY |
| 100,000 | | | |
| .05 | | 1421 | 2533 |
| .06 | | 1704 | 3041 |
| .07 | | 1987 | 3549 |
| .08 | | 2270 | 4057 |
| .09 | | 2553 | 4565 |
| .10 | | 2836 | 5073 |
| .11 | | 3119 | 5581 |
| .12 | | 3402 | 6089 |
| .13 | | 3685 | 6597 |
| .14 | | 3968 | 7105 |
| .15 | | 4251 | 7613 |
| .16 | | 4534 | 8121 |

BALANCE POINT 37 DEG.F.

ANNUAL AIR CONDITIONING COST WHEN COOLING LOAD IS SIZED TO MATCH COOLING CAPACITY OF HEAT PUMP

| | | | | | | | | | | |
|----|-----|-----|-----|-----|-----|-----|-----|-----|-----|---|
| | 05 | 06 | 07 | 08 | 09 | 10 | 12 | 14 | 16 | |
| \$ | 190 | 228 | 266 | 304 | 342 | 380 | 457 | 533 | 609 | <--ELECTRIC RATE \$/KWH <--THEORETICAL AIR CONDITIONING COST |

THE ABOVE ANNUAL HEATING AND COOLING OPERATING COSTS ARE THEORETICAL ESTIMATES ONLY AND ARE PROVIDED FOR A COMMON BASIS OF COMPARISON BETWEEN VARIOUS TYPES OF HEATING AND COOLING SYSTEMS. ACTUAL VALUES MAY VARY DEPENDING ON ACTUAL WEATHER CONDITIONS AND INDIVIDUAL USAGE PATTERN.

BAIRD MANUFACTURING COMPANY
DUAL FUEL ADD-ON HEAT PUMP GUIDE TO ENERGY COST SAVINGS

REGION 4
 HEAT PUMP MODEL: OUTDOOR 48HP04A 48HP04A/481A0-A
 HEAT COOLING CAP.: 3700 (95) 3700 (95) 10.50
 HEAT HEATING CAP.: 3700 (47) 3700 (47) 1.20 HPPT 1.40 MIN. OER REG IV
 FURNACE TYPE NATURAL GAS FURNACE EFFICIENCY 78.00 % AFUE

| HEAT PUMP COST \$/KW | HEAT PUMP COST \$/KW | NATURAL GAS COST - \$/THERM | | | | | | | | | | | | | | |
|----------------------|----------------------|-----------------------------|------|------|------|------|------|------|------|------|------|------|------|--|--|--|
| | | .35 | .40 | .45 | .50 | .55 | .60 | .65 | .70 | .75 | .80 | | .90 | 1.00 | | |
| 50,000 | \$ | 383 | 440 | 496 | 552 | 609 | 665 | 716 | 773 | 829 | 885 | 998 | 1105 | ←--THEORETICAL HEATING COST * FURNACE ONLY | | |
| | \$ | 530 | 541 | 547 | 558 | 569 | 581 | 593 | 603 | 609 | 620 | 643 | 645 | THEORETICAL HEATING COST * FURN. + HEAT PUMP | | |
| | \$ | 620 | 624 | 627 | 630 | 633 | 636 | 639 | 642 | 645 | 648 | 651 | 654 | \$ PER YEAR | | |
| | \$ | 806 | 814 | 823 | 832 | 841 | 850 | 859 | 868 | 877 | 886 | 895 | 904 | | | |
| | \$ | 987 | 998 | 1010 | 1022 | 1034 | 1046 | 1058 | 1070 | 1082 | 1094 | 1106 | 1118 | | | |
| | \$ | 1173 | 1184 | 1196 | 1208 | 1220 | 1232 | 1244 | 1256 | 1268 | 1280 | 1292 | 1304 | | | |
| | \$ | 1354 | 1365 | 1377 | 1389 | 1401 | 1413 | 1425 | 1437 | 1449 | 1461 | 1473 | 1485 | | | |
| | \$ | 1534 | 1546 | 1558 | 1570 | 1582 | 1594 | 1606 | 1618 | 1630 | 1642 | 1654 | 1666 | | | |
| | \$ | 1625 | 1642 | 1658 | 1681 | 1698 | 1715 | 1737 | 1754 | 1771 | 1794 | 1833 | 1887 | BALANCE POINT 18 DEG.F. | | |
| | 60,000 | \$ | 462 | 530 | 598 | 665 | 727 | 795 | 863 | 931 | 998 | 1060 | 1196 | 1331 | ←--THEORETICAL HEATING COST * FURNACE ONLY | |
| \$ | | 603 | 620 | 637 | 660 | 677 | 694 | 716 | 733 | 750 | 773 | 812 | 846 | THEORETICAL HEATING COST * FURN. + HEAT PUMP | | |
| \$ | | 694 | 710 | 727 | 750 | 767 | 784 | 806 | 823 | 840 | 863 | 902 | 936 | \$ PER YEAR | | |
| \$ | | 880 | 897 | 914 | 936 | 953 | 970 | 993 | 1010 | 1026 | 1049 | 1089 | 1132 | | | |
| \$ | | 1066 | 1083 | 1100 | 1123 | 1149 | 1179 | 1213 | 1252 | 1296 | 1345 | 1399 | 1458 | | | |
| \$ | | 1252 | 1269 | 1286 | 1309 | 1326 | 1342 | 1365 | 1393 | 1421 | 1449 | 1481 | 1518 | | | |
| \$ | | 1438 | 1455 | 1472 | 1495 | 1529 | 1568 | 1613 | 1664 | 1721 | 1784 | 1853 | 1928 | | | |
| \$ | | 1625 | 1642 | 1658 | 1681 | 1698 | 1715 | 1737 | 1754 | 1771 | 1794 | 1833 | 1887 | BALANCE POINT 24 DEG.F. | | |
| 70,000 | | \$ | 541 | 620 | 694 | 773 | 852 | 931 | 1010 | 1083 | 1162 | 1241 | 1393 | 1551 | ←--THEORETICAL HEATING COST * FURNACE ONLY | |
| | | \$ | 654 | 688 | 716 | 750 | 784 | 818 | 852 | 885 | 914 | 947 | 1015 | 1083 | THEORETICAL HEATING COST * FURN. + HEAT PUMP | |
| | \$ | 745 | 773 | 801 | 835 | 868 | 902 | 936 | 970 | 1003 | 1037 | 1100 | 1168 | \$ PER YEAR | | |
| | \$ | 930 | 947 | 964 | 987 | 1004 | 1021 | 1038 | 1055 | 1072 | 1089 | 1117 | 1184 | | | |
| | \$ | 1115 | 1127 | 1140 | 1155 | 1170 | 1185 | 1200 | 1215 | 1230 | 1245 | 1273 | 1337 | | | |
| | \$ | 1300 | 1312 | 1324 | 1339 | 1354 | 1369 | 1384 | 1399 | 1414 | 1429 | 1457 | 1521 | | | |
| | \$ | 1485 | 1497 | 1510 | 1525 | 1540 | 1555 | 1570 | 1585 | 1600 | 1615 | 1643 | 1707 | | | |
| | \$ | 1670 | 1682 | 1694 | 1709 | 1724 | 1739 | 1754 | 1769 | 1784 | 1800 | 1828 | 1892 | | | |
| | \$ | 1851 | 1863 | 1875 | 1890 | 1905 | 1920 | 1935 | 1950 | 1965 | 1980 | 2008 | 2072 | BALANCE POINT 28 DEG.F. | | |
| | 80,000 | \$ | 620 | 705 | 795 | 885 | 976 | 1060 | 1151 | 1241 | 1331 | 1416 | 1596 | 1771 | ←--THEORETICAL HEATING COST * FURNACE ONLY | |
| \$ | | 749 | 750 | 806 | 857 | 908 | 964 | 1015 | 1072 | 1122 | 1173 | 1280 | 1368 | THEORETICAL HEATING COST * FURN. + HEAT PUMP | | |
| \$ | | 839 | 818 | 874 | 925 | 976 | 1032 | 1083 | 1139 | 1190 | 1241 | 1348 | 1454 | \$ PER YEAR | | |
| \$ | | 1024 | 1041 | 1058 | 1081 | 1103 | 1126 | 1149 | 1172 | 1195 | 1218 | 1241 | 1264 | | | |
| \$ | | 1209 | 1226 | 1243 | 1266 | 1289 | 1312 | 1335 | 1358 | 1381 | 1404 | 1427 | 1450 | | | |
| \$ | | 1394 | 1411 | 1428 | 1451 | 1474 | 1497 | 1520 | 1543 | 1566 | 1589 | 1612 | 1635 | | | |
| \$ | | 1579 | 1596 | 1613 | 1636 | 1659 | 1682 | 1705 | 1728 | 1751 | 1774 | 1797 | 1820 | | | |
| \$ | | 1764 | 1781 | 1798 | 1821 | 1844 | 1867 | 1890 | 1913 | 1936 | 1959 | 1982 | 2005 | | | |
| \$ | | 1949 | 1966 | 1983 | 2006 | 2029 | 2052 | 2075 | 2098 | 2121 | 2144 | 2167 | 2190 | BALANCE POINT 32 DEG.F. | | |
| 90,000 | | \$ | 694 | 795 | 897 | 998 | 1094 | 1196 | 1297 | 1393 | 1495 | 1596 | 1794 | 1997 | ←--THEORETICAL HEATING COST * FURNACE ONLY | |
| | \$ | 778 | 840 | 897 | 959 | 1015 | 1077 | 1134 | 1196 | 1258 | 1314 | 1433 | 1551 | THEORETICAL HEATING COST * FURN. + HEAT PUMP | | |
| | \$ | 869 | 914 | 970 | 1022 | 1089 | 1151 | 1213 | 1279 | 1342 | 1401 | 1520 | 1638 | \$ PER YEAR | | |
| | \$ | 1054 | 1071 | 1088 | 1111 | 1133 | 1155 | 1177 | 1200 | 1222 | 1245 | 1268 | 1291 | | | |
| | \$ | 1239 | 1256 | 1273 | 1296 | 1319 | 1342 | 1365 | 1388 | 1411 | 1434 | 1457 | 1480 | | | |
| | \$ | 1424 | 1441 | 1458 | 1481 | 1504 | 1527 | 1550 | 1573 | 1596 | 1619 | 1642 | 1665 | | | |
| | \$ | 1609 | 1626 | 1643 | 1666 | 1689 | 1712 | 1735 | 1758 | 1781 | 1804 | 1827 | 1850 | | | |
| | \$ | 1794 | 1811 | 1828 | 1851 | 1874 | 1897 | 1920 | 1943 | 1966 | 1989 | 2012 | 2035 | | | |
| | \$ | 1979 | 1996 | 2013 | 2036 | 2059 | 2082 | 2105 | 2128 | 2151 | 2174 | 2197 | 2220 | BALANCE POINT 35 DEG.F. | | |
| | 100,000 | \$ | 773 | 885 | 998 | 1105 | 1218 | 1331 | 1438 | 1551 | 1664 | 1771 | 1997 | 2217 | ←--THEORETICAL HEATING COST * FURNACE ONLY | |
| \$ | | 829 | 908 | 987 | 1072 | 1151 | 1230 | 1309 | 1393 | 1472 | 1551 | 1715 | 1873 | THEORETICAL HEATING COST * FURN. + HEAT PUMP | | |
| \$ | | 920 | 953 | 1038 | 1122 | 1201 | 1280 | 1359 | 1444 | 1523 | 1602 | 1766 | 1924 | \$ PER YEAR | | |
| \$ | | 1105 | 1122 | 1139 | 1162 | 1185 | 1208 | 1231 | 1254 | 1277 | 1300 | 1323 | 1346 | | | |
| \$ | | 1290 | 1307 | 1324 | 1347 | 1370 | 1393 | 1416 | 1439 | 1462 | 1485 | 1508 | 1531 | | | |
| \$ | | 1475 | 1492 | 1509 | 1532 | 1555 | 1578 | 1601 | 1624 | 1647 | 1670 | 1693 | 1716 | | | |
| \$ | | 1660 | 1677 | 1694 | 1717 | 1740 | 1763 | 1786 | 1809 | 1832 | 1855 | 1878 | 1901 | | | |
| \$ | | 1845 | 1862 | 1879 | 1902 | 1925 | 1948 | 1971 | 1994 | 2017 | 2040 | 2063 | 2086 | | | |
| \$ | | 2030 | 2047 | 2064 | 2087 | 2110 | 2133 | 2156 | 2179 | 2202 | 2225 | 2248 | 2271 | BALANCE POINT 37 DEG.F. | | |

ANNUAL AIR CONDITIONING COST WHEN COOLING LOAD IS SIZED TO MATCH COOLING CAPACITY OF HEAT PUMP

.05 .06 .07 .08 .09 .10 .12 .14 .16 ←--ELECTRIC RATE \$/KWH

THE ABOVE ANNUAL HEATING AND COOLING OPERATING COSTS ARE THEORETICAL ESTIMATES ONLY AND ARE PROVIDED FOR A COMMON BASIS OF COMPARISON BETWEEN VARIOUS TYPES OF HEATING AND COOLING SYSTEMS. ACTUAL VALUES MAY VARY DEPENDING ON ACTUAL WEATHER CONDITIONS AND INDIVIDUAL USAGE PATTERN.

BAIRD MANUFACTURING COMPANY
DUAL FUEL AIR-ON HEAT PUMP GUIDE TO ENERGY COST SAVINGS

REGION 4
 HEAT PUMP MODEL: OUTDOOR 48SRP04A INDOOR 48IAC-A
 HEATED COOLING CAP.: 5000 (95) 5000 (100) 5000 (110) 5000 (120) 5000 (130) 5000 (140) 5000 (150) 5000 (160) 5000 (170) 5000 (180)
 HEATED HEATING CAP.: 5000 (47) 5000 (50) 5000 (55) 5000 (60) 5000 (65) 5000 (70) 5000 (75) 5000 (80) 5000 (85) 5000 (90)
 FURNACE TYPE: FURN. OIL FURNACE EFFICIENCY: 78.00 % A/C/B

| HEAT LOSS BTU | ELEC. COST \$/KWH | HEATING OIL COST - \$/GALLON | | | | | | | | | | THEORETICAL HEATING COST * FURNACE ONLY | THEORETICAL HEATING COST * FURN. + HEAT PUMP \$ PER YEAR | BALANCE POINT DEG.F. | | | |
|---------------|-------------------|------------------------------|------|------|------|------|------|------|------|------|------|---|--|----------------------|--|------|--|
| | | .70 | .80 | .90 | 1.00 | 1.10 | 1.20 | 1.30 | 1.40 | 1.50 | 1.60 | | | | 1.70 | 1.80 | |
| 50,000 | \$.05 | 558 | 637 | 716 | 795 | 880 | 959 | 1038 | 1117 | 1196 | 1280 | 1359 | 1438 | <-- | THEORETICAL HEATING COST * FURNACE ONLY | | |
| | .06 | 558 | 575 | 592 | 603 | 620 | 637 | 648 | 665 | 682 | 694 | 710 | 722 | | THEORETICAL HEATING COST * FURN. + HEAT PUMP \$ PER YEAR | | |
| | .07 | 558 | 548 | 538 | 528 | 518 | 508 | 498 | 488 | 478 | 468 | 458 | 448 | | | | |
| | .08 | 558 | 538 | 528 | 518 | 508 | 498 | 488 | 478 | 468 | 458 | 448 | 438 | | | | |
| | .09 | 558 | 528 | 518 | 508 | 498 | 488 | 478 | 468 | 458 | 448 | 438 | 428 | | | | |
| | .10 | 558 | 518 | 508 | 498 | 488 | 478 | 468 | 458 | 448 | 438 | 428 | 418 | | | | |
| | .12 | 558 | 498 | 488 | 478 | 468 | 458 | 448 | 438 | 428 | 418 | 408 | 398 | | | | |
| | .14 | 558 | 478 | 468 | 458 | 448 | 438 | 428 | 418 | 408 | 398 | 388 | 378 | | | | |
| | .16 | 558 | 458 | 448 | 438 | 428 | 418 | 408 | 398 | 388 | 378 | 368 | 358 | | | | |
| 60,000 | \$.05 | 671 | 767 | 863 | 959 | 1055 | 1151 | 1247 | 1342 | 1438 | 1534 | 1630 | 1726 | <-- | THEORETICAL HEATING COST * FURNACE ONLY | | |
| | .06 | 671 | 688 | 716 | 739 | 767 | 795 | 823 | 852 | 880 | 908 | 931 | 959 | | THEORETICAL HEATING COST * FURN. + HEAT PUMP \$ PER YEAR | | |
| | .07 | 671 | 660 | 649 | 638 | 627 | 616 | 605 | 594 | 583 | 572 | 561 | 550 | | | | |
| | .08 | 671 | 649 | 627 | 605 | 583 | 561 | 539 | 517 | 495 | 473 | 451 | 429 | | | | |
| | .09 | 671 | 627 | 605 | 583 | 561 | 539 | 517 | 495 | 473 | 451 | 429 | 407 | | | | |
| | .10 | 671 | 605 | 583 | 561 | 539 | 517 | 495 | 473 | 451 | 429 | 407 | 385 | | | | |
| | .12 | 671 | 583 | 561 | 539 | 517 | 495 | 473 | 451 | 429 | 407 | 385 | 363 | | | | |
| | .14 | 671 | 561 | 539 | 517 | 495 | 473 | 451 | 429 | 407 | 385 | 363 | 341 | | | | |
| | .16 | 671 | 539 | 517 | 495 | 473 | 451 | 429 | 407 | 385 | 363 | 341 | 319 | | | | |
| 70,000 | \$.05 | 784 | 891 | 1004 | 1117 | 1230 | 1342 | 1455 | 1568 | 1675 | 1788 | 1901 | 2014 | <-- | THEORETICAL HEATING COST * FURNACE ONLY | | |
| | .06 | 784 | 801 | 852 | 897 | 942 | 989 | 1038 | 1089 | 1134 | 1179 | 1230 | 1275 | | THEORETICAL HEATING COST * FURN. + HEAT PUMP \$ PER YEAR | | |
| | .07 | 784 | 775 | 760 | 745 | 730 | 715 | 700 | 685 | 670 | 655 | 640 | 625 | | | | |
| | .08 | 784 | 760 | 738 | 716 | 694 | 672 | 650 | 628 | 606 | 584 | 562 | 540 | | | | |
| | .09 | 784 | 738 | 716 | 694 | 672 | 650 | 628 | 606 | 584 | 562 | 540 | 518 | | | | |
| | .10 | 784 | 716 | 694 | 672 | 650 | 628 | 606 | 584 | 562 | 540 | 518 | 496 | | | | |
| | .12 | 784 | 694 | 672 | 650 | 628 | 606 | 584 | 562 | 540 | 518 | 496 | 474 | | | | |
| | .14 | 784 | 672 | 650 | 628 | 606 | 584 | 562 | 540 | 518 | 496 | 474 | 452 | | | | |
| | .16 | 784 | 650 | 628 | 606 | 584 | 562 | 540 | 518 | 496 | 474 | 452 | 430 | | | | |
| 80,000 | \$.05 | 891 | 1021 | 1151 | 1280 | 1405 | 1534 | 1664 | 1788 | 1918 | 2048 | 2172 | 2302 | <-- | THEORETICAL HEATING COST * FURNACE ONLY | | |
| | .06 | 891 | 936 | 1015 | 1099 | 1168 | 1247 | 1320 | 1399 | 1472 | 1551 | 1625 | 1704 | | THEORETICAL HEATING COST * FURN. + HEAT PUMP \$ PER YEAR | | |
| | .07 | 891 | 882 | 867 | 852 | 837 | 822 | 807 | 792 | 777 | 762 | 747 | 732 | | | | |
| | .08 | 891 | 867 | 837 | 807 | 777 | 747 | 717 | 687 | 657 | 627 | 597 | 567 | | | | |
| | .09 | 891 | 837 | 807 | 777 | 747 | 717 | 687 | 657 | 627 | 597 | 567 | 537 | | | | |
| | .10 | 891 | 807 | 777 | 747 | 717 | 687 | 657 | 627 | 597 | 567 | 537 | 507 | | | | |
| | .12 | 891 | 777 | 747 | 717 | 687 | 657 | 627 | 597 | 567 | 537 | 507 | 477 | | | | |
| | .14 | 891 | 747 | 717 | 687 | 657 | 627 | 597 | 567 | 537 | 507 | 477 | 447 | | | | |
| | .16 | 891 | 717 | 687 | 657 | 627 | 597 | 567 | 537 | 507 | 477 | 447 | 417 | | | | |
| 90,000 | \$.05 | 1004 | 1151 | 1292 | 1438 | 1579 | 1726 | 1873 | 2014 | 2161 | 2302 | 2448 | 2589 | <-- | THEORETICAL HEATING COST * FURNACE ONLY | | |
| | .06 | 1004 | 1049 | 1134 | 1218 | 1309 | 1393 | 1478 | 1563 | 1653 | 1737 | 1822 | 1907 | | THEORETICAL HEATING COST * FURN. + HEAT PUMP \$ PER YEAR | | |
| | .07 | 1004 | 995 | 980 | 965 | 950 | 935 | 920 | 905 | 890 | 875 | 860 | 845 | | | | |
| | .08 | 1004 | 965 | 935 | 905 | 875 | 845 | 815 | 785 | 755 | 725 | 695 | 665 | | | | |
| | .09 | 1004 | 935 | 905 | 875 | 845 | 815 | 785 | 755 | 725 | 695 | 665 | 635 | | | | |
| | .10 | 1004 | 905 | 875 | 845 | 815 | 785 | 755 | 725 | 695 | 665 | 635 | 605 | | | | |
| | .12 | 1004 | 875 | 845 | 815 | 785 | 755 | 725 | 695 | 665 | 635 | 605 | 575 | | | | |
| | .14 | 1004 | 845 | 815 | 785 | 755 | 725 | 695 | 665 | 635 | 605 | 575 | 545 | | | | |
| | .16 | 1004 | 815 | 785 | 755 | 725 | 695 | 665 | 635 | 605 | 575 | 545 | 515 | | | | |
| 100,000 | \$.05 | 1117 | 1280 | 1438 | 1596 | 1760 | 1918 | 2076 | 2240 | 2398 | 2561 | 2719 | 2877 | <-- | THEORETICAL HEATING COST * FURNACE ONLY | | |
| | .06 | 1117 | 1190 | 1309 | 1427 | 1540 | 1658 | 1771 | 1880 | 1993 | 2103 | 2214 | 2324 | | THEORETICAL HEATING COST * FURN. + HEAT PUMP \$ PER YEAR | | |
| | .07 | 1117 | 1100 | 1085 | 1070 | 1055 | 1040 | 1025 | 1010 | 995 | 980 | 965 | 950 | | | | |
| | .08 | 1117 | 1070 | 1040 | 1010 | 980 | 950 | 920 | 890 | 860 | 830 | 800 | 770 | | | | |
| | .09 | 1117 | 1040 | 1010 | 980 | 950 | 920 | 890 | 860 | 830 | 800 | 770 | 740 | | | | |
| | .10 | 1117 | 1010 | 980 | 950 | 920 | 890 | 860 | 830 | 800 | 770 | 740 | 710 | | | | |
| | .12 | 1117 | 980 | 950 | 920 | 890 | 860 | 830 | 800 | 770 | 740 | 710 | 680 | | | | |
| | .14 | 1117 | 950 | 920 | 890 | 860 | 830 | 800 | 770 | 740 | 710 | 680 | 650 | | | | |
| | .16 | 1117 | 920 | 890 | 860 | 830 | 800 | 770 | 740 | 710 | 680 | 650 | 620 | | | | |

ANNUAL AIR CONDITIONING COST WHEN COOLING LOAD IS SIZED TO MATCH COOLING CAPACITY OF HEAT PUMP

.05 .06 .07 .08 .09 .10 .12 .14 .16 <--ELECTRIC RATE \$/KWH

THE ABOVE ANNUAL HEATING AND COOLING OPERATING COSTS ARE THEORETICAL ESTIMATES ONLY AND ARE PROVIDED FOR A COMMON BASIS OF COMPARISON AMONG VARIOUS TYPES OF HEATING AND COOLING SYSTEMS. ACTUAL VALUES MAY VARY DEPENDING ON ACTUAL WEATHER CONDITIONS AND INDIVIDUAL USAGE PATTERNS.

BARD MANUFACTURING COMPANY

DUAL FUEL MID-ON HEAT PUMP GUIDE TO ENERGY COST SAVINGS

REGION 4
 HEAT PUMP MODEL: OUTDOOR 60URP0A INDOOR A61A0-A
 RATED COOLING CAP.: BTUH (95) 58000 SEER(10) 10
 RATED HEATING CAP.: BTUH (47) 61000 COP(47) 3.20 HSPF 7.50 MIN. ONR REG IV
 PURCHASE TYPE ELECTRIC PURCHASE EFFICIENCY 100.00 % AFUE

HEAT PUMP
 60URP0A
 677KWH

80,000

--- THEORETICAL ANNUAL HEATING COST ---
 HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

| | | |
|-----|------|------|
| .05 | 959 | 2025 |
| .06 | 1145 | 2431 |
| .07 | 1331 | 2837 |
| .08 | 1517 | 3243 |
| .09 | 1703 | 3649 |
| .10 | 1889 | 4055 |
| .11 | 2075 | 4461 |
| .12 | 2261 | 4867 |
| .13 | 2447 | 5273 |
| .14 | 2633 | 5679 |
| .15 | 2819 | 6085 |
| .16 | 3005 | 6491 |

BALANCE POINT 25 DEG.F.

90,000

--- THEORETICAL ANNUAL HEATING COST ---
 HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

| | | |
|-----|------|------|
| .05 | 1100 | 2279 |
| .06 | 1326 | 2736 |
| .07 | 1549 | 3193 |
| .08 | 1766 | 3650 |
| .09 | 1986 | 4107 |
| .10 | 2206 | 4564 |
| .11 | 2426 | 5021 |
| .12 | 2646 | 5478 |
| .13 | 2866 | 5935 |
| .14 | 3086 | 6392 |
| .15 | 3306 | 6849 |
| .16 | 3526 | 7307 |

BALANCE POINT 28 DEG.F.

100,000

--- THEORETICAL ANNUAL HEATING COST ---
 HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

| | | |
|-----|------|------|
| .05 | 1258 | 2533 |
| .06 | 1506 | 3041 |
| .07 | 1746 | 3549 |
| .08 | 1986 | 4057 |
| .09 | 2226 | 4564 |
| .10 | 2466 | 5072 |
| .11 | 2706 | 5580 |
| .12 | 2946 | 6088 |
| .13 | 3186 | 6596 |
| .14 | 3426 | 7104 |
| .15 | 3666 | 7612 |
| .16 | 3906 | 8119 |

BALANCE POINT 31 DEG.F.

110,000

--- THEORETICAL ANNUAL HEATING COST ---
 HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

| | | |
|-----|------|------|
| .05 | 1433 | 2787 |
| .06 | 1721 | 3349 |
| .07 | 2006 | 3904 |
| .08 | 2290 | 4463 |
| .09 | 2578 | 5021 |
| .10 | 2866 | 5580 |
| .11 | 3154 | 6139 |
| .12 | 3442 | 6697 |
| .13 | 3730 | 7256 |
| .14 | 4017 | 7815 |
| .15 | 4305 | 8374 |
| .16 | 4593 | 8932 |

BALANCE POINT 33 DEG.F.

120,000

--- THEORETICAL ANNUAL HEATING COST ---
 HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

| | | |
|-----|------|-------|
| .05 | 1805 | 3295 |
| .06 | 2166 | 3955 |
| .07 | 2527 | 4615 |
| .08 | 2889 | 5275 |
| .09 | 3250 | 5935 |
| .10 | 3611 | 6596 |
| .11 | 3973 | 7256 |
| .12 | 4334 | 7916 |
| .13 | 4695 | 8576 |
| .14 | 5056 | 9236 |
| .15 | 5417 | 9896 |
| .16 | 5778 | 10557 |

BALANCE POINT 37 DEG.F.

ANNUAL AIR CONDITIONING COST WHEN COOLING LOAD IS SIZED TO MATCH COOLING CAPACITY OF HEAT PUMP

| | | | | | | | | | | |
|----|-----|-----|-----|-----|-----|-----|-----|-----|-----|---|
| | .05 | .06 | .07 | .08 | .09 | .10 | .12 | .14 | .16 | |
| \$ | 278 | 260 | 303 | 346 | 390 | 433 | 520 | 607 | 693 | <-- ELECTRIC RATE \$/KWH <-- THEORETICAL AIR CONDITIONING COST |

THE ABOVE ANNUAL HEATING AND COOLING OPERATING COSTS ARE THEORETICAL ESTIMATES ONLY AND ARE PROVIDED FOR A COMMON BASIS OF COMPARISON BETWEEN VARIOUS TYPES OF HEATING AND COOLING SYSTEMS. ACTUAL VALUES MAY VARY DEPENDING ON ACTUAL WEATHER CONDITIONS AND INDIVIDUAL USAGE PATTERNS.

DOAL FUEL ADD-ON HEAT PUMP GUIDE TO ENERGY COST SAVINGS

MODEL NO. 4
 HEAT PUMP TYPE: OUTDOOR COILS
 COURSEQA/661A0-A INDOOR 661A0-A
 RATED HEATING CAP.: 3700 (47) 5000 (57) 6000 (67) 7000 (77) 8000 (87) 9000 (97) 10000 (107) 11000 (117) 12000 (127) 13000 (137) 14000 (147) 15000 (157) 16000 (167) 17000 (177) 18000 (187) 19000 (197) 20000 (207)
 FURNACE TYPE: FURN. OIL FURNACE EFFICIENCY: 78.00 % A2UB

| HEAT LOAD BTU/H | HEAT COST \$/YR | HEATING OIL COST - \$/GALLON | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
|-----------------|-----------------|------------------------------|------|--------|------|--------|------|---------|------|---------|------|---------|------|---|--|---|--|---|--|---|--|---|------|---|--|---|--|---|--|--|--|
| | | .70 | .80 | .90 | 1.00 | 1.10 | 1.20 | 1.30 | 1.40 | 1.50 | 1.60 | 1.70 | 1.80 | THEORETICAL HEATING COST * FURNACE ONLY | | | | THEORETICAL HEATING COST * FURN. + HEAT PUMP \$ PER YEAR | | | | | | | | | | | | | |
| 60,000 | 1.16 | \$ 671 | 767 | 863 | 959 | 1055 | 1151 | 1247 | 1342 | 1438 | 1534 | 1630 | 1726 | 671 767 863 959 1055 1151 1247 1342 1438 1534 1630 1726 | | | | 671 767 863 959 1055 1151 1247 1342 1438 1534 1630 1726 | | | | | | | | | | | | | |
| | | 1799 | 1816 | 1833 | 1850 | 1867 | 1884 | 1901 | 1918 | 1935 | 1952 | 1969 | 1986 | 2003 | 1799 1816 1833 1850 1867 1884 1901 1918 1935 1952 1969 1986 2003 | | | | 1799 1816 1833 1850 1867 1884 1901 1918 1935 1952 1969 1986 2003 | | | | | | | | | | | | |
| | | 70,000 | 1.16 | \$ 784 | 891 | 1004 | 1117 | 1230 | 1342 | 1455 | 1568 | 1675 | 1788 | 1901 | 2014 | 784 891 1004 1117 1230 1342 1455 1568 1675 1788 1901 2014 | | | | 784 891 1004 1117 1230 1342 1455 1568 1675 1788 1901 2014 | | | | | | | | | | | |
| | | | | 1890 | 1918 | 1946 | 1974 | 2002 | 2030 | 2058 | 2086 | 2114 | 2142 | 2170 | 2198 | 2226 | 1890 1918 1946 1974 2002 2030 2058 2086 2114 2142 2170 2198 2226 | | | | 1890 1918 1946 1974 2002 2030 2058 2086 2114 2142 2170 2198 2226 | | | | | | | | | | |
| | | | | 80,000 | 1.16 | \$ 891 | 1021 | 1151 | 1280 | 1405 | 1534 | 1664 | 1788 | 1918 | 2048 | 2172 | 2302 | 891 1021 1151 1280 1405 1534 1664 1788 1918 2048 2172 2302 | | | | 891 1021 1151 1280 1405 1534 1664 1788 1918 2048 2172 2302 | | | | | | | | | |
| | | | | | | 2121 | 2161 | 2194 | 2234 | 2268 | 2307 | 2341 | 2381 | 2415 | 2454 | 2488 | 2522 | 2121 2161 2194 2234 2268 2307 2341 2381 2415 2454 2488 2522 | | | | 2121 2161 2194 2234 2268 2307 2341 2381 2415 2454 2488 2522 | | | | | | | | | |
| | | | | | | 90,000 | 1.16 | \$ 1004 | 1151 | 1292 | 1438 | 1579 | 1726 | 1873 | 2014 | 2161 | 2302 | 2448 | 2589 | 1004 1151 1292 1438 1579 1726 1873 2014 2161 2302 2448 2589 | | | | 1004 1151 1292 1438 1579 1726 1873 2014 2161 2302 2448 2589 | | | | | | | |
| | | | | | | | | 2062 | 2136 | 2200 | 2262 | 2324 | 2386 | 2443 | 2505 | 2567 | 2629 | 2691 | 2747 | 2062 2136 2200 2262 2324 2386 2443 2505 2567 2629 2691 2747 | | | | 2062 2136 2200 2262 2324 2386 2443 2505 2567 2629 2691 2747 | | | | | | | |
| | | | | | | | | 100,000 | 1.16 | \$ 1117 | 1280 | 1438 | 1598 | 1760 | 1918 | 2076 | 2240 | 2398 | 2561 | 2719 | 2877 | 1117 1280 1438 1598 1760 1918 2076 2240 2398 2561 2719 2877 | | | | 1117 1280 1438 1598 1760 1918 2076 2240 2398 2561 2719 2877 | | | | | |
| | | | | | | | | | | 2279 | 2347 | 2415 | 2482 | 2550 | 2618 | 2685 | 2753 | 2821 | 2889 | 2956 | 3024 | 2279 2347 2415 2482 2550 2618 2685 2753 2821 2889 2956 3024 | | | | 2279 2347 2415 2482 2550 2618 2685 2753 2821 2889 2956 3024 | | | | | |
| | | | | | | | | | | 110,000 | 1.16 | \$ 1230 | 1405 | 1579 | 1760 | 1935 | 2110 | 2285 | 2465 | 2640 | 2815 | 2990 | 3165 | 1230 1405 1579 1760 1935 2110 2285 2465 2640 2815 2990 3165 | | | | 1230 1405 1579 1760 1935 2110 2285 2465 2640 2815 2990 3165 | | | |
| | | | | | | | | | | | | 2503 | 2577 | 2650 | 2724 | 2798 | 2872 | 2946 | 3020 | 3094 | 3168 | 3242 | 3316 | 2503 2577 2650 2724 2798 2872 2946 3020 3094 3168 3242 3316 | | | | 2503 2577 2650 2724 2798 2872 2946 3020 3094 3168 3242 3316 | | | |

ANNUAL AIR CONDITIONING COST WHEN COOLING LOAD IS SIZED TO MATCH COOLING CAPACITY OF HEAT PUMP
 \$ 218 280 303 348 390 438 520 609 693

--- ELECTRIC RATE \$/KWH
 --- THEORETICAL AIR CONDITIONING COST

THE ABOVE ANNUAL HEATING AND COOLING OPERATING COSTS ARE THEORETICAL ESTIMATES ONLY AND ARE PROVIDED FOR A COMMON BASIS OF COMPARISON BETWEEN VARIOUS TYPES OF HEATING AND COOLING SYSTEMS. ACTUAL VALUES MAY VARY DEPENDING ON ACTUAL WEATHER CONDITIONS AND INDIVIDUAL DESIGN PATTERN.

BAIRD MANUFACTURING COMPANY
DUAL FUEL ADD-ON HEAT PUMP GUIDE TO ENERGY COST SAVINGS

REGION 4
 HEAT PUMP MODELS: OUTDOOR COILS
 COILS/AS1AD-A INDEX AS1AD-A
 RATED COOLING CAP.: 100,000 BTU/H (95) 50000 BTU/H (95) 3.70, HSPF 7.50 MIN. DHR REG IV
 RATED HEATING CAP.: 100,000 BTU/H (74) 50000 BTU/H (74) 3.70, HSPF 7.50 MIN. DHR REG IV
 FURNACE TYPE PROPANE GAS FURNACE EFFICIENCY 78.00 % A/E/W

| HEAT LOSS BTU/H | ELECTRIC COST \$/KWH | PROPANE GAS COST - \$/GALLON | | | | | | | | | | | | |
|-----------------|----------------------|------------------------------|------|------|------|------|------|------|------|------|------|------|------|--|
| | | .60 | .65 | .70 | .75 | .80 | .85 | .90 | .95 | 1.00 | 1.10 | 1.20 | | |
| 60,000 | | \$ 874 | 947 | 1021 | 1094 | 1168 | 1241 | 1314 | 1388 | 1461 | 1608 | 1754 | 1754 | <--THEORETICAL HEATING COST * FURNACE ONLY |
| | .05 | 688 | 699 | 716 | 727 | 744 | 756 | 767 | 784 | 795 | 823 | 852 | 852 | THEORETICAL HEATING COST * FURN. + HEAT PUMP \$ PER YEAR |
| | .06 | 789 | 801 | 818 | 829 | 846 | 858 | 869 | 886 | 897 | 925 | 954 | 954 | |
| | .07 | 890 | 903 | 920 | 931 | 948 | 960 | 971 | 988 | 1000 | 1028 | 1057 | 1057 | |
| | .08 | 991 | 1005 | 1022 | 1033 | 1050 | 1062 | 1073 | 1090 | 1102 | 1130 | 1159 | 1159 | |
| | .09 | 1092 | 1107 | 1124 | 1135 | 1152 | 1164 | 1175 | 1192 | 1204 | 1232 | 1261 | 1261 | |
| | .10 | 1193 | 1209 | 1226 | 1237 | 1254 | 1266 | 1277 | 1294 | 1306 | 1334 | 1363 | 1363 | |
| | .12 | 1394 | 1411 | 1428 | 1439 | 1456 | 1468 | 1479 | 1496 | 1508 | 1536 | 1565 | 1565 | |
| | .14 | 1595 | 1613 | 1630 | 1641 | 1658 | 1670 | 1681 | 1698 | 1710 | 1738 | 1767 | 1767 | |
| | .16 | 1796 | 1815 | 1832 | 1843 | 1860 | 1872 | 1883 | 1900 | 1912 | 1940 | 1969 | 1969 | |
| | | 1839 | 1858 | 1875 | 1886 | 1903 | 1915 | 1926 | 1943 | 1955 | 1983 | 2012 | 2012 | BALANCE POINT 18 DEG.F. |
| 70,000 | | \$ 1021 | 1105 | 1190 | 1280 | 1365 | 1450 | 1534 | 1619 | 1704 | 1878 | 2048 | 2048 | <--THEORETICAL HEATING COST * FURNACE ONLY |
| | .05 | 812 | 825 | 857 | 885 | 908 | 931 | 959 | 981 | 1004 | 1055 | 1100 | 1100 | THEORETICAL HEATING COST * FURN. + HEAT PUMP \$ PER YEAR |
| | .06 | 919 | 933 | 966 | 994 | 1018 | 1041 | 1069 | 1091 | 1114 | 1165 | 1210 | 1210 | |
| | .07 | 1026 | 1041 | 1074 | 1102 | 1126 | 1149 | 1177 | 1200 | 1223 | 1274 | 1319 | 1319 | |
| | .08 | 1133 | 1149 | 1182 | 1210 | 1234 | 1257 | 1285 | 1308 | 1331 | 1382 | 1427 | 1427 | |
| | .09 | 1240 | 1257 | 1290 | 1318 | 1342 | 1365 | 1393 | 1416 | 1439 | 1490 | 1535 | 1535 | |
| | .10 | 1347 | 1365 | 1398 | 1426 | 1450 | 1473 | 1501 | 1524 | 1547 | 1598 | 1643 | 1643 | |
| | .12 | 1548 | 1567 | 1600 | 1628 | 1652 | 1675 | 1703 | 1726 | 1749 | 1790 | 1835 | 1835 | |
| | .14 | 1749 | 1769 | 1802 | 1830 | 1854 | 1877 | 1905 | 1928 | 1951 | 1992 | 2037 | 2037 | |
| | .16 | 1950 | 1971 | 2004 | 2032 | 2056 | 2079 | 2107 | 2130 | 2153 | 2194 | 2239 | 2239 | |
| | | 1993 | 2015 | 2048 | 2076 | 2100 | 2123 | 2146 | 2169 | 2192 | 2233 | 2278 | 2278 | BALANCE POINT 22 DEG.F. |
| 80,000 | | \$ 1168 | 1263 | 1365 | 1461 | 1557 | 1658 | 1754 | 1850 | 1952 | 2144 | 2341 | 2341 | <--THEORETICAL HEATING COST * FURNACE ONLY |
| | .05 | 914 | 942 | 970 | 998 | 1026 | 1055 | 1083 | 1111 | 1139 | 1190 | 1247 | 1247 | THEORETICAL HEATING COST * FURN. + HEAT PUMP \$ PER YEAR |
| | .06 | 1021 | 1050 | 1078 | 1106 | 1134 | 1162 | 1190 | 1218 | 1246 | 1297 | 1354 | 1354 | |
| | .07 | 1128 | 1157 | 1185 | 1213 | 1241 | 1269 | 1297 | 1325 | 1353 | 1404 | 1461 | 1461 | |
| | .08 | 1235 | 1264 | 1292 | 1320 | 1348 | 1376 | 1404 | 1432 | 1460 | 1511 | 1568 | 1568 | |
| | .09 | 1342 | 1371 | 1400 | 1428 | 1456 | 1484 | 1512 | 1540 | 1568 | 1619 | 1676 | 1676 | |
| | .10 | 1449 | 1478 | 1507 | 1535 | 1563 | 1591 | 1619 | 1647 | 1675 | 1726 | 1783 | 1783 | |
| | .12 | 1650 | 1680 | 1710 | 1738 | 1766 | 1794 | 1822 | 1850 | 1878 | 1929 | 1986 | 1986 | |
| | .14 | 1851 | 1881 | 1910 | 1938 | 1966 | 1994 | 2022 | 2050 | 2078 | 2129 | 2186 | 2186 | |
| | .16 | 2052 | 2082 | 2110 | 2138 | 2166 | 2194 | 2222 | 2250 | 2278 | 2329 | 2386 | 2386 | |
| | | 2095 | 2125 | 2153 | 2181 | 2209 | 2237 | 2265 | 2293 | 2321 | 2372 | 2429 | 2429 | BALANCE POINT 25 DEG.F. |
| 90,000 | | \$ 1314 | 1427 | 1534 | 1642 | 1754 | 1862 | 1974 | 2082 | 2194 | 2415 | 2635 | 2635 | <--THEORETICAL HEATING COST * FURNACE ONLY |
| | .05 | 1077 | 1122 | 1168 | 1213 | 1263 | 1309 | 1354 | 1399 | 1450 | 1540 | 1636 | 1636 | THEORETICAL HEATING COST * FURN. + HEAT PUMP \$ PER YEAR |
| | .06 | 1184 | 1230 | 1276 | 1321 | 1371 | 1417 | 1462 | 1507 | 1558 | 1648 | 1744 | 1744 | |
| | .07 | 1291 | 1337 | 1383 | 1428 | 1478 | 1523 | 1568 | 1613 | 1664 | 1754 | 1850 | 1850 | |
| | .08 | 1398 | 1444 | 1490 | 1535 | 1585 | 1630 | 1675 | 1720 | 1771 | 1861 | 1957 | 1957 | |
| | .09 | 1505 | 1551 | 1597 | 1642 | 1692 | 1737 | 1782 | 1827 | 1878 | 1968 | 2064 | 2064 | |
| | .10 | 1612 | 1658 | 1704 | 1749 | 1799 | 1844 | 1889 | 1934 | 1985 | 2075 | 2171 | 2171 | |
| | .12 | 1813 | 1859 | 1905 | 1950 | 1995 | 2040 | 2085 | 2130 | 2181 | 2271 | 2367 | 2367 | |
| | .14 | 2014 | 2060 | 2106 | 2151 | 2196 | 2241 | 2286 | 2331 | 2382 | 2472 | 2568 | 2568 | |
| | .16 | 2215 | 2261 | 2307 | 2352 | 2397 | 2442 | 2487 | 2532 | 2583 | 2673 | 2769 | 2769 | |
| | | 2258 | 2304 | 2350 | 2395 | 2440 | 2485 | 2530 | 2575 | 2626 | 2716 | 2812 | 2812 | BALANCE POINT 28 DEG.F. |
| 100,000 | | \$ 1461 | 1585 | 1704 | 1828 | 1952 | 2070 | 2194 | 2313 | 2437 | 2680 | 2928 | 2928 | <--THEORETICAL HEATING COST * FURNACE ONLY |
| | .05 | 1184 | 1235 | 1285 | 1337 | 1388 | 1438 | 1495 | 1546 | 1596 | 1698 | 1805 | 1805 | THEORETICAL HEATING COST * FURN. + HEAT PUMP \$ PER YEAR |
| | .06 | 1291 | 1342 | 1392 | 1444 | 1494 | 1544 | 1594 | 1644 | 1694 | 1796 | 1903 | 1903 | |
| | .07 | 1398 | 1449 | 1499 | 1551 | 1601 | 1651 | 1701 | 1751 | 1801 | 1903 | 2010 | 2010 | |
| | .08 | 1505 | 1556 | 1606 | 1658 | 1708 | 1758 | 1808 | 1858 | 1908 | 2010 | 2117 | 2117 | |
| | .09 | 1612 | 1663 | 1713 | 1765 | 1815 | 1865 | 1915 | 1965 | 2015 | 2117 | 2224 | 2224 | |
| | .10 | 1719 | 1770 | 1820 | 1872 | 1922 | 1972 | 2022 | 2072 | 2122 | 2224 | 2331 | 2331 | |
| | .12 | 1920 | 1971 | 2021 | 2071 | 2121 | 2171 | 2221 | 2271 | 2321 | 2423 | 2530 | 2530 | |
| | .14 | 2121 | 2172 | 2222 | 2272 | 2322 | 2372 | 2422 | 2472 | 2522 | 2624 | 2731 | 2731 | |
| | .16 | 2322 | 2373 | 2423 | 2473 | 2523 | 2573 | 2623 | 2673 | 2723 | 2825 | 2932 | 2932 | |
| | | 2365 | 2416 | 2466 | 2516 | 2566 | 2616 | 2666 | 2716 | 2766 | 2868 | 2975 | 2975 | BALANCE POINT 31 DEG.F. |
| 110,000 | | \$ 1608 | 1743 | 1878 | 2008 | 2144 | 2279 | 2415 | 2550 | 2680 | 2951 | 3216 | 3216 | <--THEORETICAL HEATING COST * FURNACE ONLY |
| | .05 | 1388 | 1461 | 1546 | 1625 | 1704 | 1783 | 1861 | 1946 | 2025 | 2183 | 2347 | 2347 | THEORETICAL HEATING COST * FURN. + HEAT PUMP \$ PER YEAR |
| | .06 | 1495 | 1568 | 1653 | 1732 | 1811 | 1890 | 1969 | 2048 | 2127 | 2285 | 2449 | 2449 | |
| | .07 | 1602 | 1675 | 1760 | 1839 | 1918 | 1997 | 2076 | 2155 | 2234 | 2392 | 2556 | 2556 | |
| | .08 | 1709 | 1782 | 1867 | 1946 | 2025 | 2104 | 2183 | 2262 | 2341 | 2499 | 2663 | 2663 | |
| | .09 | 1816 | 1889 | 1974 | 2053 | 2132 | 2211 | 2290 | 2369 | 2448 | 2606 | 2770 | 2770 | |
| | .10 | 1923 | 1996 | 2081 | 2160 | 2239 | 2318 | 2397 | 2476 | 2555 | 2713 | 2877 | 2877 | |
| | .12 | 2124 | 2197 | 2282 | 2361 | 2440 | 2519 | 2598 | 2677 | 2756 | 2914 | 3078 | 3078 | |
| | .14 | 2325 | 2398 | 2483 | 2562 | 2641 | 2720 | 2799 | 2878 | 2957 | 3115 | 3279 | 3279 | |
| | .16 | 2526 | 2599 | 2684 | 2763 | 2842 | 2921 | 3000 | 3079 | 3158 | 3316 | 3480 | 3480 | |
| | | 2569 | 2642 | 2727 | 2806 | 2885 | 2964 | 3043 | 3122 | 3201 | 3359 | 3523 | 3523 | BALANCE POINT 33 DEG.F. |

ANNUAL AIR CONDITIONING COST WHEN COOLING LOAD IS SIZED TO MATCH COOLING CAPACITY OF HEAT PUMP

| | .05 | .06 | .07 | .08 | .09 | .10 | .12 | .14 | .16 | <--ELECTRIC RATE \$/KWH | <--THEORETICAL AIR CONDITIONING COST |
|--|--------|-----|-----|-----|-----|-----|-----|-----|-----|-------------------------|--------------------------------------|
| | \$ 216 | 260 | 303 | 346 | 390 | 433 | 520 | 607 | 693 | | |

THE ABOVE ANNUAL HEATING AND COOLING OPERATING COSTS ARE THEORETICAL ESTIMATES ONLY AND ARE PROVIDED FOR A COMMON BASIS OF COMPARISON BETWEEN VARIOUS TYPES OF HEATING AND COOLING SYSTEMS. ACTUAL VALUES MAY VARY DEPENDING ON ACTUAL WEATHER CONDITIONS AND INDIVIDUAL USAGE PATTERN.