



**DUAL FUEL ADD-ON HEAT PUMP GUIDE
FOR OPERATIONAL COST SAVINGS**

REGION 4



BARD MANUFACTURING CO. • BRYAN, OHIO 43506

Dependable quality equipment since 1914



This map is reasonably accurate for most parts of the United States but is necessarily highly generalized and consequently not too accurate in mountainous regions, particularly in the Rockies.

TABLE OF CONTENTS

General Description				i
How To Use				ii
Heat Pump Outdoor Model	Heat Pump Indoor Model	Furnace Fuel	Furnace AFUE Efficiency Rating	Page
WQS30/WQSD30	H3AQ/H3AQ1	Electric Natural Gas Oil Propane	100% 65% 65% 65%	1 2 3 4
WQS36/WQSD36	H3AQ/H3AQ1	Electric Natural Gas Oil Propane	100% 65% 65% 65%	5 6 7 8
24HPQ2	H24QS1	Electric Natural Gas Oil Propane	100% 65% 65% 65%	9 10 11 12
30HPQ4	H3AQ/H3AQ1	Electric Natural Gas Oil Propane	100% 65% 65% 65%	13 14 15 16
36HPQ4	H3AQ/H3AQ1	Electric Natural Gas Oil Propane	100% 65% 65% 65%	17 18 19 20
42HPQ	H5AQ	Electric Natural Gas Oil Propane	100% 65% 65% 65%	21 22 23 24
48HPQ2	H5AQ	Electric Natural Gas Oil Propane	100% 65% 65% 65%	25 26 27 28

GENERAL DESCRIPTION

WHAT DOES THIS GUIDE SHOW?

This operational cost savings guide has been prepared to show theoretical cost savings for Bard dual fuel "add-on" heat pumps when used with either existing or new furnaces. It covers add-on applications for electric, oil, propane gas and natural gas type forced air furnaces. It includes both air source heat pumps and ground water source heat pumps at many combinations of gas, oil and electrical rates. It enables the user not only to make a theoretical operating cost comparison at today's fuel costs but also at future estimated higher energy costs.

It is important to understand that this is a theoretical comparison between fuels. Actual operation costs can vary depending on many difficult to predict variables such as the actual design heating or cooling load, air infiltration, and wind effects, solar effect, efficiency of existing furnace, severity of weather for a given heating or cooling season and also individual usage pattern.

SPECIAL FEATURE - FSM-1 FUEL SAVER MODULE

These estimates utilize the Bard FSM-1 Fuel Saver Module which permit the heat pump to operate below the balance point to maximize the energy savings. For each application an analysis should be made to determine the economic balance point which is the outdoor temperature at which it becomes more cost effective to shut the heat pump down with an outdoor thermostat. This temperature varies with each combination of fuel cost and furnace and heat pump efficiency level. Refer to tables included in the instructions with the FSM-1 module.

FURNACE EFFICIENCY

For purposes of these cost estimates, furnace efficiency levels of 100% AFUE for electric, 65% AFUE for natural and propane gas and 65% AFUE for oil was chosen. We recognize that any variation in efficiency from these values will change the operating cost somewhat. These values were chosen to best represent typical efficiency levels of most equipment in the field today. Bard standing pilot gas furnaces without flue dampers range from 60.6% to 67.9% AFUE with a 65.1% average. New Bard oil furnaces which utilize high speed flame retention head power burners range from 72% to 83.5% AFUE with the average at 78.5%. In order to represent the typical efficiency level of oil-fired furnaces currently installed in the field, it is necessary to recognize the fact that many older less efficient designs are still in use and that the efficiency level of any oil heating system will be reduced by improper adjustment or a lack of adequate maintenance and servicing on a regular basis. An oil-fired system typically requires more frequent and complex maintenance to prevent degradation of its efficiency level, hence, a 65% AFUE was chosen for these calculations. The AFUE efficiency varies, depending on the design of the specific piece of equipment and its maintenance and condition.

HOW TO USE DUAL FUEL ADD-ON
HEAT PUMP GUIDE TO ENERGY COST SAVINGS

1. Determine the heating Btuh loss and cooling Btuh gain for structure using a Bard "Whole-House Heat Loss and Gain Work Sheet," Form B008, or ACCA "Load Calculation," Manual J.
 - a. Heating house Btuh loss is _____.
 - b. Cooling house Btuh gain is _____.
2. Determine the type of fuel available at structure (what type of [fuel] heating system is already there).
 - a. Electricity
 - b. Natural Gas
 - c. Propane Gas
 - d. Fuel Oil
 - e. Good water supply and disposal
3. Call local utilities and determine area energy costs.
 - a. Electricity _____ \$/Kilowatt-hour
 - b. Natural Gas _____ \$/Therm
 - c. Propane Gas _____ \$/Gallon
 - d. Fuel Oil _____ \$/Gallon
4. Tentatively select an add-on heat pump system using Bard Manual 2100-057, "Heat Pump Sizing" as a guide, and a Bard equipment catalog.
 - a. Air to air heat pump
Model _____ Indoor Coil _____
Btuh _____ Heat Btuh _____ Cool
 - b. Water to air
Model _____ Indoor Coil _____
Btuh _____ Heat Btuh _____ Cool
5. Determine heating region where the structure is located. To do this, find the geographic location of house on regional heating load hours map. A map is located inside the front cover of this guide.
 - a. Region structure is located _____.

YOU ARE NOW READY TO USE THE "DUAL FUEL ADD-ON HEAT PUMP GUIDE"
6. Select the "Dual Fuel Add-On Heat Pump Guide" for the region the structure is located. (See step 5 above)

7. Locate the add-on heat pump model or models you tentatively selected (Step 4) in the "Guide." Refer to Table of Contents.

EXAMPLE: 36HPQ4 w/H3AQ Indoor Coil

**BARD MANUFACTURING COMPANY
DUAL FUEL ADD-ON HEAT PUMP GUIDE TO ENERGY COST SAVINGS**

<u>REGION 4</u>	<u>HEAT PUMP MODEL:</u>	<u>OUTDOOR 36HPQ4</u>	<u>INDOOR H3AQ/H3AQ1</u>
ARI RATED COOLING CAP.:	BTUH 195	1 - 16500	SEER 7.50
ARI RATED HEATING CAP.:	BTUH 147	1 - 40500	COP (47) 2.62
	BTUH (17)	1 - 25800	HSPF 6.40 MIN.DHR COP (17) 1.42

8. Now locate the furnace type by fuel used (Step 2).

EXAMPLE: A fuel oil furnace with AFUE of 65%.

<u>FURNACE TYPE FUEL OIL</u>	<u>FURNACE EFFICIENCY</u>	<u>.65.00% AFUE</u>
------------------------------	---------------------------	---------------------

9. You now have located the page or pages that will help you determine annual operating cost. See example - Figure 1.

- a. Locate the closest structure loss in Btuh column on left side of page (step 1).

EXAMPLE: 70,000 Btuh Heat Loss

- b. Locate the heating cost per unit at top of page (step 3).

EXAMPLE: \$1.40 per gallon fuel oil.

- c. Now read down the fuel cost column until directly across from structure heat loss in Btuh. This will be the theoretical annual heating cost using only the furnace.

EXAMPLE: 70,000 Btuh heat loss @ \$1.40 per gallon fuel oil, the annual cost will be \$1,878.

- d. Next locate the electric cost \$/Kw under Heat Loss Btuh for structure (step 3).

EXAMPLE: \$.06 Kw rate

- e. Now once again read down the fuel cost column until directly across from electric cost \$/Kw. You now have located the annual heating cost for the house using an add-on heat pump with the furnace.

EXAMPLE: 70,000 Btuh structure heat loss, with \$.06 Kw cost and \$1.40 per gallon fuel oil. The annual cost using a 36HPQ4 Bard heat pump with the oil furnace would be \$1173 for an annual savings of \$705 (\$1878 minus \$1173).

Now repeat steps 8 through 9 for each type fuel and/or heat pump selected. This will enable you to select the best combination of furnace and heat pump to use for a structure.

10. The balance point (the outdoor temperature at which the heat pump is running 100% of the time and just meeting structure heat loss requirements) is located on right side of page.

EXAMPLE: For a structure with a 70,000 Btu/h with a 36HPQ4 heat pump has a balance point of 31 Deg. F. Below this theoretical balance point, the heating load is automatically transferred between the heat pump and the furnace by the wall thermostat to maintain the desired temperature. This is accomplished with the FSM-1 Fuel Saver Module.

70,000	6	1342	1478	1613	1743	1875	2014	2149	2285	2423	2565	2706	2847	4--THEORETICAL HEATING COST + FURNACE ONLY
.03	5	663	688	716	739	767	795	813	845	868	895	925	956	THEORETICAL HEATING COST + FURNACE + HEAT PUMP \$ PER YEAR
.04	5	705	723	852	874	937	931	953	931	974	1060	1111	1152	
.05	5	931	959	987	1019	1019	1054	1029	1117	1132	1192	1242	1291	
.06	5	1266	1094	1122	1143	1173	1251	1226	1234	1275	1331	1337	1352	
.07	5	1261	1330	1258	1280	1329	1337	1360	1385	1412	1457	1419	1523	
.08	5	1337	1365	1393	1426	1444	1472	1495	1523	1546	1606	1551	1702	
.09	5	1467	1495	1523	1546	1574	1602	1625	1653	1675	1735	1793	1835	
.10	5	1602	1630	1648	1681	1709	1737	1760	1788	1811	1862	1918	1954	
.12	5	1873	1901	1929	1952	1990	2004	2031	2059	2092	2118	2159	2240	

BALANCE POINT IS DEG.F. 10

11. To find annual cooling cost of heat pump, look at the bottom of page under annual air conditioning cost. Directly under the electric rate \$/Kw (step 3) line, is located the annual cooling cost.

EXAMPLE: At .06 \$/Kw rate for electricity, the cooling cost would be \$234.00 annually.

ANNUAL AIR CONDITIONING COST WHEN COOLING LOAD IS SIZED TO MATCH COOLING CAPACITY OF HEAT PUMP.										5--ELECTRIC RATE \$/KWH			6--THEORETICAL AIR CONDITIONING COST	
5	117	156	167	176	187	197	208	209	210	212	213	214	215	216

THE ABOVE ANNUAL HEATING AND COOLING OPERATING COSTS ARE THEORETICAL ESTIMATES ONLY AND ARE PROVIDED FOR A COMMON BASIS OF COMPARISON BETWEEN VARIOUS TYPES OF HEATING AND COOLING SYSTEMS. ACTUAL VALUES MAY VARY DEPENDING ON ACTUAL WEATHER CONDITIONS AND INDIVIDUAL USAGE PATTERN.

NOTE. The accuracy of the "Dual Fuel-Add-On Heat Pump Guide to Energy Cost Savings," is directly affected by how accurately you estimate the structure's heat loss and heat gain in step 1. Because of uncontrollable variables, Bard Manufacturing Company is not responsible for any variation in actual operating costs from these theoretical estimates.

BARD MANUFACTURING COMPANY
DUAL FUEL ADD-ON HEAT PUMP GUIDE TO ENERGY COST SAVINGS

REGION 4
HEAT PUMP MODEL: COMPRESSOR SECTION HRS530/HRS530 INDOOR H340/H340
COOLING CAPACITY AT -22 DEG.F ENTERING WATER TEMP: -31500 BTUH -14.0 COP
HEATING CAPACITY AT -21 DEG.F ENTERING WATER TEMP: -33200 BTUH -14.0 COP
FURNACE TYPE ELECTRIC ---

HEAT LOSS
BTUH
ELEC.
COST
\$/KWH

30,000 --- THEORETICAL ANNUAL HEATING COST ---
HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

.03	\$	163	451
.04	\$	214	603
.05	\$	276	756
.06	\$	338	908
.07	\$	383	1060
.08	\$	440	1213
.09	\$	496	1365
.10	\$	547	1517
.12	\$	654	1822

BALANCE POINT -11 DEG.F.

35,000 --- THEORETICAL ANNUAL HEATING COST ---
HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

.03	\$	186	530
.04	\$	263	705
.05	\$	325	865
.06	\$	378	1020
.07	\$	433	1171
.08	\$	507	1316
.09	\$	569	1496
.10	\$	637	1771
.12	\$	761	2127

BALANCE POINT 0 DEG.F.

40,000 --- THEORETICAL ANNUAL HEATING COST ---
HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

.03	\$	214	603
.04	\$	287	806
.05	\$	361	1010
.06	\$	434	1213
.07	\$	507	1416
.08	\$	581	1619
.09	\$	656	1822
.10	\$	727	2025
.12	\$	868	2431

BALANCE POINT 8 DEG.F.

50,000 --- THEORETICAL ANNUAL HEATING COST ---
HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

.03	\$	282	756
.04	\$	376	1010
.05	\$	473	1263
.06	\$	569	1477
.07	\$	660	1677
.08	\$	750	2025
.09	\$	846	2279
.10	\$	942	2513
.12	\$	1134	3341

BALANCE POINT 19 DEG.F.

60,000 --- THEORETICAL ANNUAL HEATING COST ---
HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

.03	\$	366	908
.04	\$	485	1213
.05	\$	609	1517
.06	\$	733	1822
.07	\$	852	2127
.08	\$	976	2431
.09	\$	1100	2736
.10	\$	1218	3041
.12	\$	1461	3650

BALANCE POINT 27 DEG.F.

ANNUAL AIR CONDITIONING COST WHEN COOLING LOAD IS SIZED TO MATCH COOLING CAPACITY OF HEAT PUMP.

\$.03 .04 .05 .06 .07 .08 .09 .10 .12
\$ 60 80 100 120 140 160 180 200 240

--- ELECTRIC RATE \$/KWH

--- THEORETICAL AIR CONDITIONING COST

THE ABOVE ANNUAL HEATING AND COOLING OPERATING COSTS ARE THEORETICAL ESTIMATES ONLY AND ARE PROVIDED FOR A COMMON BASIS OF COMPARISON BETWEEN VARIOUS TYPES OF HEATING AND COOLING SYSTEMS. ACTUAL VALUES MAY VARY DEPENDING ON ACTUAL WEATHER CONDITIONS AND INDIVIDUAL USAGE PATTERN.

B&G MANUFACTURING COMPANY
DUAL FUEL ADD-ON HEAT PUMP GUIDE TO ENERGY COST SAVINGS

REGION 4
HEAT PUMP MODEL: COMPRESSOR SECTION X952060250001 INDOOR - D360(H14) ---
COOLING CAPACITY AT -23 DEG.F. ENTERING WATER TEMP: -46.00 BTUH 1.348 COP
HEATING CAPACITY AT -23 DEG.F. ENTERING WATER TEMP: -33.00 BTUH 3.325 EER
FURNACE TYPE ENCL-D1C1 ---
FURNACE EFFICIENCY .82292% EFUE

HEAT LOSS BTUH	ELEC. COST \$/KWH	HEATING OIL COST - \$/GALLON											
		1.00	1.10	1.20	1.30	1.40	1.50	1.60	1.70	1.80	2.00	2.20	2.40
30,000													
+03	\$ 575	631	688	744	806	863	919	976	1032	1151	1263	1382	--THEORETICAL HEATING COST + FURNACE ONLY
+04	\$ 163	163	193	169	169	169	169	169	169	169	169	169	--THEORETICAL HEATING COST + FURN+ HEAT PUMP \$ PER YEAR
+05	\$ 214	214	220	220	220	220	220	220	220	220	220	220	--THEORETICAL HEATING COST + FURN+ HEAT PUMP \$ PER YEAR
+06	\$ 270	270	276	276	276	276	276	276	276	276	276	276	--THEORETICAL HEATING COST + FURN+ HEAT PUMP \$ PER YEAR
+07	\$ 327	327	333	332	332	332	332	332	332	332	332	332	--THEORETICAL HEATING COST + FURN+ HEAT PUMP \$ PER YEAR
+08	\$ 378	378	383	383	383	383	383	383	383	383	383	383	--THEORETICAL HEATING COST + FURN+ HEAT PUMP \$ PER YEAR
+09	\$ 424	424	440	440	440	440	440	440	440	440	440	440	--THEORETICAL HEATING COST + FURN+ HEAT PUMP \$ PER YEAR
+10	\$ 460	460	496	496	496	496	496	496	496	496	496	496	--THEORETICAL HEATING COST + FURN+ HEAT PUMP \$ PER YEAR
+12	\$ 484	484	511	547	547	547	547	547	547	547	547	547	BALANCE POINT -11 DEG.F.
35,000													
+03	\$ 671	739	806	868	936	1004	1072	1139	1207	1342	1478	1613	--THEORETICAL HEATING COST + FURNACE ONLY
+04	\$ 191	191	191	191	191	191	191	191	191	191	191	191	--THEORETICAL HEATING COST + FURN+ HEAT PUMP \$ PER YEAR
+05	\$ 253	253	253	253	253	253	253	253	253	253	253	253	--THEORETICAL HEATING COST + FURN+ HEAT PUMP \$ PER YEAR
+06	\$ 315	315	318	318	318	318	318	318	318	318	318	318	--THEORETICAL HEATING COST + FURN+ HEAT PUMP \$ PER YEAR
+07	\$ 378	378	378	378	378	378	378	378	378	378	378	378	--THEORETICAL HEATING COST + FURN+ HEAT PUMP \$ PER YEAR
+08	\$ 425	425	444	444	444	444	444	444	444	444	444	444	--THEORETICAL HEATING COST + FURN+ HEAT PUMP \$ PER YEAR
+09	\$ 467	467	507	507	507	507	507	507	507	507	507	507	--THEORETICAL HEATING COST + FURN+ HEAT PUMP \$ PER YEAR
+10	\$ 507	507	569	569	569	569	569	569	569	569	569	569	--THEORETICAL HEATING COST + FURN+ HEAT PUMP \$ PER YEAR
+12	\$ 531	531	631	631	631	631	631	631	631	631	631	631	BALANCE POINT 0 DEG.F.
40,000													
+03	\$ 767	840	919	998	1072	1151	1224	1303	1382	1534	1687	1839	--THEORETICAL HEATING COST + FURNACE ONLY
+04	\$ 214	220	220	220	220	220	220	220	220	220	220	220	--THEORETICAL HEATING COST + FURN+ HEAT PUMP \$ PER YEAR
+05	\$ 287	293	293	293	293	293	293	293	293	293	293	293	--THEORETICAL HEATING COST + FURN+ HEAT PUMP \$ PER YEAR
+06	\$ 355	361	361	361	361	361	361	361	361	361	361	361	--THEORETICAL HEATING COST + FURN+ HEAT PUMP \$ PER YEAR
+07	\$ 428	434	434	434	434	434	434	434	434	434	434	434	--THEORETICAL HEATING COST + FURN+ HEAT PUMP \$ PER YEAR
+08	\$ 466	466	502	502	502	502	502	502	502	502	502	502	--THEORETICAL HEATING COST + FURN+ HEAT PUMP \$ PER YEAR
+09	\$ 504	504	569	569	569	569	569	569	569	569	569	569	--THEORETICAL HEATING COST + FURN+ HEAT PUMP \$ PER YEAR
+10	\$ 535	535	675	675	675	675	675	675	675	675	675	675	--THEORETICAL HEATING COST + FURN+ HEAT PUMP \$ PER YEAR
+12	\$ 564	564	643	643	643	643	643	643	643	643	643	643	BALANCE POINT 8 DEG.F.
50,000													
+03	\$ 959	1055	1151	1247	1342	1438	1534	1630	1726	1918	2110	2302	--THEORETICAL HEATING COST + FURNACE ONLY
+04	\$ 287	293	299	304	310	315	321	327	333	339	345	351	--THEORETICAL HEATING COST + FURN+ HEAT PUMP \$ PER YEAR
+05	\$ 372	378	383	383	389	394	400	400	406	417	423	429	--THEORETICAL HEATING COST + FURN+ HEAT PUMP \$ PER YEAR
+06	\$ 457	462	468	468	473	479	485	485	490	502	507	513	--THEORETICAL HEATING COST + FURN+ HEAT PUMP \$ PER YEAR
+07	\$ 521	527	552	552	558	564	569	569	575	586	592	598	--THEORETICAL HEATING COST + FURN+ HEAT PUMP \$ PER YEAR
+08	\$ 565	565	631	637	637	643	648	654	654	660	671	677	--THEORETICAL HEATING COST + FURN+ HEAT PUMP \$ PER YEAR
+09	\$ 605	610	716	716	722	727	733	733	739	750	756	761	--THEORETICAL HEATING COST + FURN+ HEAT PUMP \$ PER YEAR
+10	\$ 644	644	801	801	806	812	814	818	823	835	840	846	--THEORETICAL HEATING COST + FURN+ HEAT PUMP \$ PER YEAR
+12	\$ 674	680	884	884	891	897	902	902	902	919	926	931	BALANCE POINT 19 DEG.F.
60,000													
+03	\$ 1151	1263	1382	1495	1613	1726	1819	1957	2070	2302	2533	2764	--THEORETICAL HEATING COST + FURNACE ONLY
+04	\$ 359	400	411	423	434	445	457	462	473	496	518	541	--THEORETICAL HEATING COST + FURN+ HEAT PUMP \$ PER YEAR
+05	\$ 575	595	595	609	620	631	643	648	660	682	705	727	--THEORETICAL HEATING COST + FURN+ HEAT PUMP \$ PER YEAR
+06	\$ 711	692	694	705	716	727	739	744	756	778	801	823	--THEORETICAL HEATING COST + FURN+ HEAT PUMP \$ PER YEAR
+07	\$ 761	773	784	795	805	816	827	835	846	868	891	914	--THEORETICAL HEATING COST + FURN+ HEAT PUMP \$ PER YEAR
+08	\$ 827	828	880	880	891	902	914	924	935	947	964	987	--THEORETICAL HEATING COST + FURN+ HEAT PUMP \$ PER YEAR
+09	\$ 853	866	916	917	927	938	950	961	972	983	1004	1025	--THEORETICAL HEATING COST + FURN+ HEAT PUMP \$ PER YEAR
+10	\$ 1043	1055	1263	1263	1275	1286	1297	1303	1314	1331	1359	1382	BALANCE POINT 27 DEG.F.

ANNUAL AIR CONDITIONING COST WHEN COOLING LOAD IS SIZED TO MATCH COOLING CAPACITY OF HEAT PUMP.

ELEC. RATE \$/KWH	0.03 0.04 0.05 0.06 0.07 0.08 0.09 0.10 0.11 0.12	THEORETICAL AIR CONDITIONING COST
	60 80 100 120 140 160 180 200 220 240	

THE ABOVE ANNUAL HEATING AND COOLING OPERATING COSTS ARE THEORETICAL ESTIMATES ONLY AND ARE PROVIDED FOR A COMMON BASIS OF COMPARISON BETWEEN VARIOUS TYPES OF HEATING AND COOLING SYSTEMS. ACTUAL VALUES MAY VARY DEPENDING ON ACTUAL WEATHER CONDITIONS AND INDIVIDUAL USAGE PATTERN.

BARD MANUFACTURING COMPANY
DUAL FUEL ADD-ON HEAT PUMP GUIDE TO ENERGY COST SAVINGS

REGION 4
HEAT PUMP MODEL: COMPRESSOR SECTION BRS16/HPS16 (INDOOR-HPS16/43222)
COOLING CAPACITY AT -53 DEG.F ENTERING WATER TEMP.: 33°F BTUH - 14,720
HEATING CAPACITY AT -53 DEG.F ENTERING WATER TEMP.: 33°F BTUH - 23,720
FURNACE TYPE ELECTRIC FURNACE EFFICIENCY 100% AFUE

HEAT LOSS
BTUH \$/KWH

35,000

--- THEORETICAL ANNUAL HEATING COST ---
HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

.03	\$	197	530
.04	\$	270	705
.05	\$	333	885
.06	\$	400	1060
.07	\$	468	1241
.08	\$	536	1416
.09	\$	598	1590
.10	\$	660	1771
.12	\$	901	2127

BALANCE POINT -14 DEG.F.

40,000

--- THEORETICAL ANNUAL HEATING COST ---
HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

.03	\$	225	603
.04	\$	304	806
.05	\$	378	1010
.06	\$	451	1213
.07	\$	530	1418
.08	\$	603	1619
.09	\$	677	1822
.10	\$	756	2025
.12	\$	908	2431

BALANCE POINT -4 DEG.F.

50,000

--- THEORETICAL ANNUAL HEATING COST ---
HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

.03	\$	282	756
.04	\$	378	1110
.05	\$	473	1283
.06	\$	564	1517
.07	\$	660	1771
.08	\$	740	2025
.09	\$	846	2279
.10	\$	942	2533
.12	\$	1134	3041

BALANCE POINT 10 DEG.F.

60,000

--- THEORETICAL ANNUAL HEATING COST ---
HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

.03	\$	355	904
.04	\$	466	1213
.05	\$	586	1517
.06	\$	699	1822
.07	\$	818	2127
.08	\$	931	2431
.09	\$	1055	2736
.10	\$	1188	3041
.12	\$	1405	3650

BALANCE POINT 19 DEG.F.

70,000

--- THEORETICAL ANNUAL HEATING COST ---
HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

.03	\$	428	1060
.04	\$	541	1416
.05	\$	672	1771
.06	\$	806	2127
.07	\$	940	2431
.08	\$	1134	2838
.09	\$	1247	3193
.10	\$	1450	3549
.12	\$	1737	4280

BALANCE POINT 25 DEG.F.

ANNUAL AIR CONDITIONING COST WHEN COOLING LOAD IS SIZED TO MATCH COOLING CAPACITY OF HEAT PUMP.

\$.93 1.01 1.05 1.09 1.07 1.08 1.09 1.10 1.12

<--ELECTRIC RATE \$/KWH
<--THEORETICAL AIR CONDITIONING COST

THE ABOVE ANNUAL HEATING AND COOLING OPERATING COSTS ARE THEORETICAL ESTIMATES ONLY AND ARE PROVIDED FOR A COMMON BASIS OF COMPARISON BETWEEN VARIOUS TYPES OF HEATING AND COOLING SYSTEMS. ACTUAL VALUES MAY VARY DEPENDING ON ACTUAL WEATHER CONDITIONS AND INDIVIDUAL USAGE PATTERN.

BARD MANUFACTURING COMPANY
DUAL FUEL ADD-ON HEAT PUMP GUIDE TO ENERGY COST SAVINGS

REGION 6
HEAT PUMP MODEL: COMPRESSOR SECTION 30520/H010A1
COOLING CAPACITY AT 40 DEG.F. ENTERING WATER TEMP: 55°F
HEATING CAPACITY AT 21 DEG.F. ENTERING WATER TEMP: 55°F
FURNACE EFFICIENCY: 85%
FURNACE TYPE: FUEL OIL

HEAT LOSS BTUH	ELEC. kW/kWh	HEATING DEL. COST - \$/GALLON											
		1.00	1.10	1.20	1.30	1.40	1.50	1.60	1.70	1.80	2.00	2.20	2.40
--THEORETICAL HEATING COST + FURNACE ONLY													
35,000	\$ 671	T39	808	868	936	1004	1072	1139	1207	1342	1478	1613	
.03	\$ 203	203	203	203	203	203	203	203	203	203	203	203	
.04	\$ 270	270	270	270	270	270	270	270	270	270	270	270	
.05	\$ 332	332	332	332	332	332	332	332	332	332	332	332	
.06	\$ 400	400	400	400	400	400	400	400	400	400	400	400	
.07	\$ 468	468	468	468	468	468	468	468	468	468	468	468	
.08	\$ 530	530	530	530	530	530	530	530	530	530	530	530	
.09	\$ 598	598	598	598	598	598	598	598	598	598	598	598	
.10	\$ 665	665	665	665	665	665	665	665	665	665	665	665	
.12	\$ 795	795	795	795	795	795	795	795	795	795	795	795	
BALANCE POINT 14 DEG.F.													
40,000	\$ 767	840	919	998	1072	1151	1224	1303	1382	1534	1687	1839	
.03	\$ 231	231	231	231	231	231	231	231	231	231	231	231	
.04	\$ 304	304	304	304	304	304	304	304	304	304	304	304	
.05	\$ 378	378	378	378	378	378	378	378	378	378	378	378	
.06	\$ 451	451	451	451	451	451	451	451	451	451	451	451	
.07	\$ 530	530	530	530	530	530	530	530	530	530	530	530	
.08	\$ 603	603	603	603	603	603	603	603	603	603	603	603	
.09	\$ 677	677	677	677	677	677	677	677	677	677	677	677	
.10	\$ 750	750	750	750	750	750	750	750	750	750	750	750	
.12	\$ 902	902	902	902	902	902	902	902	902	902	902	902	
BALANCE POINT 4 DEG.F.													
50,000	\$ 959	1055	1151	1247	1342	1438	1534	1630	1726	1916	2110	2302	
.03	\$ 282	282	287	287	287	287	287	287	287	287	287	287	
.04	\$ 378	378	383	383	383	383	383	383	383	383	383	383	
.05	\$ 468	468	473	473	473	473	473	473	473	473	473	473	
.06	\$ 558	558	564	564	564	564	564	564	564	564	564	564	
.07	\$ 648	648	654	654	654	654	654	654	654	654	654	654	
.08	\$ 739	739	744	744	744	744	744	744	744	744	744	744	
.09	\$ 829	829	835	835	835	835	835	835	835	835	835	835	
.10	\$ 919	919	925	925	925	925	925	925	925	925	925	925	
.12	\$ 1105	1105	1111	1111	1111	1111	1111	1111	1111	1111	1111	1111	
BALANCE POINT 10 DEG.F.													
60,000	\$ 1151	1263	1382	1495	1613	1725	1839	1957	2070	2302	2533	2764	
.03	\$ 361	365	378	383	383	383	383	383	383	383	383	383	
.04	\$ 462	473	479	485	485	490	490	490	490	490	490	490	
.05	\$ 569	575	581	586	592	592	598	598	598	598	598	598	
.06	\$ 671	677	682	688	694	694	694	694	694	694	694	694	
.07	\$ 778	784	789	795	801	801	806	812	818	829	835	846	
.08	\$ 880	885	891	897	902	902	908	914	919	925	936	947	
.09	\$ 987	993	998	1004	1010	1010	1015	1021	1026	1032	1043	1055	
.10	\$ 1089	1094	1100	1105	1111	1111	1117	1121	1122	1122	1145	1158	
.12	\$ 1303	1309	1314	1320	1326	1326	1331	1337	1342	1348	1359	1371	
BALANCE POINT 19 DEG.F.													
70,000	\$ 1342	1478	1613	1743	1878	2014	2149	2285	2420	2685	2956	3227	
.03	\$ 457	462	473	485	496	507	519	530	541	554	566	589	
.04	\$ 575	581	587	593	603	615	626	637	648	660	682	705	
.05	\$ 688	694	705	716	727	739	750	761	773	795	818	840	
.06	\$ 806	812	823	835	846	857	868	880	891	914	936	959	
.07	\$ 919	925	936	947	959	970	981	993	1003	1026	1049	1072	
.08	\$ 1038	1043	1055	1066	1077	1089	1100	1111	1122	1145	1168	1190	
.09	\$ 1151	1156	1168	1179	1190	1201	1213	1224	1235	1258	1280	1303	
.10	\$ 1265	1270	1280	1291	1309	1320	1331	1342	1354	1376	1399	1421	
.12	\$ 1500	1506	1517	1529	1540	1551	1563	1574	1585	1608	1630	1653	
BALANCE POINT 25 DEG.F.													

ANNUAL AIR CONDITIONING COST WHEN COOLING LOAD IS SIZED TO MATCH COOLING CAPACITY OF HEAT PUMP.

\$.03 105 105 105 107 108 109 110 112

--ELECTRIC RATE \$/kWh

\$.03 101 126 141 176 202 221 252 303

--THEORETICAL AIR CONDITIONING COST

THE ABOVE ANNUAL HEATING AND COOLING OPERATING COSTS ARE THEORETICAL ESTIMATES ONLY AND ARE PROVIDED FOR A COMMON BASIS OF COMPARISON BETWEEN VARIOUS TYPES OF HEATING AND COOLING SYSTEMS. ACTUAL VALUES MAY VARY DEPENDING ON ACTUAL WEATHER CONDITIONS AND INDIVIDUAL USAGE PATTERN.

BARD MANUFACTURING COMPANY

DUAL FUEL ADD-ON HEAT PUMP GUIDE TO ENERGY COST SAVINGS

REGION 4
 HEAT PUMP MODEL: COMPRESSOR SECTION BPS182W052A8 INDOOR - H330W022A8
 COOLING CAPACITY AT -23 DEG.F ENTERING WATER TEMP AT - 3510°F STDN - 144°F EDP
 HEATING CAPACITY AT -23 DEG.F ENTERING WATER TEMP AT - 3510°F STDN - 144°F EDP
 FURNACE TYPE PROBESSE-D4S FURNACE EFFICIENCY - 82.00% AFUE

HEAT LOSS BTUH	ELEC COST \$/KWH	PROPANE GAS COST - \$/GALLON											
		.60	.65	.70	.75	.80	.85	.90	.95	1.00	1.10	1.20	1.30
35,000	\$ 615	665	716	767	818	868	919	970	1021	1122	1230	1230	--THEORETICAL HEATING COST + FURNACE ONLY
	+.03	\$ 197	203	203	203	203	203	203	203	203	203	203	203
	+.04	\$ 265	270	270	270	270	270	270	270	270	270	270	270
	+.05	\$ 327	332	332	332	332	332	332	332	332	332	332	332
	+.06	\$ 394	400	400	400	400	400	400	400	400	400	400	400
	+.07	\$ 462	468	468	468	468	468	468	468	468	468	468	468
	+.08	\$ 530	536	536	536	536	536	536	536	536	536	536	536
	+.09	\$ 599	598	598	598	598	598	598	598	598	598	598	598
	+.10	\$ 665	665	665	665	665	665	665	665	665	665	665	665
	+.12	\$ 789	795	795	795	795	795	795	795	795	795	795	795
40,000	\$ 699	756	818	874	936	993	1049	1111	1168	1286	1405	1405	--THEORETICAL HEATING COST + FURNACE ONLY
	+.03	\$ 231	231	231	231	231	231	231	231	231	231	231	231
	+.04	\$ 304	304	304	304	304	304	304	304	304	304	304	304
	+.05	\$ 378	378	378	378	378	378	378	378	378	378	378	378
	+.06	\$ 451	451	451	451	451	451	451	451	451	451	451	451
	+.07	\$ 530	530	530	530	530	530	530	530	530	530	530	530
	+.08	\$ 603	603	603	603	603	603	603	603	603	603	603	603
	+.09	\$ 677	677	677	677	677	677	677	677	677	677	677	677
	+.10	\$ 750	750	750	750	750	750	750	750	750	750	750	750
	+.12	\$ 902	902	902	902	902	902	902	902	902	902	902	902
50,000	\$ 974	947	1021	1094	1168	1241	1314	1386	1461	1608	1754	1754	--THEORETICAL HEATING COST + FURNACE ONLY
	+.03	\$ 282	282	282	282	287	287	287	287	287	293	293	293
	+.04	\$ 378	378	378	378	383	383	383	383	383	389	389	389
	+.05	\$ 466	466	466	466	473	473	473	473	473	479	479	479
	+.06	\$ 558	558	558	558	564	564	564	564	564	569	569	569
	+.07	\$ 648	648	648	648	654	654	654	654	654	660	660	660
	+.08	\$ 739	739	739	739	744	744	744	744	744	750	750	750
	+.09	\$ 829	829	829	829	835	835	835	835	835	840	840	840
	+.10	\$ 919	919	919	919	925	925	925	925	925	931	931	931
	+.12	\$ 1105	1105	1105	1105	1111	1111	1111	1111	1111	1117	1117	1117
60,000	\$ 1049	1139	1230	1314	1405	1489	1579	1664	1754	1929	2104	2104	--THEORETICAL HEATING COST + FURNACE ONLY
	+.03	\$ 361	361	366	366	372	378	378	383	389	396	400	400
	+.04	\$ 462	462	468	468	473	479	479	485	490	496	502	502
	+.05	\$ 569	569	575	575	581	588	588	592	598	603	609	609
	+.06	\$ 671	671	677	677	682	688	688	694	699	705	710	710
	+.07	\$ 778	778	784	784	789	795	795	801	806	812	818	818
	+.08	\$ 880	880	885	885	891	897	897	902	908	914	919	919
	+.09	\$ 987	987	993	993	998	1004	1004	1004	1010	1016	1021	1026
	+.10	\$ 1089	1089	1094	1094	1100	1105	1105	1111	1117	1122	1128	1128
	+.12	\$ 1303	1303	1309	1309	1314	1320	1320	1326	1331	1337	1342	1342
70,000	\$ 1230	1331	1433	1534	1636	1737	1845	1946	2048	2251	2460	2460	--THEORETICAL HEATING COST + FURNACE ONLY
	+.03	\$ 445	451	462	468	479	485	496	504	513	530	547	547
	+.04	\$ 564	569	581	588	598	603	615	620	631	648	665	665
	+.05	\$ 677	682	694	699	710	716	727	733	744	761	778	778
	+.06	\$ 795	801	812	818	829	835	846	852	863	880	897	897
	+.07	\$ 908	914	925	931	942	947	954	964	976	993	1010	1010
	+.08	\$ 1026	1032	1043	1049	1060	1066	1077	1083	1094	1111	1128	1128
	+.09	\$ 1156	1162	1173	1179	1190	1196	1207	1224	1241	1241		
	+.10	\$ 1263	1263	1275	1280	1292	1297	1309	1314	1326	1342	1359	1359
	+.12	\$ 1489	1495	1506	1512	1523	1529	1540	1546	1557	1574	1591	1591

ANNUAL AIR CONDITIONING COST WHEN COOLING LOAD IS SIZED TO MATCH COOLING CAPACITY OF HEAT PUMP.

++ELECTRIC RATE \$/KWH ++THEORETICAL AIR CONDITIONING COST
 + .75 101 126 151 176 202 227 252 303

THE ABOVE ANNUAL HEATING AND COOLING OPERATING COSTS ARE THEORETICAL ESTIMATES ONLY AND ARE PROVIDED FOR A COMMON BASIS OF COMPARISON BETWEEN VARIOUS TYPES OF HEATING AND COOLING SYSTEMS. ACTUAL VALUES MAY VARY DEPENDING ON ACTUAL WEATHER CONDITIONS AND INDIVIDUAL USAGE PATTERN.

BARD MANUFACTURING COMPANY
DUAL FUEL ADD-ON HEAT PUMP GUIDE TO ENERGY COST SAVINGS

REGION 4
HEAT PUMP MODEL: OUTDOOR 25HP02 INDOOR H240S1
RATED COOLING CAP.: BTUH 785 T=80°F SEER T=81
ARI RATED HEATING CAP.: BTUH 147 I=75°F COP 1.7 E=2.10 A. HSPF 6.15 MIN. OMR REG IV
FURNACE TYPE ELECTRIC E=1.90 A. SOURCE EFFICIENCY 100% A.O.D. & EUE

HEAT LOSS
BTUH

ELEC.
COST
\$/KWH

25,000

--- THEORETICAL ANNUAL HEATING COST ---
HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

+03	\$	208	378
+04	\$	210	402
+05	\$	338	631
+06	\$	406	796
+07	\$	473	885
+08	\$	567	1010
+09	\$	615	1139
+10	\$	682	1263
+12	\$	814	1517

BALANCE POINT 19 DEG.F.

30,000

--- THEORETICAL ANNUAL HEATING COST ---
HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

-03	\$	248	451
-04	\$	321	603
-05	\$	406	755
-06	\$	470	908
-07	\$	575	1060
-08	\$	654	1213
-09	\$	719	1365
-10	\$	818	1517
-12	\$	981	1822

BALANCE POINT 24 DEG.F.

35,000

--- THEORETICAL ANNUAL HEATING COST ---
HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

+03	\$	293	530
+04	\$	389	705
+05	\$	490	885
+06	\$	581	1060
+07	\$	686	1241
+08	\$	776	1416
+09	\$	874	1596
+10	\$	970	1771
+12	\$	1168	2127

BALANCE POINT 28 DEG.F.

40,000

--- THEORETICAL ANNUAL HEATING COST ---
HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

+03	\$	344	603
+04	\$	451	806
+05	\$	569	1010
+06	\$	682	1213
+07	\$	795	1416
+08	\$	908	1619
+09	\$	1020	1822
+10	\$	1134	2025
+12	\$	1359	2431

BALANCE POINT 31 DEG.F.

50,000

--- THEORETICAL ANNUAL HEATING COST ---
HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

+03	\$	451	756
+04	\$	603	1010
+05	\$	756	1263
+06	\$	908	1517
+07	\$	1060	1771
+08	\$	1213	2025
+09	\$	1359	2279
+10	\$	1512	2533
+12	\$	1816	3041

BALANCE POINT 36 DEG.F.

ANNUAL AIR CONDITIONING COST WHEN COOLING LOAD IS SIZED TO MATCH COOLING CAPACITY OF HEAT PUMP.

* -03 -04 -05 -06 -07 -08 -09 -10 -12
* = \$1.94 1.94 1.94 1.94 1.94 1.94 1.94 1.94 1.94

--ELECTRIC RATE \$/KWH
--THEORETICAL AIR CONDITIONING COST

THE ABOVE ANNUAL HEATING AND COOLING OPERATING COSTS ARE THEORETICAL ESTIMATES ONLY AND ARE PROVIDED FOR A COMMON BASIS OF COMPARISON BETWEEN VARIOUS TYPES OF HEATING AND COOLING SYSTEMS. ACTUAL VALUES MAY VARY DEPENDING ON ACTUAL WEATHER CONDITIONS AND INDIVIDUAL USAGE PATTERN.

BARD MANUFACTURING COMPANY
DUAL FUEL ADD-ON HEAT PUMP GUIDE TO ENERGY COST SAVINGS

REGION 3
HEAT PUMP MODEL: OUTDOOR_B24922 INDOOR_B24951
ART RATED COOLING CAP.: BTUH 173 74000 SEER 7.00 COP 1.73 2x10+ MSPE 6.25 MIN.DHR REG IV
ART RATED HEATING CAP.: BTUH 147 14200 COP(17) 1.15 2x10+ MSPE 6.25 MIN.DHR REG IV
BTUH 117 14200 COP(17) 1.15 2x10+ MSPE 6.25 MIN.DHR REG IV
FURNACE TYPE BALANCE GAS FURNACE EFFICIENCY 95.00% AFUE

HEAT LOSS BTUH	ELEC. COST \$/KWH	NATURAL GAS COST - \$/THERM											
		.35	.40	.44	.50	.55	.60	.65	.70	.75	.80		
25,000	\$ 231	265	299	332	361	394	428	462	496	530	598	665	
	+.03	203	208	214	220	225	231	236	242	259	270	282	
	+.04	253	259	265	270	276	282	287	293	299	310	321	
	+.05	304	310	316	321	327	332	338	344	349	351	352	
	+.06	355	361	366	372	378	383	389	394	400	411	423	
	+.07	406	411	417	423	428	434	440	445	451	462	473	
	+.08	457	463	468	473	479	485	490	496	502	507	514	
	+.09	508	513	519	524	530	536	541	547	552	558	564	
	+.10	559	564	569	575	581	586	592	598	603	609	615	
	+.12	610	615	621	627	633	638	644	649	655	661	667	
	\$ 665	671	677	682	688	694	699	705	710	722	733	744	
30,000	\$ 276	315	355	394	434	479	519	558	598	637	716	795	
	+.03	236	248	259	270	282	293	304	315	327	338	361	383
	+.04	293	304	315	327	338	349	361	372	383	394	417	440
	+.05	344	355	366	378	389	400	411	423	434	445	468	490
	+.06	394	406	417	428	440	451	462	473	485	496	519	541
	+.07	445	456	468	473	485	496	507	519	530	541	552	568
	+.08	496	507	518	524	536	547	558	569	581	592	603	626
	+.09	547	558	569	581	592	603	615	626	637	648	660	682
	+.10	598	609	620	631	643	654	665	677	688	699	710	733
	+.12	650	662	673	684	695	706	717	728	739	750	761	783
35,000	\$ 321	372	417	462	507	558	601	648	694	744	835	931	
	+.03	282	304	321	344	361	383	400	423	440	462	502	561
	+.04	332	355	372	394	411	424	436	451	469	493	552	592
	+.05	378	400	417	440	457	479	496	510	536	558	598	617
	+.06	428	451	468	490	507	520	541	560	586	609	648	686
	+.07	473	496	513	536	552	575	594	615	631	654	694	733
	+.08	524	547	564	586	603	624	643	664	682	705	744	784
	+.09	575	598	615	637	654	677	698	716	733	756	795	835
	+.10	626	649	666	682	699	722	739	756	778	801	840	880
	+.12	677	704	721	738	751	763	780	797	814	842	881	921
40,000	\$ 372	423	479	530	581	637	688	744	794	852	959	1060	
	+.03	321	344	366	389	411	434	457	479	502	524	569	615
	+.04	378	400	423	445	466	490	513	536	558	581	626	671
	+.05	428	451	473	496	517	538	560	582	604	621	677	722
	+.07	485	507	530	552	575	598	620	643	665	688	733	778
	+.08	541	564	586	609	631	654	677	699	722	744	789	815
	+.09	592	615	637	660	682	704	727	749	771	795	840	885
	+.10	648	671	694	716	739	761	784	806	829	852	897	942
	+.12	705	727	750	773	795	818	840	863	885	908	953	998
50,000	\$ 462	530	598	665	727	795	863	931	998	1060	1196	1331	
	+.03	411	451	490	530	575	615	656	696	731	773	852	931
	+.04	452	496	536	575	620	660	699	739	778	818	897	976
	+.05	507	547	586	626	671	710	750	789	824	866	947	1026
	+.06	552	592	631	671	716	756	795	835	874	914	993	1072
	+.07	598	637	677	716	761	801	840	880	919	959	1038	1117
	+.08	643	682	722	761	806	846	885	925	964	1004	1083	1164
	+.09	688	727	767	806	852	891	931	970	1010	1049	1128	1207
	+.10	733	773	812	852	897	936	976	1015	1054	1094	1173	1252
	+.12	823	863	902	942	987	1026	1066	1105	1145	1184	1269	1342

ANNUAL AIR CONDITIONING COST WHEN COOLING LOAD IS SIZED TO MATCH COOLING CAPACITY OF HEAT PUMP.

ELECTRIC RATE \$/KWH THEORETICAL AIR CONDITIONING COST
-.03 -.04 -.05 -.06 -.07 -.08 -.09 -.10 -.11 -.12

THE ABOVE ANNUAL HEATING AND COOLING OPERATING COSTS ARE THEORETICAL ESTIMATES ONLY AND ARE PROVIDED FOR A COMMON BASIS OF COMPARISON BETWEEN VARIOUS TYPES OF HEATING AND COOLING SYSTEMS. ACTUAL VALUES MAY VARY DEPENDING ON ACTUAL WEATHER CONDITIONS AND INDIVIDUAL USAGE PATTERN.

BARD MANUFACTURING COMPANY
DUAL FUEL ADD-ON HEAT PUMP GUIDE TO ENERGY COST SAVINGS

REGION 1
HEAT PUMP MODEL: OUTDOOR 24H802 INDOOR H24051
ARTI RATED COOLING CAP. ATUH 147 1-14200 COP 1.4-1.2420 MSPE 8.4-8.45 MIN.DHR 0.65 IV
ARTI RATED HEATING CAP. ATUH 117 1-14200 COP 1.1-1.25 MIN.DHR 0.65 IV
FURNACE TYPE FUEL OIL

HEAT LOSS BTUH	ELECTRICITY RATE \$/KWH	HEATING OIL COST - \$/GALLON											
		1.00	1.10	1.20	1.30	1.40	1.50	1.60	1.70	1.80	2.00	2.20	2.40
25,000	\$.479	524	575	620	671	716	767	812	863	959	1055	1151	--THEORETICAL HEATING COST + FURNACE ONLY
	+.03	521	574	620	675	725	771	821	871	968	1065	1161	THEORETICAL HEATING COST + FURN.+ HEAT PUMP \$ PER YEAR
	+.04	526	586	622	671	727	773	823	873	970	1060	1156	
	+.05	532	593	638	684	734	784	834	884	981	1071	1168	
	+.06	538	596	640	686	736	786	836	886	984	1074	1170	
	+.07	545	647	682	728	773	823	873	923	1020	1117	1214	
	+.08	553	513	513	514	524	524	530	530	538	541	547	552
	+.09	555	515	515	515	515	515	515	515	515	515	515	515
	+.10	561	631	637	643	643	643	648	648	654	660	665	671
	+.12	575	756	761	767	773	773	778	784	788	794	801	BALANCE POINT 19 DEG.F.
30,000	\$.575	631	688	744	806	863	919	975	1032	1151	1263	1382	--THEORETICAL HEATING COST + FURNACE ONLY
	+.03	565	670	726	782	827	893	949	1004	1151	1263	1382	THEORETICAL HEATING COST + FURN.+ HEAT PUMP \$ PER YEAR
	+.04	593	638	644	696	752	818	874	930	1082	1151	1263	
	+.05	600	406	411	417	423	429	434	440	507	519	530	541
	+.06	606	473	476	492	496	502	507	519	580	598	609	620
	+.07	536	561	547	552	558	564	569	575	586	598	609	620
	+.08	563	609	615	620	626	631	637	643	654	665	677	688
	+.09	671	677	682	688	694	699	705	710	722	732	744	755
	+.10	733	739	744	750	756	761	767	773	784	795	806	818
	+.12	568	874	980	885	891	902	908	919	931	942	953	BALANCE POINT 24 DEG.F.
35,000	\$.671	739	806	868	936	1004	1072	1139	1207	1342	1478	1613	--THEORETICAL HEATING COST + FURNACE ONLY
	+.03	521	327	336	349	361	369	378	389	400	417	440	457
	+.04	599	600	411	423	434	440	451	462	473	490	513	530
	+.05	669	473	485	496	507	513	524	536	547	564	586	603
	+.06	541	541	558	560	561	568	569	579	580	597	600	617
	+.07	615	620	631	643	654	660	671	682	694	710	725	750
	+.08	688	694	705	716	727	739	744	756	767	784	808	823
	+.09	761	767	778	789	801	806	816	829	840	857	868	887
	+.10	835	840	852	863	874	880	891	902	912	924	935	970
	+.12	981	987	998	1010	1021	1026	1038	1044	1060	1077	1100	1117
40,000	\$.767	840	919	998	1072	1151	1224	1303	1382	1534	1687	1839	--THEORETICAL HEATING COST + FURNACE ONLY
	+.03	383	400	411	426	445	457	473	490	502	530	564	592
	+.04	487	473	489	502	519	530	547	564	582	603	637	663
	+.05	536	532	564	581	598	609	626	643	654	682	716	744
	+.06	615	631	643	660	677	683	705	722	733	761	795	823
	+.07	694	710	722	739	756	767	784	801	812	840	874	907
	+.08	773	789	801	818	833	848	863	880	891	914	953	981
	+.09	852	868	880	897	914	925	942	959	970	998	1032	1060
	+.10	925	942	953	970	987	998	1015	1032	1043	1072	1105	1134
	+.12	1081	1100	1111	1128	1144	1156	1173	1190	1201	1230	1263	1292
50,000	\$.959	1055	1151	1241	1342	1438	1534	1630	1726	1916	2110	2302	--THEORETICAL HEATING COST + FURNACE ONLY
	+.03	530	558	586	615	643	665	694	722	750	800	863	919
	+.04	613	643	671	699	727	750	778	806	835	891	947	1004
	+.05	694	722	750	778	804	829	857	885	914	970	1024	1083
	+.06	778	804	835	863	891	914	942	970	1055	1111	1166	1252
	+.07	863	891	919	947	976	996	1026	1055	1083	1139	1198	1252
	+.08	942	976	1004	1032	1060	1083	1111	1139	1169	1224	1280	1337
	+.09	1032	1060	1089	1117	1145	1168	1196	1224	1252	1309	1365	1421
	+.10	1115	1145	1173	1201	1230	1252	1280	1309	1337	1393	1450	1506
	+.12	1286	1314	1342	1371	1399	1421	1450	1478	1506	1563	1619	1675

ANNUAL AIR CONDITIONING COST WHEN COOLING LOAD IS SIZED TO MATCH COOLING CAPACITY OF HEAT PUMP

ANNUAL AIR CONDITIONING COST WHEN COOLING LOAD IS SIZED TO MATCH COOLING CAPACITY OF HEAT PUMP	--ELECTRIC RATE \$/KWH
\$.03 .04 .05 .06 .07 .08 .09 .10 .11 .12	--THEORETICAL AIR CONDITIONING COST
\$.91 .94 .116 .146 .166 .189 .213 .237 .284	

THE ABOVE ANNUAL HEATING AND COOLING OPERATING COSTS ARE THEORETICAL ESTIMATES ONLY AND ARE PROVIDED FOR A COMMON BASIS OF COMPARISON BETWEEN VARIOUS TYPES OF HEATING AND COOLING SYSTEMS. ACTUAL VALUES MAY VERY DEPENDING ON ACTUAL WEATHER CONDITIONS AND INDIVIDUAL USAGE PATTERN.

BARD MANUFACTURING COMPANY
DUAL FUEL ADD-ON HEAT PUMP GUIDE TO ENERGY COST SAVINGS

REGION
HEAT PUMP MODEL: OUTDOOR 300EES INDOOR_H340_08_0252L
ARI RATED COOLING CAP.: BTUH 147 22000 COP147 12.73 ARI RATED HEATING CAP.: BTUH 117 29200 COP117 10.50 MSPE 6.52 MIN.DHR REG IV
FURNACE TYPE ELECTRIC FURNACE EFFICIENCY 100.00% AFUE

HEAT LOSS
BTUH

ELEC.
COST
\$/KWH

30,000

--- THEORETICAL ANNUAL HEATING COST ---
HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

.03	\$	242	451
.04	\$	321	603
.05	\$	394	756
.06	\$	473	908
.07	\$	558	1060
.08	\$	637	1213
.09	\$	716	1365
.10	\$	795	1517
.12	\$	959	1822

BALANCE POINT 14 DEG.F.

35,000

--- THEORETICAL ANNUAL HEATING COST ---
HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

.03	\$	276	530
.04	\$	368	705
.05	\$	462	885
.06	\$	552	1060
.07	\$	648	1241
.08	\$	739	1416
.09	\$	829	1596
.10	\$	919	1771
.12	\$	1105	2127

BALANCE POINT 18 DEG.F.

40,000

--- THEORETICAL ANNUAL HEATING COST ---
HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

.03	\$	315	603
.04	\$	423	806
.05	\$	524	1010
.06	\$	627	1213
.07	\$	729	1416
.08	\$	826	1619
.09	\$	923	1822
.10	\$	1020	2025
.12	\$	1269	2431

BALANCE POINT 22 DEG.F.

50,000

--- THEORETICAL ANNUAL HEATING COST ---
HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

.03	\$	406	756
.04	\$	541	1010
.05	\$	677	1263
.06	\$	812	1517
.07	\$	947	1771
.08	\$	1083	2025
.09	\$	1224	2279
.10	\$	1356	2533
.12	\$	1625	3041

BALANCE POINT 26 DEG.F.

60,000

--- THEORETICAL ANNUAL HEATING COST ---
HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

.03	\$	507	908
.04	\$	682	1213
.05	\$	866	1517
.06	\$	1050	1822
.07	\$	1190	2127
.08	\$	1354	2431
.09	\$	1523	2736
.10	\$	1698	3041
.12	\$	2036	3690

BALANCE POINT 30 DEG.F.

ANNUAL AIR CONDITIONING COST WHEN COOLING LOAD IS SIZED TO MATCH COOLING CAPACITY OF HEAT PUMP.

\$.03 .04 .05 .06 .07 .08 .09 .10 .12

--- ELECTRIC RATE \$/KWH
--- THEORETICAL AIR CONDITIONING COST

THE ABOVE ANNUAL HEATING AND COOLING OPERATING COSTS ARE THEORETICAL ESTIMATES ONLY AND ARE PROVIDED FOR A COMMON BASIS OF COMPARISON BETWEEN VARIOUS TYPES OF HEATING AND COOLING SYSTEMS. ACTUAL VALUES MAY VARY DEPENDING ON ACTUAL WEATHER CONDITIONS AND INDIVIDUAL USAGE PATTERN.

BARD MANUFACTURING COMPANY

DUAL FUEL ADD-ON HEAT PUMP GUIDE TO ENERGY COST SAVINGS

REGION 3
 HEAT PUMP MODEL: OUTDOOR 300E05 INDOOR M2AR203A0L
 ARE RATED COOLING CAP.: BTUH 1951 - 62300 BTU SEER 0.870
 ARE RATED HEATING CAP.: BTUH 1671 - 42000 BTU COP(17) 2.72+ HSPF 0.850 MIN.DHR REG TV
 FURNACE TYPE NATURAL GAS FURNACE EFFICIENCY 0.85x0.93=SEUE

HEAT LOSS BTUH	ELEC. COST \$/KWH	NATURAL GAS COST - \$/THERM										
		+35	+40	+45	+50	+55	+60	+65	+70	+75	+80	
30,000	\$ 276	315	355	394	434	474	514	554	594	634	716	195
	+\$03	236	236	242	248	253	259	259	265	270	276	282
	+\$04	304	304	310	315	321	327	327	332	334	344	361
	+\$05	372	372	378	383	389	394	394	400	406	411	417
	+\$06	434	434	440	445	451	457	457	462	468	473	479
	+\$07	502	502	507	513	519	524	524	530	536	541	547
	+\$08	569	569	575	581	586	592	592	598	603	609	615
	+\$09	637	637	643	648	654	660	660	665	671	677	682
	+\$10	705	705	710	716	722	727	727	733	739	744	750
	+\$12	840	840	846	852	857	863	863	868	874	880	885
												BALANCE POINT 14 DEG.F.
35,000	\$ 321	372	417	462	507	558	603	648	694	744	835	931
	+\$03	270	276	287	293	304	310	321	332	338	349	366
	+\$04	344	349	361	366	378	383	394	406	411	423	440
	+\$05	411	417	428	434	445	451	462	473	479	490	507
	+\$06	479	485	496	502	513	519	524	530	536	541	558
	+\$07	552	558	569	575	586	592	592	603	615	620	631
	+\$08	620	626	637	643	654	660	671	682	693	704	716
	+\$09	694	699	710	716	727	733	744	756	761	773	789
	+\$10	761	767	778	784	795	801	812	823	829	840	857
	+\$12	902	908	919	925	936	942	953	964	970	981	998
												BALANCE POINT 18 DEG.F.
40,000	\$ 372	423	479	530	581	637	688	744	795	842	959	1060
	+\$03	310	327	338	355	372	383	400	417	428	446	473
	+\$04	383	400	411	428	443	457	473	490	505	524	557
	+\$05	451	468	479	496	513	524	541	558	566	585	613
	+\$06	519	536	547	564	581	592	603	626	637	654	672
	+\$07	586	603	615	631	648	660	677	694	705	722	739
	+\$08	654	671	682	699	716	727	744	761	773	784	802
	+\$09	722	739	750	767	784	795	812	829	840	857	885
	+\$10	789	806	818	835	852	863	880	897	904	923	953
	+\$12	931	947	959	976	993	1004	1021	1038	1049	1066	1094
												BALANCE POINT 22 DEG.F.
50,000	\$ 662	630	598	665	727	795	863	931	998	1060	1196	1331
	+\$03	394	423	451	479	507	536	564	592	620	648	705
	+\$04	462	490	519	547	575	603	631	660	688	716	773
	+\$05	530	558	586	615	643	671	699	727	756	784	840
	+\$06	592	620	648	677	705	733	761	789	818	846	902
	+\$07	660	688	716	744	773	801	829	857	885	914	970
	+\$08	727	756	784	812	840	868	897	925	953	981	1038
	+\$09	795	823	852	880	908	936	966	993	1021	1049	1105
	+\$10	851	885	914	942	970	998	1026	1055	1083	1111	1168
	+\$12	993	1021	1049	1077	1105	1134	1162	1190	1218	1247	1303
												BALANCE POINT 28 DEG.F.
60,000	\$ 558	637	716	795	874	959	1038	1117	1196	1275	1438	1596
	+\$03	490	541	586	637	682	727	778	823	874	919	1025
	+\$04	567	608	643	694	739	784	835	880	931	976	1072
	+\$05	638	648	694	744	789	835	885	931	981	1026	1122
	+\$06	694	704	752	801	846	891	943	987	1038	1083	1179
	+\$07	761	759	801	852	897	943	993	1038	1089	1134	1230
	+\$08	812	853	908	959	1004	1049	1100	1145	1196	1241	1337
	+\$09	868	919	964	1014	1060	1105	1156	1201	1253	1297	1393
	+\$10	926	1026	1072	1122	1168	1213	1263	1309	1359	1405	1500
	+\$12											BALANCE POINT 33 DEG.F.

ANNUAL AIR CONDITIONING COST WHEN COOLING LOAD IS SIZED TO MATCH COOLING CAPACITY OF HEAT PUMP

\$ +03	\$04	\$05	\$06	\$07	\$08	\$09	\$10	\$11	\$12	--> ELECTRIC RATE \$/KWH
\$ 85	\$13	141	170	198	226	253	283	310	340	--> THEORETICAL AIR CONDITIONING COST

THE ABOVE ANNUAL HEATING AND COOLING OPERATING COSTS ARE THEORETICAL ESTIMATES ONLY AND ARE PROVIDED FOR A COMMON BASIS OF COMPARISON BETWEEN VARIOUS TYPES OF HEATING AND COOLING SYSTEMS. ACTUAL VALUES MAY VARY DEPENDING ON ACTUAL WEATHER CONDITIONS AND INDIVIDUAL USAGE PATTERN.

BARD MANUFACTURING COMPANY

DUAL FUEL ADD-ON HEAT PUMP GUIDE TO ENERGY COST SAVINGS

REGION 4
HEAT PUMP MODEL# OUTDOOR 30HPS3 INDOOR_H2004H340LBTUH RATED COOLING CAP. 30HPS3 BTUH 743 1-2000 COP14.1 2.754 HSPP_6.250 MIN. OHR REG IV
BTUH RATED HEATING CAP. 30HPS3 BTUH 117 1-2020 COP17 1.72 FURNACE EFFICIENCY .85±0.03 LSEUE

HEAT LOSS BTUH	ELEC. COST \$/KWH	HEATING OIL COST - \$/GALLON											
		1.00	1.10	1.20	1.30	1.40	1.50	1.60	1.70	1.80	2.00	2.20	2.40
30,000	\$ 575	631	688	744	804	863	919	976	1032	1151	1263	1382	--THEORETICAL HEATING COST + FURNACE ONLY
	+.03	242	248	248	253	253	253	259	259	265	270	270	276
	+.04	315	321	321	327	327	327	332	332	338	344	344	349
	+.05	389	394	394	400	400	400	406	406	411	417	417	423
	+.06	462	468	468	473	473	473	479	479	485	490	490	496
	+.07	536	541	541	547	547	547	552	552	558	564	564	569
	+.08	609	615	615	620	620	620	626	626	631	637	637	643
	+.09	683	694	694	699	699	699	705	705	710	716	716	722
	+.10	756	767	767	773	773	773	778	778	784	789	789	795
	+.12	908	914	914	919	919	919	925	925	931	936	936	942
													BALANCE POINT 14 DEG.F.
35,000	\$ 671	739	805	882	936	1004	1072	1139	1207	1342	1478	1613	--THEORETICAL HEATING COST + FURNACE ONLY
	+.03	293	293	299	304	310	310	315	321	327	332	344	349
	+.04	372	372	378	383	389	389	394	400	406	411	423	428
	+.05	452	457	462	468	473	473	479	485	490	496	507	513
	+.06	536	536	541	547	552	552	558	564	569	575	586	592
	+.07	620	620	626	631	637	637	643	648	654	660	671	677
	+.08	699	699	705	710	716	716	722	727	733	739	750	756
	+.09	784	784	789	795	801	801	806	812	818	823	835	840
	+.10	868	868	874	880	884	885	891	897	902	908	919	925
	+.12	1032	1032	1038	1043	1049	1049	1055	1060	1066	1072	1083	1099
													BALANCE POINT 18 DEG.F.
40,000	\$ 767	840	919	998	1072	1151	1224	1303	1382	1534	1687	1839	--THEORETICAL HEATING COST + FURNACE ONLY
	+.03	338	344	349	361	366	372	378	383	394	400	417	434
	+.04	423	428	434	443	451	457	462	468	479	480	502	519
	+.05	513	513	524	526	531	541	547	552	558	569	581	592
	+.06	603	609	615	620	631	637	643	648	653	663	671	682
	+.07	694	694	705	714	722	727	733	739	750	761	773	789
	+.08	784	789	795	806	812	818	823	829	840	852	863	880
	+.09	874	880	885	897	903	908	914	919	931	942	953	970
	+.10	964	970	976	987	993	998	1004	1010	1031	1032	1043	1060
	+.12	1139	1145	1151	1162	1168	1173	1179	1184	1196	1207	1218	1235
													BALANCE POINT 22 DEG.F.
50,000	\$ 959	1055	1151	1247	1342	1438	1534	1630	1726	1918	2110	2302	--THEORETICAL HEATING COST + FURNACE ONLY
	+.03	451	462	479	496	507	524	536	552	564	578	626	654
	+.04	547	558	575	592	603	620	631	648	660	674	729	760
	+.05	648	660	677	694	705	722	732	740	751	765	823	852
	+.06	750	761	778	795	806	823	833	852	863	877	929	959
	+.07	852	863	880	897	908	925	936	953	964	978	1026	1053
	+.08	953	964	981	998	1010	1026	1038	1055	1056	1106	1128	1146
	+.09	1055	1066	1083	1100	1111	1128	1139	1156	1165	1201	1220	1259
	+.10	1156	1168	1184	1201	1213	1230	1241	1258	1269	1303	1331	1359
	+.12	1354	1365	1382	1394	1410	1427	1438	1455	1467	1500	1529	1557
													BALANCE POINT 26 DEG.F.
60,000	\$ 1151	1263	1382	1495	1613	1726	1839	1957	2070	2302	2533	2764	--THEORETICAL HEATING COST + FURNACE ONLY
	+.03	561	603	631	654	682	705	733	756	784	835	885	936
	+.04	688	710	739	761	789	812	840	863	891	942	993	1043
	+.05	795	818	846	868	897	919	947	970	998	1049	1100	1151
	+.06	902	925	953	976	1004	1026	1055	1077	1105	1156	1207	1258
	+.07	1015	1038	1066	1089	1117	1139	1168	1190	1218	1269	1320	1371
	+.08	1230	1252	1280	1303	1331	1354	1382	1405	1433	1484	1534	1585
	+.09	1337	1359	1388	1410	1438	1461	1480	1512	1540	1591	1642	1692
	+.10	1451	1479	1608	1630	1658	1681	1709	1732	1760	1811	1862	1912
													BALANCE POINT 33 DEG.F.

ANNUAL AIR CONDITIONING COST WHEN COOLING LOAD IS SIZED TO MATCH COOLING CAPACITY OF HEAT PUMP.

+.03	.04	.05	.06	.07	.08	.09	.10	.11	--ELECTRIC RATE \$/KWH		
\$.45	.113	.141	.170	.198	.226	.255	.283	.340	--THEORETICAL AIR CONDITIONING COST		

THE ABOVE ANNUAL HEATING AND COOLING OPERATING COSTS ARE THEORETICAL ESTIMATES ONLY AND ARE PROVIDED FOR A COMMON BASIS OF COMPARISON BETWEEN VARIOUS TYPES OF HEATING AND COOLING SYSTEMS. ACTUAL VALUES MAY VERY DEPENDING ON ACTUAL WEATHER CONDITIONS AND INDIVIDUAL USAGE PATTERN.

BARD MANUFACTURING COMPANY

DUAL FUEL ADD-ON HEAT PUMP GUIDE TO ENERGY COST SAVINGS

REGION 3
HEAT PUMP MODEL: OUTDOOR THERMOS **INDOOR-H380ZH380L**
ARI RATED COOLING CAP. BTUH (47) 23500 COP(4.7) 2.21 **MSPF 0.850 MIN.DHR REG IV**
BTUH (17) 10200 COP(17) 0.90 **FURNACE EFFICIENCY 0.82003.6EUE**
FURNACE TYPE PROPANE GAS

HEAT LOSS BTUH	ELEC. COST \$/KWH	PROPANE GAS COST - \$/GALLON											
		.60	.65	.70	.75	.80	.85	.90	.95	1.00	1.10	1.20	1.30
30,000 --THEORETICAL HEATING COST + FURNACE ONLY													
103	\$ 262	262	268	248	248	253	253	253	259	259	265	265	265
104	\$ 215	215	321	321	321	327	327	327	332	332	338	338	338
105	\$ 349	349	304	304	304	400	400	400	406	406	411	411	411
106	\$ 262	262	406	406	406	473	473	473	479	479	485	485	485
107	\$ 536	536	541	541	541	547	547	547	552	552	558	558	558
108	\$ 409	409	615	615	615	620	620	620	626	626	631	631	631
109	\$ 688	688	694	694	694	699	699	699	705	705	710	710	710
110	\$ 761	761	767	767	767	773	773	773	778	778	784	784	784
112	\$ 908	908	914	914	914	918	918	918	925	925	931	931	931
35,000 --THEORETICAL HEATING COST + FURNACE ONLY													
103	\$ 267	267	293	299	304	304	310	315	321	327	327	327	327
104	\$ 264	264	372	378	383	383	389	394	400	406	406	406	406
105	\$ 507	507	457	457	457	468	468	473	479	485	490	490	490
106	\$ 210	210	426	521	521	527	527	531	538	538	544	544	544
107	\$ 595	595	615	620	626	626	631	631	637	643	648	648	648
108	\$ 594	594	629	729	729	730	730	730	737	737	743	743	743
109	\$ 776	776	784	784	789	794	798	800	805	812	818	818	818
110	\$ 863	863	864	874	874	880	880	885	891	893	902	902	902
112	\$ 1026	1026	1032	1038	1043	1043	1049	1055	1060	1066	1066	1066	1066
40,000 --THEORETICAL HEATING COST + FURNACE ONLY													
103	\$ 315	318	366	369	355	361	361	366	372	382	394	394	394
104	\$ 413	423	428	434	440	425	445	451	461	468	474	474	474
105	\$ 507	513	515	516	516	538	538	541	541	558	569	569	569
106	\$ 596	593	600	615	620	626	626	631	637	648	650	650	650
107	\$ 688	694	699	705	710	716	716	722	727	736	750	750	750
108	\$ 778	784	789	795	795	800	804	812	818	826	840	840	840
109	\$ 868	874	880	885	891	897	897	902	908	919	931	931	931
110	\$ 959	964	970	976	981	987	987	993	998	1001	1021	1021	1021
112	\$ 1134	1139	1145	1151	1156	1162	1162	1166	1173	1184	1196	1196	1196
50,000 --THEORETICAL HEATING COST + FURNACE ONLY													
103	\$ 440	451	602	468	679	690	802	513	524	547	569	569	569
104	\$ 539	547	558	564	575	586	596	609	620	643	665	665	665
105	\$ 637	648	660	665	677	686	699	710	722	746	767	767	767
106	\$ 739	750	761	767	778	789	801	812	823	846	868	868	868
107	\$ 840	852	863	868	880	891	902	914	925	947	970	970	970
108	\$ 942	953	964	970	981	993	1004	1015	1026	1049	1072	1072	1072
109	\$ 1043	1055	1066	1072	1083	1094	1105	1117	1128	1151	1173	1173	1173
110	\$ 1145	1158	1168	1173	1184	1196	1207	1218	1230	1252	1275	1275	1275
112	\$ 1342	1354	1365	1371	1382	1393	1404	1416	1427	1450	1472	1472	1472
60,000 --THEORETICAL HEATING COST + FURNACE ONLY													
103	\$ 558	575	598	615	637	654	677	694	710	720	789	789	789
104	\$ 665	682	705	722	746	761	784	801	816	842	897	897	897
105	\$ 773	789	812	828	852	868	891	908	926	964	1004	1004	1004
106	\$ 880	897	916	936	956	976	998	1015	1032	1072	1112	1112	1112
107	\$ 993	1010	1032	1048	1072	1089	1111	1128	1156	1184	1224	1224	1224
108	\$ 1100	1122	1144	1166	1179	1196	1218	1235	1255	1292	1331	1331	1331
109	\$ 1207	1232	1254	1276	1296	1303	1326	1346	1366	1396	1438	1438	1438
110	\$ 1324	1354	1374	1393	1410	1426	1447	1467	1486	1506	1546	1546	1546
112	\$ 1336	1359	1374	1391	1413	1430	1453	1470	1487	1506	1566	1566	1566

ANNUAL AIR CONDITIONING COST WHEN COOLING LOAD IS SIZED TO MATCH COOLING CAPACITY OF HEAT PUMP.

1 103 104 105 106 107 108 109 110 112

2 --ELECTRIC RATE \$/KWH
3 --THEORETICAL AIR CONDITIONING COST

THE ABOVE ANNUAL HEATING AND COOLING OPERATING COSTS ARE THEORETICAL ESTIMATES ONLY AND ARE PROVIDED FOR A COMMON BASIS OF COMPARISON BETWEEN VARIOUS TYPES OF HEATING AND COOLING SYSTEMS. ACTUAL VALUES MAY VARY DEPENDING ON ACTUAL WEATHER CONDITIONS AND INDIVIDUAL USAGE PATTERN.

BARD MANUFACTURING COMPANY
DUAL FUEL ADD-ON HEAT PUMP GUIDE TO ENERGY COST SAVINGS

REGION # - MODEL: OUTDOOR 34HPDX INDOOR_M230_08-42101
 ARI RATED COOLING CAP.: BTUH 1981 -- SEER 7.50
 ARI RATED HEATING CAP.: BTUH 1471 -- COP 1.2-6.1, HSPF 6.50 MIN.DR. REC IV
 BTUH (LT) 24800, COP(LT) 1.2-6.1
 FURNACE TYPE ELECTRIC --- FURNACE EFFICIENCY 100.00% NEW

HEAT LOSS
BTUH ELEC.
 COST
 \$/KWH

40,000 --- THEORETICAL ANNUAL HEATING COST --- HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY			
+03	\$	321	603
+04	\$	428	806
+05	\$	536	1010
+06	\$	643	1213
+07	\$	750	1416
+08	\$	857	1619
+09	\$	964	1822
+10	\$	1066	2025
+12	\$	1280	2431
			BALANCE POINT 16 DEG.F.
50,000 --- THEORETICAL ANNUAL HEATING COST --- HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY			
+03	\$	406	756
+04	\$	536	1010
+05	\$	641	1263
+06	\$	806	1517
+07	\$	942	1771
+08	\$	1072	2025
+09	\$	1213	2279
+10	\$	1342	2533
+12	\$	1608	3041
			BALANCE POINT 23 DEG.F.
60,000 --- THEORETICAL ANNUAL HEATING COST --- HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY			
+03	\$	490	908
+04	\$	654	1213
+05	\$	823	1517
+06	\$	987	1822
+07	\$	1151	2127
+08	\$	1314	2431
+09	\$	1478	2736
+10	\$	1642	3041
+12	\$	1969	3650
			BALANCE POINT 27 DEG.F.
70,000 --- THEORETICAL ANNUAL HEATING COST --- HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY			
+03	\$	592	1060
+04	\$	789	1416
+05	\$	987	1771
+06	\$	1184	2127
+07	\$	1376	2431
+08	\$	1574	2838
+09	\$	1771	3193
+10	\$	1969	3549
+12	\$	2364	4260
			BALANCE POINT 31 DEG.F.
80,000 --- THEORETICAL ANNUAL HEATING COST --- HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY			
+03	\$	705	1213
+04	\$	942	1517
+05	\$	1173	2025
+06	\$	1410	2431
+07	\$	1647	2838
+08	\$	1884	3244
+09	\$	2115	3650
+10	\$	2353	4057
+12	\$	2821	4869
			BALANCE POINT 34 DEG.F.

ANNUAL AIR CONDITIONING COST WHEN COOLING LOAD IS SIZED TO MATCH COOLING CAPACITY OF HEAT PUMP.

+03 +04 +05 +06 +07 +08 +09 +10 +12
\$ 117 \$156 \$195 \$234 \$273 \$312 \$351 \$390 \$468

--ELECTRIC RATE \$/KWH

--THEORETICAL AIR CONDITIONING COST

THE ABOVE ANNUAL HEATING AND COOLING OPERATING COSTS ARE THEORETICAL ESTIMATES ONLY AND ARE PROVIDED FOR A COMMON BASES OF COMPARISON BETWEEN VARIOUS TYPES OF HEATING AND COOLING SYSTEMS. ACTUAL VALUES MAY VARY DEPENDING ON ACTUAL WEATHER CONDITIONS AND INDIVIDUAL USAGE PATTERNS.

BARD MANUFACTURING COMPANY
DUAL FUEL ADD-ON HEAT PUMP GUIDE TO ENERGY COST SAVINGS

REGION 4
HEAT PUMP MODEL: OUTDOOR 62H00 INDOOR HS20
ART RATED COOLING CAP: BTUH 70,000 COP 2.07 SEER 8.00
ART RATED HEATING CAP: BTUH 147,000 COP 1.72 EER 8.00
BTUH 117,000 COP 1.71 EER 8.00
FURNACE TYPE ELECTRIC FURNACE EFFICIENCY 100.00% AFUE

HEAT LOSS
BTUH

ELEC.
COST
\$/KWH

40,000

--- THEORETICAL ANNUAL HEATING COST ---
HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

+03	\$	332	603
+04	\$	440	806
+05	\$	547	1010
+06	\$	650	1213
+07	\$	773	1416
+08	\$	885	1619
+09	\$	993	1822
+10	\$	1105	2025
+12	\$	1320	2431

BALANCE POINT 17 DEG.F.

50,000

--- THEORETICAL ANNUAL HEATING COST ---
HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

+03	\$	617	756
+04	\$	552	1010
+05	\$	688	1263
+06	\$	823	1517
+07	\$	964	1771
+08	\$	1105	2025
+09	\$	1241	2279
+10	\$	1382	2533
+12	\$	1698	3041

BALANCE POINT 23 DEG.F.

60,000

--- THEORETICAL ANNUAL HEATING COST ---
HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

+03	\$	502	908
+04	\$	671	1213
+05	\$	840	1517
+06	\$	1004	1822
+07	\$	1173	2127
+08	\$	1342	2431
+09	\$	1512	2735
+10	\$	1681	3041
+12	\$	2014	3650

BALANCE POINT 27 DEG.F.

70,000

--- THEORETICAL ANNUAL HEATING COST ---
HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

+03	\$	598	1060
+04	\$	806	1416
+05	\$	1004	1771
+06	\$	1207	2127
+07	\$	1405	2431
+08	\$	1602	2735
+09	\$	1805	3143
+10	\$	2008	3549
+12	\$	2409	4260

BALANCE POINT 31 DEG.F.

80,000

--- THEORETICAL ANNUAL HEATING COST ---
HEAT PUMP WITH ELECTRIC HEAT ELECTRIC HEAT ONLY

+03	\$	710	1213
+04	\$	953	1619
+05	\$	1190	2025
+06	\$	1427	2431
+07	\$	1664	2838
+08	\$	1901	3244
+09	\$	2138	3650
+10	\$	2375	4057
+12	\$	2849	4869

BALANCE POINT 34 DEG.F.

ANNUAL AIR CONDITIONING COST WHEN COOLING LD40 IS SIZED TO MATCH COOLING CAPACITY OF HEAT PUMP.

\$ 103 104 105 106 107 108 109 110 112

---ELECTRIC RATE \$/KWH

---THEORETICAL AIR CONDITIONING COST

THE ABOVE ANNUAL HEATING AND COOLING OPERATING COSTS ARE THEORETICAL ESTIMATES ONLY AND ARE PROVIDED FOR A COMMON BASIS OF COMPARISON BETWEEN VARIOUS TYPES OF HEATING AND COOLING SYSTEMS. ACTUAL VALUES MAY VARY DEPENDING ON ACTUAL WEATHER CONDITIONS AND INDIVIDUAL USAGE PATTERN.

